

60://WUSM NRB/WUSM_RB_SPOOLING MASTER.rvt

CUT AND PACKAGE ONLY. DO NOT ASSEMBLE.




AS-L07-007 - ISOMETRIC



A1 A3 B1 B3
A2 A4 B2 B4


2 **AS-L07-007** AS-L07-007SCALE: 1/2" = 1'-0"




JOB: WASH U NRB

TICKET:
AS-L07-007
Drawn By: Author

Mark	Qty	Size	Description	Length	Insulation	ROD 1	ROD 2	Strut Width	
01	1	3"	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	18'-10 5/8"	1 1/2"				
02	1	2"	Cerro Type K Hard Copper Pipe	17'-5 3/4"	1 1/2"				
03	1	2"	Cerro Type K Hard Copper Pipe	0'-10 3/4"	1 1/2"				
04	1	3"	Weldbend Std Wt SA234 WPB CS BW LR 90 Deg Ell		1 1/2"				
05	1	3/4"	Victaulic No.647 TT Dielectric Transition Fitting		1"				
06	1	2"x3/4"	Nibco Wrot 611R CxCxC Reducing Tee		1 1/2"				
07	1	2"	Nibco Wrot 607 90 Deg Ell CxC		1 1/2"				NRB
08	1	2"	Nibco Wrot 600 Dimpled Stop Coupling CxC		1 1/2"] =
09	1	3"x3/4"	Anvil 3000# FS Thread-O-Let		1"				$\rceil \supset $
10	3	C"	D Line D2000 ZN Coh 40 Pipe Clamp				0"		몽
11	3	5"	B-Line D2000 ZN Och 40 Pipe Olamp				0"		- -≺
12	3	50"	B-Line 1-5/8 GRN 12GA Bk/Bk 2in Slotted Unistrut			4` - 0 5/8"	2` - 8 5/8"	4` - 6"] >
10 3	6 5/8	8" B-LINE	E #2020						40 -
11 3	5 1/8	8" B-LINE	#2062						101
									2
									JOB:
									j








В3 А3 B1 A4 B2

BIM 360://WUSM NRB/WUSM RB HPF.rvt 2/1/2022 11:42:35 AM



тіскет: HP-L07-007

Drawn By: Author DATE: 11/17/21

1233 N. Price Rd. St. Louis, Mo 63132-2303 314-997-6600 phone