



Position of route through floor / wall for under floor heating cold tail, etc to be confirmed.

Room thermostat position to be confirmed.  
**Note: Thermostat is located inside bathroom - must be outside of zone 2.**

ThermoSphere Mesh  
TSM-150-0800 150W/m<sup>2</sup>  
16m x 0.5m mat.

1 no. heat sensor probe positioned between heating mat. Position indicative only.

All dimensions and details are approximate and must be checked on site.  
No part of this drawing may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopying, without prior permission in writing from ThermoSphere

DRAWING APPROVAL

CLIENT .....  
SIGNED .....  
DATE .....

thermo

Sphere

Bridge House, Pattenden Lane  
Marden, Kent TN12 9QJ

T: 0800 019 5899  
F: 08700 41 21 40  
[www.thermosphere.com](http://www.thermosphere.com)

Project:	
Description: Apartment 505 Master Bathroom Underfloor Heating Layout	
Date:	November 2021
Drawing No.	K1-BS-505-01
Scale:	1:20@A3
Rev	A

A	Mat layout revised.	11/03/2022
Rev	Description	Date