

Instrument: HVA 68-2
Serial Number: GH5228.22I001

- | | | |
|---|--|--------------------------|
| A | Check discharge Unit (Range 4.8MΩ to 6MΩ): | R _{EE} = 4.8 MΩ |
| B | Emergency-Off Check: | pass |
| C | Functional Check | pass |
| | DC+ / DC- / Sine / Square @ max. Voltage | |
| D | Burn-In Test, 1h with max. Voltage and full Load | pass |
| E | External Voltage 230V @ 50-60 Hz | pass |
| F | External Voltage 10kV @ 50-60 Hz | pass |
| G | Auto Calibration Sequence | pass |

H Voltage Measurement Check, Load > 500MΩ:

Range	V Set Value	V Reference	Tolerance (max 0.5%)
low positive [kV]	4.0	3.997	0.1%
low negative [kV]	-4.0	-3.998	0.1%
high positive [kV]	30.0	29.98	0.1%
high negative [kV]	-30.0	-30.02	0.1%
high positive [kV]	60.0	59.96	0.1%
high negative [kV]	-60.1	-60.03	0.1%

I Current Measurement Check, Load ~12MΩ / ~250kΩ

Range	I Set Value	I Reference	Tolerance (max 0.5%)
low positive [μA]	707	708	0.1%
low negative [μA]	-709	-708	0.1%
high positive [mA]	25.18	25.16	0.1%
high negative [mA]	-25.26	-25.24	0.1%

J Equipment used

	Model	ID#
High Voltage Probe	Vitretek HVL-150	P0660
Voltmeter	Vitretek4700	P0661
Currentmeter	Tektronix DMM4020	P0601

K Firmware Version: 4.20.6

L Final Inspection – grounding test pass

The test equipment used for this purpose is regularly calibrated against company standards that are traceable to National or International Standards.

Date of Calibration: 10/2025

Tested by: A. Kaplan

Calibration expires: 11/2026

Signature: *Adem Kaplan*



Calibration Certificate

for

PDC1

Serial No: GH5728.22A017

Certificate Number: GH5728.22A017.2

The test equipment used for this purpose is regularly calibrated against company standards that are traceable to National or International Standards.

Equipment used

Type:
ID#

RIGOL DS4A 194200506
P0610

Type:
ID#

Precision-Thermo-Hygrometer
P0394

Date of Calibration: 10/2025

Tested by: A. Kaplan

Calibration expires: 11/2026

Signature: *Adnan Kaplan*

Firmware Version:

V1.19.3

Functional Check:

pass

Ambient Conditions:

Ambient temperature:
Humidity:

22.0 °C
46 % r.H.

Pulse Charge:

Range	PDC1 [pC]	Ref. Value [pC]	Tolerance	Tolerance Allowed
- 10 pC	-10	-9.92	-0.8%	3.0%
- 20 pC	-20	-20.2	1.0%	3.0%
- 50 pC	-50	-50.1	0.2%	3.0%
- 100 pC	-100	-100.8	0.8%	2.0%
- 200 pC	-200	-199.0	-0.5%	2.0%
- 500 pC	-500	-504.0	0.8%	2.0%
- 1 nC	-1000	-996.0	-0.4%	2.0%
- 2 nC	-2000	-2020.0	1.0%	2.0%
- 5 nC	-5000	-5040.0	0.8%	2.0%
- 10 nC	-10000	-10080.0	0.8%	2.0%

Range	PDC1 [pC]	Ref. Value [pC]	Tolerance	Tolerance Allowed
10 pC	10	9.96	-0.4%	3.0%
20 pC	20	19.9	-0.5%	3.0%
50 pC	50	49.9	-0.2%	3.0%
100 pC	100	99.6	-0.4%	2.0%
200 pC	200	201.0	0.5%	2.0%
500 pC	500	504.0	0.8%	2.0%
1 nC	1000	996.0	-0.4%	2.0%
2 nC	2000	2020.0	1.0%	2.0%
5 nC	5000	5040.0	0.8%	2.0%
10 nC	10000	10080.0	0.8%	2.0%

Connection cable 0.5m into 50 Ohms input



Calibration Certificate PDTD60-2

Certificate Number
GH5715.22I001.2

TD calibration

- I LED Functional Check (both sides) pass
J Ground Connection Check pass
K Burn-In Test, 1h with max. Voltage and full Load pass

L Voltage Measurement Check

Voltage Setpoint [kV]	5.007	30.02	60.02
TD Voltage [kV]	5.004	29.98	59.97
Error (max. 0.3%)	0.1%	0.1%	0.1%

M Current Measurement Check, Load 37MOhm/ 1MOhm

Current Setpoint [mA]	0.2048	10.03
TD Current [mA]	0.205	10.02
Error (max. 0.3%)	0.1%	0.1%

N Tan Delta / Dissipation Factor Test Load 15nF @ 0.1Hz

Voltage Setpoint [kVrms]	11.0	22.0	33.0	44.0
Voltage TD60 [kVrms]	11.0	22.0	33.0	44.0
TD Reference [E-3]	0.5	0.8	0.8	0.8
TD Measured [E-3]	0.6	0.8	0.9	0.8
TD Tolerance range [E-3]	+/- 0.1	+/- 0.1	+/- 0.1	+/- 0.1

O Equipment used

	Model	ID#
High Voltage Probe	Vitrek HVL-150	P0866
Voltmeter	Vitrek4700 HV Meter	P0867
Currentmeter	Fluke 87V	P0252
TD-RT90	Test Capacitor 15nF 90kV peak	P0576
0.1Hz Power Supply	HVA94	P0694
Calibrator	PDC1	P0616

- P TD Firmware Version: 2.40.3
Q Final Inspection – grounding test Pass

Date of Calibration: 10/2025

Tested By: A. Kaplan

Calibration Expires: 11/2026

Signature: *Adem Kaplan*

	Calibration Certificate PDTD60-2	Certificate Number GH5715.22I001.2
---	---	---------------------------------------

Instrument: **PDTD60-2**

A System equipment
PDTD60-2 CC **GH5715.22I001**
TD Serialnumber GH5301.22P001
PD60-2 Filter GH5712.22I001

B LED Functional Check pass
Battery
Mains

C Supply Test pass
Mains Supply
Battery / Battery Charger

D Communication Check pass
PDTD60-2 – PC
Remote Control with HVA

E PD level measurement check

PD reference [pC]	100	500
PD measured [pC]	102	495
PD tolerance range [E-3]	2.0%	1.0%
Max +/- 3%		

F Functional Check pass
PD level ≤50pC at full voltage (44kVrms)

G PD detection and localization pass

H Software Version b2Suite 2.0.2.59
Functional check