

LOAD CALCULATOR BASIC QUICKSTART

This is a field-first, one-page quick guide for first-time users.

What this tool does

'Load Calculator Basic' estimates:

- total connected load (kW)
- recommended generator size (kW) using the 80% loading rule
- fuel runtime estimate (gallons-based)

Use it for planning and rapid field checks. It is not a final engineering design tool.

Open and run

1. Open 'index.html' in a modern browser.
2. No internet or server is required.
3. All save/autosave data stays in the current browser on the current device.

Fast workflow (recommended)

1. Enter quantities for equipment rows.
2. Use 'Sort' and 'Search' to focus the list.
3. Review side cards:
 - 'Total connected load (all items)'
 - 'Recommended generator'
 - 'Check Against Available Generator'
 - 'Fuel & Runtime Estimate'
4. Enter:
 - 'Available generator capacity' (kW)
 - 'Fuel Tank Capacity' (Gallons)
5. Print or save/export as needed.

Scenarios and files

- 'Save Scenario': save current worksheet as a named scenario.
- 'Load/Delete/Clear all': manage saved scenarios in this browser.
- 'Export to file': create a JSON backup/share file.
- 'Import from file': load a JSON scenario file.

If imported data has issues, the tool sanitizes values and can download a text report describing what was corrected.

Autosave (toolbar)

- 'Clear Autosaved State': removes worksheet recovery state only.
- 'Last autosaved': shows latest autosave timestamp.
- Named saved scenarios are **not** deleted by clearing autosave state.

Reset buttons

- 'Reset Quantities': clears quantities only.
- 'Reset Worksheet': clears worksheet fields and custom rows.

Both actions ask for confirmation before applying.

Important usage notes

- Search filters the view, but all-items totals remain authoritative.
- 'Filtered view load' appears only when search is active.
- Confirm critical equipment nameplate ratings and starting behavior before final decisions.

Safety/disclaimer

This calculator is a simplified estimator for planning support. Final electrical sizing must be validated by qualified engineering personnel.