COLLECTION OF CTL DECISIONS

Standard: Generality	**Sub clause: ---**	**Sheet n. 9A** **Page 1(1)**
Subject: Electric strength test: Speed of increasing the test voltage	**Key words:** **- electric strength** **- test voltage**	**Decision n. taken at 16th meeting/1979**

Question:

Electric strength test: What is the speed of increasing the test voltage when the standard specifies just “quickly”or does not give a clear specification ?

Decision:

The following tets procedure has to be adopted: “Initially, not more than half the prescribed voltage is applied, then it is raised rapidly to the full value”

Explanatory notes: