COLLECTION OF CTL DECISIONS

Standard: GENERALITY	Sub clause: ---	Sheet n. 166A Page 1(1)
Subject: Acceptance of cross-slotted screws	**Key words:** **- cross-slotted screw**	**Decision n. 15 taken at 17th meeting/1980**

Question:

Are cross-slotted screws generally accepted in electrical equipment ?

Decision:

Yes, without any restriction, as the tool used for this type of screws cannot be considered as a special tool

Explanatory notes: