☑ CTL Provisional DECISION SHEET (PDSH)
☐ CTL DECISION SHEET (DSH)

Standard(s) (incl. year)	**Subclause(s)**	**Tracking No.**
IEC 60947-1:2024 Ed.6	9.3.4.1.2 b) and Fig. 9 – 11 Test circuits	2286
Category		
POW		
Subject	**Keywords**	**Developed by**
Time interval between two successive short-circuit operations	Resetting time, reclose, short-circuit	ETF 7

Question

If the manufacturer states in the documentation, that checks need to be done on the CB (circuit breaker), which leads to a longer time than the required 3 minutes (e.g. 15 minutes due to checks), is it allowed to extend the time between two successive short-circuit operations (O-t-CO) to be longer than 3 minutes, even if the circuit breakers resetting time would allow a sooner reclosing?

Decision

If a CB (circuit breaker) can be reclosed after 3 min, then the time between two successive short-circuit operations may not be extended.

Explanatory notes

Enquiry:
Date: 2025-04-24

PDSH:
Year of publication: 2025
To be approved at CTL plenary: 2026

DSH
Publication date: ---

Customer request to extend time interval between two successive short-circuit operations, even when the circuit breaker can be reclosed.

Disclaimer: This document is controlled and has been released electronically.
Only the version on the IECEE Website is the current document version.