☑ CTL Provisional DECISION SHEET (PDSH)

☐ CTL DECISION SHEET (DSH)

Standard(s) (incl. year)	**Subclause(s)**	**Tracking No.**
IEC 62196-1:2022	16.5	2278
Category		
ELVH		
Subject	**Keywords**	**Developed by**
Maximum permissible temperature for parts used in higher ambient temperature than 40°C	Temperature rise	ETF 14
Question		
1. Shall the test result be corrected to the declared max. ambient temperature if it is higher than 40°C? (e.g., 50°C) 2. Shall the limited value of clause 16.5 be changed when the declared max. ambient temperature is higher than 40°C?		
Decision		
1. The test result shall be corrected to the declared max. ambient temperature. 2. The limited value of clause 16.5 shall remain unchanged even if the higher ambient temperature is declared.		
Explanatory notes		
Enquiry: Date: 2025-02-17		
PDSH: Year of publication: 2025 To be approved at CTL plenary: 2025-03		
DSH Publication date: N/A		

Disclaimer: This document is controlled and has been released electronically.
Only the version on the IECEE Website is the current document version.