☑ CTL Provisional DECISION SHEET (PDSH)
☐ CTL DECISION SHEET (DSH)

Standard(s) (incl. year)	**Subclause(s)**	**Tracking No.**
IEC 62619:2022	Clause 6.2 Clause 11	2281
Category		
BATT		
Subject	**Keywords**	**Developed by**
Capacity confirmation for battery system and capacity marking	Capacity, Marking	ETF 13

Question

According to clause 6.2 Test items, “tests are made with the number of cells or battery systems specified in Table 1, using cells or battery systems that are stored for not more than six months, under conditions specified by the cell or battery system manufacturer.”

Q1:

For compliance within the CB Scheme, shall the capacity confirmation be obtained by

a. Acceptance
   - for cells, of the cell manufacturer shipping inspection report,
   - for battery systems, of calculation based on the cell capacity as measured during the cell manufacturer shipping inspection provided by battery system manufacture

   or
b. A capacity confirmation test performed by the CBTL prior to the test sequence in clause 7?

According to Clause 11 marking and designation, which states, “Refer to Clause 5 of IEC 62620: 2014”, the battery system shall bear a rated capacity marking in accordance with Clause 5 of IEC 62620:2014.

Q2: How to verify the capacity of the battery system for the marking?

Decision

A1: Option b., the capacity confirmation test performed by the CBTL prior to the test sequence in clause 7.

A2: The capacity of the cells shall be measured in conjunction with clause 7.1 using the sample tested in clause 7.2.5 (Overcharge test) to ensure the samples are healthy and correct. (“Healthy and correct” means capacity and voltage are no less than the cell specification.)

In the case of a battery system, the capacity may be calculated based on the verified cell capacity.

Explanatory notes

Enquiry:
Date: 2024-08-06

PDSH:
Year of publication: 2025
To be approved at CTL plenary: 2026

DSH
Publication date:

None.

Disclaimer: This document is controlled and has been released electronically.
Only the version on the IECEE Website is the current document version.