



METER TEST PROVING RECORD

Quorum Calibration, LLC

Date of Test 5/5/2026

Last Test Date _____

Location Chelsea Global			Address 281 Eastern Ave, Chelsea, MA 02150			Product ULSD			Thruput Since Last Test			Product Gravity 38			
Meter Make Smith			Model # F4S1			Size 4"			Serial# KM-107556			Meter ID# L1A2			
Last Test Totalizer Finish			This Test Start			This Test Finish			Prover Serial # 1459			Prover Size 1000 Gallons			
RUN#															
FLOW RATE	380			380											
A) PROVER TANK READING	996.2			996.89											
B) PROVER TEMPS Top / Mid / Bot	60	60	60	60	60	60									
C) AVERAGE PROVER TEMP	60.00000			60.00000			0.00000			0.00000			0.00000		
D) CTS METAL FACT.	1			1			0.99926			0.99926			0.99926		
E) CTL (TABLE 6-B)	1.00000			1.00000			0.00000			0.00000			0.00000		
F) NET PROVER READING	996.20			996.89			0.00			0.00			0.00		
G) METERED AMOUNT	1001.21			995.22											
H) INVOICE TEMP.	60			60											
I) CTL (TABLE 6-B)	1.00000			1.00000			0.00000			0.00000			0.00000		
J) NET METER READING	1001.210			995.220			0.000			0.000			0.000		
K) NET ERROR GALS.	-5.0100			1.6700			0.0000			0.0000			0.0000		
L) METER ERROR %	-0.5004			0.1678			0.0000			0.0000			0.0000		
M) CUBIC INCHES	-1157.31			385.77			0.00			0.00			0.00		
N) PRESENT METER FACTOR	0.9950			1.0017			0.0000			0.0000			0.0000		
O) PRESENT METER FACTOR	1.04235			1.04235											
P) NEW METER FACTOR	1.03713			1.0441			0.00000			0.00000			0.00000		

METER SEAL #: _____

COMMENTS: _____

Performed By: _____

Factor goes DOWN to bring product UP
Factor goes UP to bring product DOWN