

Proving

Meter: GC_L6_A1_ULSD - Global Chelsea ULSD
Field Location: CHELSEA
Reason:
Date Performed: 5/4/2026 11:03:11AM

1869 IH 37 Access Rd
George West, TX
78022



Identification		
Customer:	GLOBAL - Global	Operator: GLOBAL - Global
		Federal ID:

Meter			
Characteristics			
Brand:		Nominal K-Factor:	200.0000 N/gal
Model:		Nominal Size:	4.00 in
Serial:	n/a	Passes Per Run:	1
Proving Mode:	Volumetric	Tmp. Compensated:	No
MF Calc. Method:	Avg. Meter Factor	Interface:	PIU
Track Factor:	Meter Factor	Density Mode:	Manual
Proving Acceptance Criteria			
Repeatability:	0.050 %	Consistency Req.:	3 out of 3
	Prior	Historical	Baseline
Prior Dev Check:	Yes	No	No
Max Deviation:	0.25 %		
No. Prev. Factors:			
Prior Cutoff:	No	No	
Product Dependent:	No		
Use Failed Provings:	Yes		

Prover/Proving			
Prover			
Prover Class:	Displacement	Cubical Coeff. (Gc):	2.88E-5 1/°F
Displacer:	Sphere	Elasticity:	2.8E7 psi
Brand:	Quorum 6" Ball	Base Prover Vol.:	0.955332 bbl
Serial:	QC3	Cert. Date:	
Pipe ID:	6.065 in		
Pipe Thickness:	0.280 in		
Product Data			
Product:	Diesel		
Product Table:	Table B - Refined Products (2004)		
Hydro. Correction:	Yes		
Density:	37.7 °API		
@ Temperature:	60.0 °F	Equil. Vapor Pres.:	0.0 psig
@ Pressure:	0.0 psi	Base Density:	37.7 °API
Product Batch #:			
Norm. Op. Press.:			

Proving									
					Run Data				
Run No.	Accepted	Tp (°F)	Tm (°F)	Pp (psig)	Pm (psig)	Ni	FlowRate	IMF	
1	Yes	55.6	55.6	9.3	9.3	7698.609	247.792	1.04224	
2	Yes	54.5	54.5	9.5	9.5	7697.074	247.552	1.04242	
3	Yes	54.2	54.2	9.8	9.8	7697.373	257.597	1.04237	
Average		54.8	54.8	9.5	9.5	7697.6853	250.981	1.04234	
Results									
- Meter -		- Prover -		- Factors -		- Status -			
Nm:	7697.6853	CTSp:	.99985	MF:	1.0423	Repeatability:	0.017 %		
IVm:	38.4884	CPSp:	1.00001	CMF:	1.0423	Uncertainty:	0.026 %		
CTLm:	1.00246	CTLp:	1.00246	MA:	0.9594	Prior Dev.:	0.0575 %		
CPLm:	1.00005	CPLp:	1.00005	KF:	191.88	Passed:	Yes		
CCFm:	1.00251	CCFp:	1.00237	CKF:	191.88				
ISVm:	38.5850	GSVp:	40.2190	CPLo:	1.0000				

Historical Data											
	Task ID	Date	Product	Flow Rate	Tp	Pp	Totalizer	Throughput	Base Dens	Rep. %	MF
Base.											MF Dev
Prev.	1757634437	09/11/2025 13:47	Diesel	229 gal/min	72.7 °F	9.3 psig			36.0 °API	0.008	1.0429
Curr.	1777928591	05/04/2026 11:03	Diesel	251 gal/min	54.8 °F	9.5 psig			37.7 °API	0.017	1.0423

Notes											



Proving

Meter: GC_L6_A1_ULSD - Global Chelsea ULSD
Field Location: CHELSEA
Reason:
Date Performed: 5/4/2026 11:03:11AM

1869 IH 37 Access Rd
George West, TX
78022



Meter Factor History



Equipment

	Brand	Model	Serial	Dev Range	Cal Range	Accuracy	Last Cert. Date
Meter:			n/a				

