



**SYMPHONY**  
Critical Power Solutions

# TECHNICAL SERVICE JOB CARD

JOB CARD NO: **40762**

## CUSTOMER & SERVICE DETAILS

Client Name:	KCB	Service Date:	12/05/23		
Personnel Name:	LEWIS	Start Time:	2:30pm	End Time:	3:34pm
Site Name:	KNH	Town:	NRA		

## EQUIPMENT DETAILS

NO.	EQUIPMENT MODEL	SERIAL NO.	FAULT DESCRIPTION/STATUS
1.	DELTA 3KVA	37016400242MA	UPS faulty
2.			
3.			

## EQUIPMENT ENVIRONMENT

Cleanliness	OK
Ac & Ventilation	AC NOT working
Recommendation	none

## ACTIONS/ ACTIVITIES CARRIED OUT/ ISSUES NOTED

- Found ACIM OFF.
- UPS faulty
- Inverter etc

## BATTERY READINGS

No. of Strings:		Battery Qty:		Rating:		V		Ah	Total Voltage:	V
1.	2.	3.	4.	5.	6.	7.	8.	9.	10.	
11.	12.	13.	14.	15.	16.	17.	18.	19.	20.	
21.	22.	23.	24.	25.	26.	27.	28.	29.	30.	
31.	32.	33.	34.	35.	36.	37.	38.	39.	40.	

## RECOMMENDATIONS/ CONCLUSIONS

- Left panel on inverter
- took UPS to workshop for repair.

## SITE & CUSTOMER APPROVAL

Site Contact Person:	Moses Odundo	Signature:	<i>[Signature]</i>	Date:	12/05/23
Client Contact Person:		Signature		Date & Stamp:	