

TECHNICAL SERVICE JOB CARD

JOB CARD NO: **40268**

CUSTOMER & SERVICE DETAILS

Client Name:	K.C.B	Service Date:	05/04/2023		
Personnel Name:	Shem / John	Start Time:	0930hrs	End Time:	1400hrs
Site Name:	KCB Kencom	Town:	Nairobi		

EQUIPMENT DETAILS

NO.	EQUIPMENT MODEL	SERIAL NO.	FAULT DESCRIPTION/STATUS
1.	LP Series 60KVA		Preventive maintenance
2.	URS 1, 2, 3 and 4		
3.			

EQUIPMENT ENVIRONMENT

Cleanliness	ok
Ac & Ventilation	ok
Recommendation	None.

ACTIONS/ ACTIVITIES CARRIED OUT/ ISSUES NOTED

- Checked on fan functionality of the four URSs.
- Opened and cleaned the URSs.
- Measured and recorded the batteries voltage while running on batteries support for 6 minutes.
- The battery discharge was okay and reconnected back the URS.
- Collected event logs.


BATTERY READINGS

No. of Strings:		Battery Qty:		Rating:		V		Ah		Total Voltage:		V	
1.	2.	3.	4.	5.	6.	7.	8.	9.	10.				
11.	12.	13.	14.	15.	16.	17.	18.	19.	20.				
21.	22.	23.	24.	25.	26.	27.	28.	29.	30.				
31.	32.	33.	34.	35.	36.	37.	38.	39.	40.				

RECOMMENDATIONS/ CONCLUSIONS

- Report based on battery voltage data recorded and event logs taken will be provided after analysis.
- Left the URS supporting the load comfortably.

SITE & CUSTOMER APPROVAL

Site Contact Person:	Signature:	Date:
Client Contact Person: Dorcas Litunya	Signature: 	Date & Stamp:

For: KCB BANK KENYA LTD.

12/04/2023 
GIGIRI DRS, FACILITIES DEPARTMENT

GIGIRI DRS, FACILITIES DEPARTMENT
For: KCB BANK KENYA LTD.