

TECHNICAL SERVICE JOB CARD

JOB CARD NO: **31489**

CUSTOMER & SERVICE DETAILS

Client Name:	ETCO BANK	Service Date:	22/09/2022
Personnel Name:	DAVID AGISU	Start Time:	End Time:
Site Name:	NAGURU BRANCH	Town:	

EQUIPMENT DETAILS

NO.	EQUIPMENT MODEL	SERIAL NO.	FAULT DESCRIPTION/STATUS SERVICE
1.	PW9120SDD01	1026103	In good working condition
2.			
3.			

EQUIPMENT ENVIRONMENT

Cleanliness	✓
Ac & Ventilation	✓
Recommendation	✓

ACTIONS/ ACTIVITIES CARRIED OUT/ ISSUES NOTED

- Input voltage checked 240V
- Output voltage checked 230V
- Battery voltage checked 260V
- All other components checked okay.

BATTERY READINGS

No. of Strings:	Battery Qty:	Rating:	Ah	Total Voltage:
1. 13.5V	2. 13.6V	3. 13.4V	4. 13.3V	5. 13.2V
6. 13.5V	7. 13.4V	8. 13.1V	9. 13.2V	10. 13.5V
11. 13.2V	12. 13.5V	13. 13.4V	14. 13.2V	15. 13.4V
16. 13.2V	17. 13.5V	18. 13.2V	19. 13.4V	20. 13.5V
21. 13.2V	22. 13.5V	23. 13.4V	24. 13.2V	25. 13.4V
26. 13.2V	27. 13.5V	28. 13.4V	29. 13.2V	30. 13.4V
31. 13.2V	32. 13.5V	33. 13.4V	34. 13.2V	35. 13.4V
36. 13.2V	37. 13.5V	38. 13.4V	39. 13.2V	40. 13.4V

RECOMMENDATIONS/ CONCLUSIONS

- Up serviced all components checked, cleaned & polished
- left in good working condition

SITE & CUSTOMER APPROVAL

Site Contact Person:	Signature:	Date:
Client Contact Person: Naomi Muntia	Signature: [Signature]	Date & Stamp: 22/09/2022

