

# TECHNICAL SERVICE JOB CARD

JOB CARD NO: **46810**

## CUSTOMER & SERVICE DETAILS

Client Name:	Total Energies	Service Date:	2/05/2023
Personnel Name:	David Agre	Start Time:	End Time:
Site Name:	hpg	Town:	Industrial area

## EQUIPMENT DETAILS

NO.	EQUIPMENT MODEL	SERIAL NO.	FAULT DESCRIPTION/STATUS
1.	hpg series	hpg05051A24/12	ups Pm
2.		01A071	
3.			

## EQUIPMENT ENVIRONMENT

Cleanliness	✓
Ac & Ventilation	✓
Recommendation	✓

## ACTIONS/ ACTIVITIES CARRIED OUT/ ISSUES NOTED

- Input Cables checked and tightened
- Input voltage checked OK
- Battery voltage checked OK
- All components checked and confirmed okay

## BATTERY READINGS

No. of Strings:		1		Battery Qty:		20		Rating:		12 V 7 Ah		Total Voltage:		240 V	
1.	2.	3.	4.	5.	6.	7.	8.	9.	10.						
11.	12.	13.	14.	15.	16.	17.	18.	19.	20.						
21.	22.	23.	24.	25.	26.	27.	28.	29.	30.						
31.	32.	33.	34.	35.	36.	37.	38.	39.	40.						

## RECOMMENDATIONS/ CONCLUSIONS

- Ups serviced and left in good working condition

## SITE & CUSTOMER APPROVAL

Site Contact Person:	BESIAS WONGRE	Signature:	[Signature]	Date:	02/05/2023
Client Contact Person:		Signature:		Date & Stamp:	

