

JOB CARD NO: **30487**
**CUSTOMER & SERVICE DETAILS**

Client Name:	GE H/C	Service Date:	13/01/23
Personnel Name:	Daniel K. Nganga	Start Time:	End Time:
Site Name:	Malindi Sub-County	Town:	MALINDI

**EQUIPMENT DETAILS**

NO.	EQUIPMENT MODEL	SERIAL NO.	FAULT DESCRIPTION/STATUS
1.	SMC1500LC	A52137261610	PM Service
2.			
3.			

**EQUIPMENT ENVIRONMENT**

Cleanliness	OK.
Ac & Ventilation	Ventilation OK.
Recommendation	

**ACTIONS/ ACTIVITIES CARRIED OUT/ ISSUES NOTED**

Found UPS in operation.
Switched off and Service Carried out.
Batteries were checked and tested.
Input and output voltages were tested/checked.


**BATTERY READINGS**

No. of Strings:	1		Battery Qty:	2		Rating:	12 V 10(17) Ah		Total Voltage:	26.6V
1. 13.3	2. 13.2	3.	4.	5.	6.	7.	8.	9.	10.	
11.	12.	13.	14.	15.	16.	17.	18.	19.	20.	
21.	22.	23.	24.	25.	26.	27.	28.	29.	30.	
31.	32.	33.	34.	35.	36.	37.	38.	39.	40.	

**RECOMMENDATIONS/ CONCLUSIONS**

UPS was serviced and left working OK.
---------------------------------------

**SITE & CUSTOMER APPROVAL**

Site Contact Person:		Signature:		Date:	
Client Contact Person:	SAMSON JINDWA	Signature		Date & Stamp:	13 JAN 2023

