

TECHNICAL SERVICE JOB CARD

40761

JOB CARD NO:

CUSTOMER & SERVICE DETAILS			
Client Name:	GE Health Care	Service Date:	10/05/2023
Personnel Name:	Lewis	Start Time:	11:30am
Site Name:	Consolata Hospital	End Time:	19:30hrs
		Town:	NKUBU.

EQUIPMENT DETAILS			
NO.	EQUIPMENT MODEL	SERIAL NO.	FAULT DESCRIPTION/STATUS
1.	SG SI 60KVA	S10601917B316F	UPS service
2.			
3.			

EQUIPMENT ENVIRONMENT	
Cleanliness	Clean
Ac & Ventilation	O/K
Recommendation	None

ACTIONS/ ACTIVITIES CARRIED OUT/ ISSUES NOTED
- UPS found running normally supporting the load but with audible alarm
- Preventive maintenance carried out successfully. Batteries tested & re-bailed.
- Inverter and mains voltages calibration done. Downloaded events & parameters for further analysis and reporting.

BATTERY READINGS									
No. of Strings:	1	Battery Qty:	30	Rating:	12 V	40 Ah	Total Voltage:	409 V	02
1.	2.	3.	4.	5.	6.	7.	8.	9.	10.
11.	12.	13.	14.	15.	16.	17.	18.	19.	20.
21.	22.	23.	24.	25.	26.	27.	28.	29.	30.
31.	32.	33.	34.	35.	36.	37.	38.	39.	40.

RECOMMENDATIONS/ CONCLUSIONS
- UPS left running normally after service but with alarm 4531 "inverter and mains not synchronised" because generator is running. Frequency out of tolerance. Otherwise UPS is O.K.

SITE & CUSTOMER APPROVAL			
Site Contact Person:		Signature:	Date:
Client Contact Person:	DERRICK	Signature	Date & Stamp:

