

# TECHNICAL SERVICE JOB CARD

JOB CARD NO: **40809**

## CUSTOMER & SERVICE DETAILS

Client Name:	Total Energies	Service Date:	28/04/2023
Personnel Name:	David Agutu	Start Time:	End Time:
Site Name:	JKIA	Town:	Nairobi

## EQUIPMENT DETAILS

NO.	EQUIPMENT MODEL	SERIAL NO.	FAULT DESCRIPTION/STATUS
1.	LP Series	2051A24/1717A	ups gm
2.		590	
3.			

## EQUIPMENT ENVIRONMENT

Cleanliness	✓
Ac & Ventilation	✓
Recommendation	✓

## ACTIONS/ ACTIVITIES CARRIED OUT/ ISSUES NOTED

- Ups Input Output voltage checked okay
- ups charger board components checked okay
- ups cooling fan checked not functioning well
- ups batteries checked faulty
- ups casing cleaned and polished.
- ups dust removed on boards.

## BATTERY READINGS

No. of Strings:		1		Battery Qty:		20		Rating:		12 V 7 Ah		Total Voltage:		240V	
1.	2.	3.	4.	5.	6.	7.	8.	9.	10.						
11.	12.	13.	14.	15.	16.	17.	18.	19.	20.						
21.	22.	23.	24.	25.	26.	27.	28.	29.	30.						
31.	32.	33.	34.	35.	36.	37.	38.	39.	40.						

## RECOMMENDATIONS/ CONCLUSIONS

All batteries need to be replaced (12v 7AH) 20 pieces.
--

TOTAL ENERGIES MARKETING KENYA PLC

J.K.I.A AVIATION DEPOT

SITE & CUSTOMER APPROVAL P. O. Box 30735 - 00100

Site Contact Person:	NAIROBI	Signature:		Date:	
Client Contact Person:		Signature	RW	Date & Stamp:	