

TECHNICAL SERVICE JOB CARD

JOB CARD NO: **40663**

CUSTOMER & SERVICE DETAILS

Client Name:	1-muni KCB	Service Date:	12/4/2023
Personnel Name:	Devin mwayi	Start Time:	End Time:
Site Name:	1 muni	Town:	Maringi

EQUIPMENT DETAILS

NO.	EQUIPMENT MODEL	SERIAL NO.	FAULT DESCRIPTION/STATUS
1.	ABB 31UA		UPS Repair
2.			
3.			

EQUIPMENT ENVIRONMENT

Cleanliness	Oil
Ac & Ventilation	Oil
Recommendation	None

ACTIONS/ ACTIVITIES CARRIED OUT/ ISSUES NOTED

-	Returned back the UPS on 6hr
-	Replaced 12417 Batteries 1st 7 6pcs
-	Mounted 4way Consumable unit 2pcs
-	Replaced 4P4MUBS
-	DC Fuse 30A RPI Replaced
-	Surge protector PWS installed

BATTERY READINGS

No. of Strings:		Battery Qty:		Rating:		V		Ah	Total Voltage:	V
1.	2.	3.	4.	5.	6.	7.	8.	9.	10.	
11.	12.	13.	14.	15.	16.	17.	18.	19.	20.	
21.	22.	23.	24.	25.	26.	27.	28.	29.	30.	
31.	32.	33.	34.	35.	36.	37.	38.	39.	40.	

RECOMMENDATIONS/ CONCLUSIONS

UPS been returned to site and Standby
removed and taken back to Symphony

SITE & CUSTOMER APPROVAL

Site Contact Person:	Devin	Signature:	Devin	Date:	12/4/2023
Client Contact Person:	Richard Munira	Signature:	Richard	Date & Stamp:	12/4/2023

For: KCB BANK KENYA LTD.
GIGIRI DRS, FACILITIES DEPARTMENT