









Head Office:

06 Trench Road, Hydepark Industrial Estate T +44 (0)28 9034 2655 Newtownabbey, Belfast, BT36 4TY

F +44 (0)28 9034 2651

sales@fortress-sefa.com www.fortress-sefa.com

**NBS L20/610 ROLLER SHUTTERS** 

Version 06/Jan 2016/Page 1 of 2

**APPENDIX 13** FORTRESS DBS501 FABRIC SMOKE CURTAIN

Fortress DBS501 Fabric Smoke Curtain. **Product Reference** 

Description Fabric fire barrier designed to protect escape routes from the effects of fire,

thus enabling building occupants to reach fire exits.

Fortress DBS501 is ideally suited to larger office, commercial and retail **Application** 

premises. Typical applications include exhibition halls, shopping centres,

department stores, schools, hotels and community buildings.

Size Tailored specification to requirement.

Last revision August 2008. Larger sizes by specification.

Please consult Fortress SEFA for advice.

Performance CE-marked: Product Standard BS EN 13241-1 2003 + A1:2011.

BS EN 12604 Industrial, commercial and garage doors and gates. Mechanical

aspects - Requirements.

Fire performance: 2 hours fire resistance BS476: Parts 20 & 22 (1987) and

parts 6 & 7 class 'O'.

BS EN 12453 Industrial, commercial and garage doors and gates.

Safety in use of power operated doors - Requirements.

BS EN 12424 Industrial, commercial and garage doors and gates. Resistance to wind load: BSEN 12424:2000, Classification 5.

Manufacturer's Declaration of Conformity in accordance with the Construction

Products Directive 2013.

Manufacturer's Declaration of Incorporation in accordance with the Machinery

Directive 98/37/EC.

Arrangement Vertical roller shutter for face fixing.

Barrel Mild steel tube finished with one coat rust inhibitive primer.

**End Plates** 2mm-3mm (depending on curtain size/weight) mild steel plates finished with

one coat rust inhibitive primer.

BS 476 Fortress 240+ Fire Shield Fabric™ specially designed reinforced woven Curtain

glass-fibre material coated on both sides with a reflective micronized aluminium polymer with an integrity rating of 120 minutes. Galvanised steel bottom rail

fabricated from 1.2mm galvanised steel.

Guides N/A

Head Box 1.2mm galvanised steel 175mm x 175mm box assembly houses the curtain

operator, barrel and curtain assembly

BS EN 12453 Galvanised steel roll-formed base bar with Fortress Anti-Catch

System  $^{\text{TM}}$  designed to avoid any lifting hazard.

Finish Standard finish is galvanised steel guides, coil casing and bottom rail, with non-

galvanised components finished with one coat rust inhibitive primer.

BS EN 12453 Fortress FC IBM™ single-phase operator with normal day to day Operation

operation by low voltage key switch (24 Volt) linked to the building fire alarm

system.

On receiving a signal from the fire alarm, the control panel will either close the curtain under power close or controlled decent gravity drop. Control panel must be connected to a 13amp/non switched fused spur located within 1 m of the

motor position.

We reserve the right to alter specifications without prior notice. Copyright © 2016 Fortress SEFA LLP.

**Belfast** Dublin Dundee Glasgow Manchester London Uppsala Stockholm Göteborg Malmö Gdańsk Warsaw











Head Office:

06 Trench Road, Hydepark Industrial Estate T +44 (0)28 9034 2655 Newtownabbey, Belfast, BT36 4TY

F +44 (0)28 9034 2651

sales@fortress-sefa.com www.fortress-sefa.com

**NBS L20/610 ROLLER SHUTTERS** 

Version 06/Jan 2016/Page 2 of 2

**APPENDIX 13** 

FORTRESS DBS501 FABRIC FIRE CURTAIN

**OPTIONAL EXTRAS** 

**Operating Controls** BS EN 12453 Hold-to-run and dead-man close automation for applications

Where there are untrained door users. Drive unit incorporates a manual crank

release for emergency use.

DBF1: Volt free electrical signal will trigger the door to drive closed under **Accessories** 

DBF2: Volt free electrical signal will trigger the door to: close under power control/ part close/ close under smoke detection signal/ close when signalled by fire alarm/ close on timer/ show a visual display 'Shutter Closing'/ sound an audio warning/ trigger a controlled descent unit activated by a battery backup

power system.

DBF3: Thermal fusible link.

Galvanised sheet steel coil casing or fascia hood.

Motor hood (BS EN 13241-1: all moving parts to be covered by casing on all

Shutters less than 2500mm high).

Brush seal to head.

Battery backup - 240 Volt single-phase operation

Electrical Photocell (light beam sensor will detect the presence of a person or object that

interrupts the light beam providing a non-contact safety system).

Audio Visual Fire Alarm Interface Panel

Curtain N/A

**Finishes** Door curtain and guides can be supplied BS EN 12206-1 DuPont® polyester

powder coated (PPC) to the Fortress Pro-Tec range of 29 BS and RAL colours. Matt PPC finishes only. All finishes are applied in-house using an electrostatic process. Under normal circumstances average film thickness of 60-80µm (microns) is applied. Non-standard colours are available on request - this may

increase lead times. Please consult Fortress SEFA for advice.

Standard DuPont® **Colour Range** 

BS 00A05; BS 08B29; BS 04E53; BS 12B27; BS 18B25; BS 18E53; RAL 1015; RAL 1021; RAL 3005; RAL 3020; RAL 5003; RAL 5005; RAL 5010; RAL 5013; RAL 5015; RAL 6005; RAL 6029; RAL 7016; RAL 7021; RAL 7031; RAL 7035; RAL 7037; RAL 8016; RAL 9001; RAL 9005 (BLACK); RAL 9006 (SILVER);

RAL 9007; RAL 9010 (WHITE); RAL 9910.

Services Fortress SEFA provides a full technical advice service.

NBS Specifications.

RIBA CPD.

Manufacturer Fortress Pro-Tec Ltd. 120 Old Coach Road, Templepatrick, Ballyclare, County

Antrim, BT39 0HA.

Tel: +44 (0)28 9443 3693. Fax: +44 (0)28 9034 2651. Email: info@fortress-sefa.com Web: www.fortress-sefa.com