ELECTRICAL INSTALLATION CONDITION REPORT

Installation: Flat 2A, 22 Canal Street, London E2 8QR
Client: Harbourline Property Fund I LP
Inspector: Brightspark Electrical

Date of inspection: 5 June 2021
Next inspection recommended by: 5 June 2026

Overall assessment of the installation: Satisfactory

Observations and classification
None recorded.

Code C1: danger present. Code C2: potentially dangerous.
Remedial work for C1 or C2 must be done within 28 days of the inspection.