ELECTRICAL INSTALLATION CONDITION REPORT

Installation: Flat 5C, 22 Canal Street, London E2 8QR

Client: Harbourline Property Fund I LP

Inspector: Brightspark Electrical

Date of inspection: 20 August 2024

Next inspection recommended by: 20 August 2029

Overall assessment of the installation: Unsatisfactory

Observations and classification

1. Socket circuits in the kitchen have no RCD protection. Code C2.

2. Consumer unit label missing. Code C3.

Code C1: danger present. Code C2: potentially dangerous.

Remedial work for C1 or C2 must be done within 28 days of the inspection.