

CUNY MSDS Capstone Project

COMMERCIAL BUILDING ENERGY CONSUMPTION

ANALYSIS AND PREDICTION

March 25, 2019

John Grando
john.grando@spsmail.cuny.edu

Contents

Abstract	1
Introduction	1
Research	2
Related Work	2
Literature Review	2
Theory and Hypothesis	2
Data and Methods	3
General Process	3
Data Pre-Processing	4
Electricity	4
General	4
Response Analysis	5
Variable Selection - PCA	5
Variable Selection - PLS	5
Variable Selection - Random Forest	5
Variable Selection - Lasso	6
Variable Selection - Forward Selection	6
Variable Selection - Recursive Feature Elimination	6
Variable Selection - Simple Neural Network	6
Variable Selection - Selected Variable Analysis	7
Natural Gas	8
General	8
Response Analysis	8
Variable Selection - PCA	8
Variable Selection - PLS	8
District Heat	9
General	9
Fuel Oil	10
General	10
Neural Network Models	11
General	11
Hyperparameter Training	11
Electricity	12
Summary	12
Variable Selection Summary	13

Future Work	13
Natural Gas	14
District Heat	15
Fuel Oil	16
Appendix - Electricity	17
Response	17
PCA	17
PLS	18
Random Forest	20
Forward Selection	22
Recursive Feature Extraction	24
Simple Neural Network	26
Select Variable Analysis	28
Appendix - Neural Networks	36
Electricity	36
Selected Variables	38

Abstract

Commercial Building Energy Consumption accounts for approximately 25%¹ of the United States energy production profile. Many economical and sociological factors are pushing owners of these buildings to reduce energy consumption and optimize performance. However, it is difficult to say whether a building is operating efficiently or not. Using publicly available data, models can be constructed to predict major fuel consumption. Keywords: building energy consumption, predicted energy consumption, baseline energy model.

Introduction

Building owners, local governments, and utility providers are all looking for ways to reduce energy consumption. Reasons for doing so can vary all the way from social responsibility to economic gain. Some people want to show off an efficient building, others want to identify properties that are in need of improvement. However, this concept of evaluating building performance typically requires two things; measuring the property in question's consumption, and comparing it to a standard practice equivalent. Additionally, in order for the final product to be useful, it is important that the final set of predictors be parsimonious and be realistically available to users.

Comparing summary statistics between buildings, such as energy use per square foot, is not as simple as it seems because there are a multitude of factors that affect a building's energy consumption profile. The building use type can cause energy use to vary by a large amount; such as office buildings and refrigerated warehouses. Also, some factors may have critical importance for some buildings and not others, which can lead to significant differences in consumption. This complexity of making similar comparisons creates a situation where it is difficult to determine whether a building is performing consistent with, or better than, other standard practice buildings.

Commercially, using the most popular example, ENERGY STAR² has implemented a benchmarking algorithm that scores buildings on a scale from 1 – 100 using market-available data. The output of this benchmarking algorithm is a unit-less score, as well as a reference 'baseline' building. However, the methodology is not released and it is unclear what factors are important to influence the energy consumption of the building. These barriers make it difficult to provide custom comparisons and nearly impossible to make batch predictions from a set of buildings, or variations of buildings.

Every few years, the U.S. Energy Information Administration (EIA) conducts a survey attempting to record pertinent features of these buildings, known officially as the Commercial Buildings Energy Consumption Survey (CBECS)³. While the survey is expansive (i.e. more than 600 tracked features), it is essential to create a model that is usable and only requires predictors that can easily be attained by building operators. Therefore, in this study a series of models will be evaluated in order to determine the most important predictors which will then be used to train a final, more complex, model. After completion of the model, the predictors will be evaluated on how easy they are to attain, and will possibly be exchanged with simpler variables that are highly correlated.

¹EIA - https://www.eia.gov/energyexplained/index.php?page=us_energy_commercial

²ENERGY STAR - <https://www.energystar.gov/>

³EIA Microdata

Research

Related Work

The idea of determining building energy efficiency is not a novel concept in itself. As previously mentioned, ENERGY STAR has a building benchmarking tool⁴. Additionally, the United States Green Building Council has created the Arc Platform⁵ which provides benchmarking and active monitoring features. While these platforms provide building comparisons in the form of an overall score, it is difficult to explore the space around the building attribute inputs themselves as well as compare consumption of a specific building to its equivalent standard practice building. With this functionality, a more direct comparison can be made and relative environmental impact can be measured.

Literature Review

There are a variety of texts that are dedicated to the analysis of building energy consumption, and determining operating efficiency. For example, ASHRAE Guideline 14/ASHRAE Guideline 14⁶ provides a standardized set of energy, demand, and water savings calculation procedures. Also, there are guidelines that must be followed for buildings undergoing new construction or major renovation, which have energy compliance sections (ASHRAE Guideline 90.1, 189.1, and International Energy Conservation Code)⁷. Particularly, there is a well thought out process for auditing commercial buildings, known as ASHRAE Audits, which start at the lowest level (I) and progress to the highest level (III) as the opportunity for energy and cost savings becomes more apparent⁸.

Theory and Hypothesis

Commercial buildings are complex and encompass a wide variety of purposes. In order to be functional, they all must be powered, and require a considerable amount of energy to operate properly, which can be costly. In fact, there is a whole industry dedicated to ensuring the proper operation of a structure. The most direct example is the ASHRAE energy audit process. As part of the initial audit process, an assessment of the building's overall operational efficiency is gauged. Typically, an auditor will walk through the building, analyze utility bills, and make the closest energy consumption comparisons they can. This takes years of experience and sometimes requires highly tuned spreadsheets that have been developed over a long period of time. It can take a surprising amount of effort just to determine if a building is operating efficiently or not, which demonstrates how useful it could be to have a model at hand which predicts building consumption based on easily attainable features.

⁴<https://www.energystar.gov/buildings/about-us/how-can-we-help-you/benchmark-energy-use/benchmarking>

⁵<https://arcskoru.com/>

⁶https://www.techstreet.com/standards/guideline-14-2014-measurement-of-energy-demand-and-water-savings?product_id=1888937

⁷<https://www.energycodes.gov/status-state-energy-code-adoption>

⁸<http://aea.us.org/3143-2.html>

The CBECS data set provide some insight as to what building attributes most greatly affect building energy consumption. Over 400 survey questions are recorded and coupled with major fuel consumption. These fuel sources are Electricity, Natural Gas, District Heat, and Fuel Oil. However, it would not be useful to construct a model with a large number of predictors, as it would require a large amount of time and effort to compile the necessary information in order to provide a prediction. Therefore, one of the main focuses for this study will be to extract the fewest amount of predictors necessary in order to make accurate predictions.

Given the complex nature, it is unlikely a linear regression will provide the best prediction accuracy. This point is especially highlighted by the fact the the goal of this study is produce a parsimonious set of predictors, which means a small subset must be selected. Therefore, an investigation into more complex, nonlinear, algoriithms will be performed in order to keep the number of necessary predictors as low as possible while still capturing complex interactions.

Data and Methods

General Process

Due to the large number of features in the survey responses, it is not possible to analyze each one individually. Therefore, the first steps in the process will be centered around selecting a smaller subset. First, a principle component analysis will be performed. Second, a partial least squares model will be fit to the response. Third, a random forest regression will be used in order to try and extract any nonlinear relationships. Fourth, an attempt to construct a lasso regression model will be made. Fifth, a forward selection linear model will also be fit in order to see if an automated approach can be taken. Finally, a simple neural network model will be trained to gauge the possible effectiveness of using this model type. The magnitude and contribution percentage of each variable will be considered in selecting features from this model. Also, the various error rates from each preliminary model will be used as a benchmark for the final model performance.

After the preliminary set of models have been run and summarized, the extracted variables will be analyzed in order to verify their importance, gauge their potential predictive power, and to check whether they are easily attainable for a building operator/owner. This step is very important because it is essential worthwhile variables are used to predict the outcome. Selecting a variable that, for one reason or another, is erroneous may lead to reduced predictive power in the final model. If a variable did pass our initial analysis but doesn't actually have much predictive power (i.e. it only changes values by a slight amount) then it may not be worthwhile to select it at all. All selected variables increase the complexity of the model; therefore, we wish to only select those that will matter. Finally, the predictor must be usable, and 'knowable'. These three concepts will be used in the analyzation of the candidate variables from the the preliminary analysis.

Finally, a neural network model will be built to take the verified subset of features and make predictions for the selected major fuel use. A variety of hyperparameters will be tested, using cross-validation, and compared on a common error metric. This step will reveal the optimal hyperparameter combination to use for the model. The prospective model will then be retrained on the entired entire training and validation data. This model's selected error metrics will then be compared to the preliminary models, which should be considered a floor for performance. Once this is done, the model can then be re-assessed for feature selection as well as analyzed for the

value/tradeoff of adding/removing certain features.

For each fuel end-use, two parallel final models will be considered; one model will use a total consumption response variable in units of mmBTU, and another model that will be considered will have the response variable normalized based on gross floor area in units of BTU per square foot. The final decision on which model will be chosen will come after the neural network models have been fully trained.

Data Pre-Processing

The raw data set consists of 6,720 samples and 1,119 features. However, multiple steps of pre-processing were required in order to prepare the data. Note, there are many columns which are being used as imputation flags and statistical weights (for aggregation) which, when removed, reduced the number of features down to approximately 400. While these columns are useful to indicate where values have been imputed into the dataset by the source's own methodologies, rather than try to change back the data to the original records it has been determined that the imputed values were sufficiently applied and the dataset will not be imputed any further.

After evaluating the reduced data set, some feature engineering efforts were taken. First, very specific cases which resulted in many null responses to follow-up survey questions (e.g. buildings less than 1,000 gross square feet), buildings open for less than a year, and features with a large amount of nulls were removed. Second, some null entries were converted to zero when logically appropriate. For example, if a building was indicated to not be cooled, then a follow up question asking what percentage of the building is cooled was not asked, resulting in an null. In this instance, the null value was replaced with a zero. Third, some values were removed as they simply did not apply to the study (e.g. expenditure for energy sources in USD). Fourth, nominal categorical values that had null responses were encoded to a special value. The thinking for this approach is that if, in fact, a null value for a feature ends up being a significant predictor, then it can be analyzed what factors make this situation occur. Fifth, the categorical features were then one-hot encoded to separate columns. The preprocessed data set was transformed to 6661 rows and 456 features (before one-hot encoding).

Electricity

General

The preprocessed data was passed to the aforementioned set of algorithms in order to determine the best possible set of candidate predictors with some additional adjustments. Only buildings that indicated electricity being used ELUSED were included in the samples for this major fuel use. Then, one of each pair of predictors with correlations above 0.75 were removed, to avoid model selection issues. Additionally, the other major fuel consumption values were removed from the set of possible predictors. Also, the numeric predictors were transformed via BoxCox methodology as well as centered and scaled due to the varying scales and skewness.

Two potential outlier was found in the analysis. A public assembly space reported an energy consumption of 1E09 BTUs whereas the next highest consumption for this building type, with similar area was 3E08 BTU (less than one third of the value), and the 3rd quartile value of this

subset is 5.5E06. While it is noted that there were significantly higher indications of refrigeration use than other comparables, the inclusion of this data point still vastly skews most models due to its high leverage. Similarly, an 'Other' space type has a reported energy consumption of 7E08 BTU whereas the next highest value is 2E08 BTU and the third quartile value is 2E06. While this building is large (1.4 mmSF), and has a lot of server equipment (>500), it is still greatly beyond the next closest category and seems to be causing instability in the models due to lack of similar data points. Therefore, these points have been removed and the caveat of instability past a maximum limit will be instituted (<5E08 BTU), due to lack of additional information.

Response Analysis

The response data appear to be unimodal and have a heavy right skew. After filtering for this model's end-use, there are 6499 samples in the data set. The energy use was converted to units mmBTU (1e6 BTU) and the log was taken in an attempt to maintain homoscedacity as the variance of the energy used also scales with the magnitude. *Appendix*

Variable Selection - PCA

RMSE: NA, Rsquared: NA

Top 5: LAUNDR [NA], NWKER, COOK [NO], PRNTRN, EDSEAT

The principle component analysis indicates that only About 5.0% of the variance in the data can be explained in the first principle component, which then drops to about 2% for the second principle component. These results reveal that there does not appear to be a clear set of axes that can explain the variance of the data very well, which indicates there may be some very complex interactions taking place in the predictors. *Appendix*

Variable Selection - PLS

RMSE: 12109, Rsquared: 0.763

Top 5: NWKER, PRNTRN, RFGVNN, NELVTR, COPIERN

This model returned a promising result; however, it must be noted that all predictors were used in this process. Looking at the output thus far, it appears that the number of workers, receptical equipment, and refrigeration equipment, influence electrical consumption. *Appendix*

Variable Selection - Random Forest

RMSE: 17284, Rsquared: 0.809

Top 5: PUBCLIM.7 [WITHELD], SQFTC.8 [200K SF - 500K SF], NELVTR, NWKER, SQFTC.9 [500K SF - 1mm SF]

As with the PLS, model, the resulting error metrics were promising, with slightly better RMSE and Rsquared values. The selected variables are ver similar except the square foot categories are coming into play. Also note that the presence of publicly withheld data, for security reasons, was a selected feature, possibly due to the nature of high security government buildings. *Appendix*

Variable Selection - Lasso

RMSE: NA, Rsquared: NA

Top 5: NA

This resulted in a very poor fit, which is not unexpected. Lasso models typically work when a few variables can be used to predict the response, which does not appear to be the case in this instance. Due to the lack of fit, this model will not be used in the variable selection process. Additionally, the actual model was poor enough that predictions could not be made on the data, which is the reason for the lack of reported metrics.

Variable Selection - Forward Selection

RMSE: 18490, Rsquared: 0.453

Top 5: NWKER, PRNTRN, RFGVNN, NELVTR, COPIERN

This model was building using the leaps package which iteratively selected the best predictor variable up to a limit of 100. Unsurprisingly, the best model turned out to be the maximum setting; however, encouraging model metrics were still not returned. *Appendix*

Variable Selection - Recursive Feature Elimination

RMSE: 10462, Rsquared: 0.831

Top 5: NWKER, RFGICN, NELVTR, HCBED_bin.2[>250], PUBLICM.7[WITHHELD]

A more direct approach was taken with this model, which is specifically used to extract useful features from data sets. As can be seen, there are many of the same predictors chosen in this model as in previous models. *Appendix*

Variable Selection - Simple Neural Network


RMSE: 12337, Rsquared: 0.768

Top 5: PUBCLIM.7[WITHHELD], HCBED_bin.2[>250], TVVIDEON_bin.2[>200], MRI[YES], NWKER

Given that the final model will be a neural network, it made sense to try a simple out-of-the-box training model to see if any particular features worked better with this specific process, which provided encouraging results. *Appendix*

Variable Selection - Selected Variable Analysis

Model	RMSE	R2	MAE
partialLeastSquares	1.169408e+04	0.7780371	3.237700e+03
leaps	2.327804e+04	0.3559985	5.652596e+03
randomForest	1.182305e+06	0.2788200	8.100512e+05
recursiveFeatureExtraction	2.221181e+07	0.8247289	8.762935e+06
neuralNetwork	4.453689e+07	0.1406134	1.061397e+07
lasso	8.242048e+13	0.0000032	2.936412e+13



In order to rank the most impactful features, the variable importance metrics from the selected models were all set to the same scale then summed up. As a preliminary check, the top 20 predictors are plotted in the appendix and are generally discussed here. It seems the attempts to create stratified random samples, by building type, may have been beneficial in this case since there are some very building type specific end-uses that are highly ranked. It does cause some concern that there are some odd selections, such as the 'withheld' column of the climate encoded variables being selected; however, it seems as though whatever reasoning to classify these types of buildings this way is a direct indicator of electrical consumption. When evaluating multiple selected atypical variables (e.g. LAUNDR_3[laundry provided by offsite services]) it seems that just the applicability of the question influences the consumption (building types - lodgining, healthcare, nursing). In an attempt to truly follow the important predictors, no variables have been removed from this set and the order of importance remains unchanged. *Appendix*

Natural Gas

General

As previously noted, only buildings that indicated natural gas being used NGUSED were included in the samples for this major fuel use. Then, one of each pair of predictors with correlations above 0.75 were removed, to avoid model selection issues. Numeric predictors were transformed via BoxCox methodology as well as centered and scaled due to the varying scales and skewness. Note, no further commentary will be made in the following sections unless it differs from previous sections.

Response Analysis

After filtering for this model's end-use, there are 4355 samples in the data set. The same transformations were applied to this response variable as electricity. *Appendix*

Variable Selection - PCA

RMSE: 0.0, Rsquared: NA

Top 5: NWKER, EDSEAT, PBA.14 [EDUCATION], STRLZR..1 [NA], PRINTRN

No further commentary. *Appendix*

Variable Selection - PLS

RMSE: 11784, Rsquared: 0.776

Top 5: NWKER, PRINTRN, NELVTR, RFGVNN, RFGWIN

No further commentary. *Appendix*

District Heat

General

Test

Fuel Oil

General

Test

Neural Network Models

General

The choice to use neural networks for the final model was multi-faceted. First, these types of models are very good at capturing complex non-linear interactions. This appears to be the case with the data set given the failure of lasso models as well as the low percentage of variance capture for the first few dimensions of the principal component and partial least squares analyses. Secondly, neural networks have the ability to select different loss functions. This is beneficial because it is important to highlight practicality of the results returned. As the estimated energy consumption grows, it is somewhat acceptable for the error rate to grow proportionally if it results in better fits for the low estimates. As an example, a large datacenter may use a lot of energy so a slightly higher relative error rate may not be a big issue since it could be a small portion of the overall consumption; however, if a non-heated warehouse with a moderate error rate, comparative to the rest of the data set, would be wildly inaccurate. Therefore, the loss function for this set of models was chosen to be the mean squared logarithmic error in an effort to reflect the reasoning noted above.


Hyperparameter Training

In order to select the most optimized set of parameters, some hyperparameter training was performed. Some standard searches were made, such as varying the dropout rate, regularization, learning rate, and batch size; however, one additional training set was incorporated to highlight the goals of this study. A series of models were tested which had an incrementally decreasing number of variables, by least importance, in order to test the loss of accuracy.

Electricity

Summary

The final selected model consisted of a 3 hidden layers, 200 hidden layer nodes, a dropout rate of 0.6, no regularization, batch sizes of 150, using the rmsprop() algorithm with a learning rate of 0.01, and 100 predictors. As can be seen in the graph below, the number of variables needed to obtain near-peak performance, is much less than the full set.



The final selected model, after re-training, has a MSLE of 0.875 and RMSE of 15357. Comparing this model ('Full Neural Network') to the previous feature extraction models, which used many more variables, the performance is competitive. Note, in an effort to provide a sufficient number of data points for such a large model, 50% of the training data had noise added to the numeric columns and appended to the existing set.

Feature Extraction Model Results

Model	RMSE	R2	MAE
recursiveFeatureExtraction	10462.67	0.8305013	4168.206
partialLeastSquares	12109.87	0.7636348	3292.720
neuralNetwork	12337.32	0.7681178	3617.357
Full Neural Network	15357.48	0.7082770	3950.527
randomForest	17284.70	0.8087479	5495.435
leaps	18490.39	0.4527306	4865.344

The residuals indicate that the variance scales with the response variable; however, since neural network models do not operate on a principle of homoscedacity, only underlying patterns are of concern. Additionally, the noted error pattern is by design so that higher error in higher consumption projects are acceptable. *Appendix*

Variable Selection Summary

The final model chosen uses 100 variables. Many of the features within the set have to do with the amount of receptacle equipment within the building as well as major electrical appliances (e.g. elevators) and essential equipment (e.g. data center servers, refrigeration). In fact, there are only a few cryptic selected variable (e.g. existence of employee breakroom) that may be more related to the building type rather than the actual question being asked. *Appendix*

Future Work

While it was determined that some heteroscedacity would be acceptable, there does appear to be area for improvement. Additionally, as mentioned at the beginning of this report, the sampling of this data set was stratified to reflect the building population. However, it is noted that there are some building classes that have greater variance than others. Therefore, it may be useful to use this stratification as a weighted method, based on PBAPLUS, in order to try and emphasize accuracy on the most prevalent building types. Also, there was not a lot of attention paid to the actual transformations of the predictors given the large quantity of them. It is possible a better fit can be obtained with more intelligent transformations applied to the features after further analysis.

The automated selection process does seem to have included some highly correlated pairs, such as requesting the numeric amount of workers as well as the binned category of this value. This does reduce the number of necessary questions, but it is unclear if both are necessary and/or if they are possibly detrimental. Also, there are a number of questions that may be automatically known just based on the usage type as some questions do not apply to all buildings. It is possible take the steps used in asking questions in the survey in order to build a live form that can automatically parse out the meaningful questions based on building type, which could reduce the need to enter a value for all the selected variables.


Natural Gas

District Heat


Fuel Oil

Appendix - Electricity



Response





PCA






PLS








Random Forest









Forward Selection









Recursive Feature Extraction






Simple Neural Network








Select Variable Analysis


Model	RMSE	R2	MAE
partialLeastSquares	1.169408e+04	0.7780371	3.237700e+03
leaps	2.327804e+04	0.3559985	5.652596e+03
randomForest	1.182305e+06	0.2788200	8.100512e+05
recursiveFeatureExtraction	2.221181e+07	0.8247289	8.762935e+06
neuralNetwork	4.453689e+07	0.1406134	1.061397e+07
lasso	8.242048e+13	0.0000032	2.936412e+13






















Appendix - Neural Networks

Electricity





Selected Variables

NWKER	Number of employees	RFGICE	Commercial ice makers	RFGLCN	Number of closed case refrigeration units	CHLDUCT	Chiller system: Duct reheat
PRNTRN	Number of printers	NWKERC	Number of employees category	BLRDUCT	Boiler system: Duct reheat	CHLPKG	Chiller system: Packaged unit
PUBCLIM	Building America climate region	FKHT2	Fuel oil used for secondary heating	PCTRMC	Number of computers category	RGSTR	Cash registers
HCBED	Licensed bed capacity	RFGOPN	Number of open case refrigeration units	HTVVAV	Heating ventilation: Central air handling with VAV	COPIER	Photocopiers
TVVIDEO	Number of TV or video displays	NWKERC	Number of employees category	CHLPKG	Chiller system: Packaged unit	HIDP	Percent lit by HID
MRI	MRI machines	CHLAIRCL	Chiller type: Air-cooled	ECNTYPE	Type of economizer	NWKERC	Number of employees category
NELVTR	Number of elevators	BREAKRM	Employee lounge, breakroom, or pantry	OCSN	Occupancy sensors	RFTILT	Roof tilt
COPIERN	Number of photocopiers	CHLFNCL	Chiller system: Fan coil units in rooms	SERVERC	Number of servers category	XRAYN	Number of X-ray machines
RGVN	Number of refrigerated vending machines	RGSTRN	Number of cash registers	FACDST	Plant produces district steam	BLDPLT	Central plant in building
RFGIN	Number of ice makers	RFGOP	Open case refrigeration units	RFGL	Closed case refrigeration units	LAPTPC	Number of laptops category
ELEVTR	Elevators	EMCS	Building automation system	SQFTC	Square footage category	ENGINE	Reciprocating engines
LAUNDR	Laundry onsite	XRAYN	Number of X-ray machines	EMCSLT	BAS controls lighting	BLRFNCL	Boiler system: Fan coil units in rooms
CAF	Cafeteria or large restaurant	RFGRSN	Number of residential refrigerators	FACDCW	Plant produces district chilled water	DCNTRSFC	Data center or server farm sqft category
DCNTRSFC	Data center or server farm sqft category	SNACK	Snack bar or concession stand	KITCHN	Small kitchen area	LNHRPC	Lit off hours category
FACACT	Type of complex	LTNR24	Lights off during 24 hours	NESLTR	Number of escalators	DHDUCT	District heat system: Duct reheat
SERVERN	Number of servers	LED	Light-emitting diode (LED) bulbs	NGCOOK	Natural gas used for cooking	RENSAF	Fire, safety, or security upgrade
LINACC	Linear accelerators	SQFTC	Square footage category	NELVTR	Number of elevators	SERVERC	Number of servers category
RGFWIN	Number of walk-in units	TRNGRM	Computer-based training room	BASEMNT_HAS	NA	LAPTPC	Number of laptops category
GENUSE	Use of generated electricity	FKTYPE	Specify fuel oil, diesel, or kerosene	CHLINDC	Chiller system: Induction units	PCTRMC	Number of computers category
PCTRMC	Number of computers category	FDPREP	Commercial or large kitchen	HWRDCL	How reduce cooling	RGVEN	Refrigerated vending machines
STRLZR	Sterilizers or autoclaves	NFLOOR	Number of floors	BLRAIR	Boiler system: Central air handler	HID	High intensity discharge (HID) bulbs
LAUNDR	Laundry onsite	LABEQP	Laboratory equipment	FASTFD	Fast food or small restaurant	TVVIDEO	TV or video displays
RGVEN	Refrigerated vending machines	ENGINE	Reciprocating engines	COOK	Energy used for cooking	STCOOK	District steam used for cooking
LEDP	Percent lit by LED	ESCLTR	Escalators	CHILLR	Central chillers inside the building	BLRINDC	Boiler system: Induction units
RGWI	Walk-in refrigeration units	RFGCOMP	Number of compact refrigerators	NWKERC	Number of employees category	FACELC	Plant produces electricity