

iPad

11:18 AM

Emissions Monitoring Tool

☰

VN-14550

Emission of acid from valve packing. Currently below threshold for operational shutdown.

Next Check Due: 20/11/23

Current Check Due: 01/11/23

Status: Checks Completed

PI-1314

Emission of nitrogen from pressure gauge threaded connection. Currently below threshold for operational shutdown.

Next Check Due: 01/12/23

Current Check Due: 01/11/23

Status: Checks Completed

>

09:52 AM

Emissions Monitoring Tool

☰

VN-14550

Emission of acid from valve packing. Currently below threshold for operational shutdown.

Next Check Due: 20/11/23

Current Check Due: 01/11/23

Status: Checks Completed

>