mod_clock_ena_gen.v

AUTHORS

JAY CONVERTINO

DATES

2025/01/27

INFORMATION

Brief

Generate a enable signal at some rate that divides the clock. This can be any rate. This enable will not be a 50% clock cycle or as stable as a pll. This uses the mod algorithm. Essentially it adds the number of ticks till it reaches the clock rate and then saves the remainder and generates a 1 cycle high pulse.

License MIT

Copyright 2025 Jay Convertino

Permission is hereby granted, free of charge, to any person obtaining a copy of this software and associated documentation files (the "Software"), to deal in the Software without restriction, including without limitation the rights to use, copy, modify, merge, publish, distribute, sublicense, and/or sell copies of the Software, and to permit persons to whom the Software is furnished to do so, subject to the following conditions:

The above copyright notice and this permission notice shall be included in all copies or substantial portions of the Software.

THE SOFTWARE IS PROVIDED "AS IS", WITHOUT WARRANTY OF ANY KIND, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO THE WARRANTIES OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE AND NONINFRINGEMENT. IN NO EVENT SHALL THE AUTHORS OR COPYRIGHT HOLDERS BE LIABLE FOR ANY CLAIM, DAMAGES OR OTHER LIABILITY, WHETHER IN AN ACTION OF CONTRACT, TORT OR OTHERWISE, ARISING FROM, OUT OF OR IN CONNECTION WITH THE SOFTWARE OR THE USE OR OTHER DEALINGS IN THE SOFTWARE.

mod_clock_ena_gen

```
module mod_clock_ena_gen #(
parameter
CLOCK_SPEED
=
2000000,
parameter
START_AT_ZERO
=
0,
parameter
DELAY
=
```

```
) ( input clk, input rstn, input hold, input [31:0] rate, output ena )
```

Mod rate enable generator

Parameters

CLOCK_SPEED This is the aclk frequency in Hz

parameter

START_AT_ZERO Start counter at 0 if set. Otherwise start at CLOCK_SPEED/2.

parameter

DELAY Delay the enable by a number of clock ticks

parameter

Ports

clk Clock used for enable generation

rstn Negative reset for anything clocked on clk

hold hold enable low and pause + reset count till hold removed (low).

rate rate that enable pulse will be generated, must be less then the clock rate.

ena positive enable that is pulsed high at enable rate.