

# Electrical: Harness/Cables/Sockets & Distribution Boards

## Perform Maintenance Check

Frequency

Weekly

Models

Harness/Cables/Sockets & Distribution Boards

Estimated Time to Complete

20 Minutes

### Health & Safety Hazards



Electricity

### Food Safety



Wash and dry hands **after** performing this task



Ensure nuts, bolts & screws are tight



Inspect equipment. Do not use if damaged

#### Check for the following

##### Overhead Cable

- 1 Electrical plug for loose screws and loose or loose/damaged wires
- 2 Power cable for kinks/nicks/splits or other damage
- 3 Socket and plug fit securely into position
- 4 Clip fitting is present and socket cover clips into position

##### Distribution Board

- 5 Distribution board covers present and lock into position Kitchen area distribution boards Grill/Fryer stations and harnesses


##### Harness

- 6 All screws are present and tightened (check behind the socket cover)
- 7 Socket covers are all present, in good condition
- 8 Power cable for kinks/nicks/splits or other damage


##### Power board

- 9 Sockets, all screws are present and tightened
- 10 Socket covers are all present, in good condition


Overhead Cable



Power Board



Harness



Distribution Board

