



REPUBLIC OF THE PHILIPPINES
DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
ENVIRONMENTAL MANAGEMENT BUREAU

Regional Office No. 1
DENR Bldg., Government Center, Sevilla, City of San Fernando,
La Union

18 NOV 2019

HON. EDISON U. CHUA

Managing Head
UKL EVER RESORT
Airport Road, Brgy. 46, Nalbo, Laoag City,
Ilocos Norte

Dear **Hon. Chua**:

We are pleased to inform you the approval of "Temporary Permit to Operate" Air Pollution Installation of your firm. You are hereby advised, however, that said permit shall be released only to you or to your authorized representative upon presentation of your authorization to claim the same and payment of **Five Hundred Pesos (P 500.00)** as permit fee.

In this regard, your regular permit will be issued to you upon compliance with the provisions of EMB Memorandum Circular No. 2007-003 which requires your **425 HP CUMMINS NTA855-G1 Diesel engine** to have a source Emission Test once every two (2) years. Source Emission Test must be conducted by DENR Accredited Third Party Samplers.

Please take note that "Permit Conditions" must be strictly observed; otherwise, penalties shall be imposed on violations pursuant to the provisions of Republic Act 8749 otherwise known as The Philippine Clean Air Act of 1999.

You are hereby advised to claim said Permit within **sixty (60) days** from receipt of the Notice otherwise it will be deemed cancelled. Check payments should be payable to **EMB-1 for the account of BUREAU OF TREASURY**.

For your guidance and strict compliance.

Very truly yours,


ENGR. MARIA DORICA NAZ-HIPE, CSE
Regional Director



fmr: RNPascua

Protect the environment... Protect Life...

Tel. Nos. (072)-607-3057 / 700-2448; Fax No. (072)-700-2449; e-mail: embdenr1@yahoo.com

18 NOV 2019

HON. EDISON U. CHUA

Managing Head

UKL EVER RESORT

Airport Road, Brgy. 46, Nalbo, Laoag City,
Ilocos Norte

Dear **Hon. Chua:**

We are pleased to inform you the approval of "Temporary Permit to Operate" Air Pollution Installation of your firm. You are hereby advised, however, that said permit shall be released only to you or to your authorized representative upon presentation of your authorization to claim the same and payment of **Five Hundred Pesos (P 500.00)** as permit fee.

In this regard, your regular permit will be issued to you upon compliance with the provisions of EMB Memorandum Circular No. 2007-003 which requires your **425 HP CUMMINS NTA855-G1 Diesel engine** to have a source Emission Test once every two (2) years. Source Emission Test must be conducted by DENR Accredited Third Party Samplers.

Please take note that "Permit Conditions" must be strictly observed; otherwise, penalties shall be imposed on violations pursuant to the provisions of Republic Act 8749 otherwise known as The Philippine Clean Air Act of 1999.

You are hereby advised to claim said Permit within **sixty (60) days** from receipt of the Notice otherwise it will be deemed cancelled. Check payments should be payable to **EMB-1 for the account of BUREAU OF TREASURY**.

For your guidance and strict compliance.

Very truly yours,

ENGR. MARIA DORICA NAZ-HIPE, CESE

Regional Director



Department of Environment and Natural Resources
ENVIRONMENTAL MANAGEMENT BUREAU R01
Clearance and Permitting Division

TEMPORARY PERMIT TO OPERATE



POA-19J-01IN23-260

08:43:17 AM



REPUBLIC OF THE PHILIPPINES
DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
ENVIRONMENTAL MANAGEMENT BUREAU

Regional Office No. 1
DENR Bldg., Government Center, Sevilla, City of San Fernando,
La Union

Permit Number: POA- 19J-01IN23-260

Date Issued: **18 NOV 2019**

Valid Until: **January 24, 2020**

TEMPORARY PERMIT TO OPERATE
AIR POLLUTION INSTALLATION

Pursuant to Section I, Rule XIX of Department Administrative Order No. 2000-81, Series of 2000, known as the 'Implementing Rules and Regulations of the Philippine Clean Air Act of 1999 (RA 8749)', and Department Administrative Order Number 2004-26, PERMIT IS HEREBY GRANTED TO:

UKL EVER RESORT HOTEL

Brgy. 46, Nalbo, Laoag City
Ilocos Norte

to operate the following:

One (1) unit 425 HP CUMMINS NTA855-G1 Diesel engine as prime mover of Generator set.
xxx

Approved by:

ENGR. MARIA DORICA NAZ-HIPE, CESE
Regional Director

Recommended by:

ENGR. NICANOR C. ESTEBAN
Chief, Clearance and Permitting Division

Permit Conditions

1. The Managing Head or the Pollution Control Officer in-charge of the above facility shall keep record of its operations and shall furnish quarterly Self-Monitoring Report of the same to this Office within the first two weeks after the quarter.
2. This Permit shall be automatically suspended and penalty shall be imposed for non compliance with or violation of any provision of the Act, its Implementing Rules and Regulations, and/or permit conditions; false or inaccurate information in the application for permit that led to the issuance of the permit; false or inaccurate information in the monitoring data or in reports required by the Permit to Operate; refusal to allow lawful inspection conducted by the duly authorized personnel of the Bureau; non-payment of the appropriate fees; or other valid purposes.
3. Application for renewal of this Permit may be filed at least thirty (30) days before expiry date.
4. This Permit must be posted in a conspicuous location near the facility and shall be adequately framed or otherwise protected against damage and submit proof of compliance thirty (30) days from date of issuance.
5. This permit is not transferrable, however, in case of transfer of ownership or control of the establishment and/or facilities, the transferee shall notify the Bureau within fifteen (15) working days of the fact of transfer of ownership or control.
6. Submit to this Office an Emission Test Result of your Generator once every two years in compliance with EMB MC No. 2007-003.

Tax Identification Number 110-521-897-008

ECC-RO1-1305-0087

	Permit Fee	500.00	
2606811	Filing Fee	600.00	10/25/2019
2606811	PD 1856 Fee	10.00	10/25/2019

2606811	D S T	30.00	10/25/2019
---------	-------	-------	------------

Department of Environment and Natural Resources
ENVIRONMENTAL MANAGEMENT BUREAU RO1
Clearance and Permitting Division
TEMPORARY PERMIT TO OPERATE



POA-19J-01IN23-260

08:43:17 AM

Protect the environment... Protect Life...

Tel. Nos. (072)-607-3057 / 700-2448; Fax No. (072)-700-2449; e-mail: embdenr1@yahoo.com

Permit Number: POA- 19J-01IN23-260

Date Issued: 18 NOV 2019

Valid Until: January 24, 2020

TEMPORARY PERMIT TO OPERATE
AIR POLLUTION INSTALLATION

Pursuant to Section I, Rule XIX of Department Administrative Order No. 2000-81, Series of 2000, known as the 'Implementing Rules and Regulations of the Philippine Clean Air Act of 1999 (RA 8749)', and Department Administrative Order Number 2004-26, PERMIT IS HEREBY GRANTED TO:

UKL EVER RESORT HOTEL

Brgy. 46, Nalbo, Laoag City
Ilocos Norte

to operate the following:

One (1) unit 425 HP CUMMINS NTA855-G1 Diesel engine as prime mover of Generator set.
xxx

Approved by:

ENGR. MARIA DORICA NAZ-HIPE, CESE
Regional Director

Recommended by:

ENGR. NICANOR C. ESTEBAN
Chief, Clearance and Permitting Division

Permit Conditions

1. The Managing Head or the Pollution Control Officer in-charge of the above facility shall keep record of its operations and shall furnish quarterly Self-Monitoring Report of the same to this Office within the first two weeks after the quarter.
2. This Permit shall be automatically suspended and penalty shall be imposed for non compliance with or violation of any provision of the Act, its Implementing Rules and Regulations, and/or permit conditions; false or inaccurate information in the application for permit that led to the issuance of the permit; false or inaccurate information in the monitoring data or in reports required by the Permit to Operate; refusal to allow lawful inspection conducted by the duly authorized personnel of the Bureau; non-payment of the appropriate fees; or other valid purposes.
3. Application for renewal of this Permit may be filed at least thirty (30) days before expiry date.
4. This Permit must be posted in a conspicuous location near the facility and shall be adequately framed or otherwise protected against damage and submit proof of compliance thirty (30) days from date of issuance.
5. This permit is not transferrable, however, in case of transfer of ownership or control of the establishment and/or facilities, the transferee shall notify the Bureau within fifteen (15) working days of the fact of transfer of ownership or control.
6. Submit to this Office an Emission Test Result of your Generator once every two years in compliance with EMB MC No. 2007-003.

Tax Identification Number 110-521-897-008

ECC-RO1-1305-0087

	Permit Fee	500.00	
2606811	Filing Fee	600.00	10/25/2019
2606811	PD 1856 Fee	10.00	10/25/2019

2606811 D S T

30.00 10/25/2019

Department of Environment and Natural Resources
ENVIRONMENTAL MANAGEMENT BUREAU RO1
Clearance and Permitting Division
TEMPORARY PERMIT TO OPERATE

POA-19J-01IN23-260
08:43:17 AM