



REPUBLIC OF THE PHILIPPINES
DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
ENVIRONMENTAL MANAGEMENT BUREAU

Regional Office No. 1
DENR Bldg., Government Center, Sevilla, City of San Fernando,
La Union

05 DEC 2019

MR. JHOENSON SY SIY
Proponent
GOLDEN HARVESTA INC.
Portic, Bugallon
2416 Pangasinan

Dear Mr. Siy:

We are pleased to inform you the approval of Temporary Permit to Operate Air Pollution Installation of your firm. You are hereby advised, however, that said permit shall be released only to you or to your authorized representative **upon presentation of your authorization to claim the same, Professional Tax Receipt of the Mechanical Engineer and total payment of One Thousand Pesos (P1,000.00) as permit fee.**

You are also required to comply with Memorandum Circular No. 2007-003 which require generator sets to undergo emission test and to submit the Emission Test Result for the issuance of a regular Permit to Operate.

Memorandum Circular No. 2007-003 (Compliance Testing Requirements) states that: *"A small source is defined as diesel generator rated at 599 KW or less (regardless of its frequency of operation) should be tested by the permittee/facility operator once during the first year of its operation to verify its compliance. Thereafter, it should be tested once every second year"*.

Please take note that **"Permit Conditions"** must be strictly observed; otherwise, penalties shall be imposed on violations pursuant to the provisions of Republic Act 8749 otherwise known as The Philippine Clean Air Act of 1999. Be reminded that said permit shall be filed at least thirty (30) days before its expiry date.

You are hereby advised to claim said Permit within sixty (60) days from receipt of the Notice otherwise it will be deemed cancelled. Check payments should be payable to **EMB-1 for the account of BUREAU OF TREASURY.**

Further, you are required to comply with Section 8 (Accreditation of PCOs) of DENR Administrative Order (DAO) 2014 – 02 within **sixty (60) days**. A list of requirements and application form of PCO Accreditation are hereby attached.

For your guidance and strict compliance.

Very truly yours,


ENGR. MARIA DORICA NAZ-HIPE, CESE
Regional Director

ecl/as
fm: R. Nisperos

Protect the environment... Protect Life...

Tel. Nos. (072)-607-3057 / 700-2448; Fax No. (072)-700-2449; e-mail: embdenr1@yahoo.com



POA-19K-01PA15-098

12:52:33 PM

05 DEC 2019

MR. JHOENSON SY SIY

Proponent
GOLDEN HARVESTA INC.
Portic, Bugallon
2416 Pangasinan

Dear **Mr. Siy**:

We are pleased to inform you the approval of Temporary Permit to Operate Air Pollution Installation of your firm. You are hereby advised, however, that said permit shall be released only to you or to your authorized representative **upon presentation of your authorization to claim the same, Professional Tax Receipt of the Mechanical Engineer and total payment of One Thousand Pesos (P1,000.00) as permit fee.**

You are also required to comply with Memorandum Circular No. 2007-003 which require generator sets to undergo emission test and to submit the Emission Test Result for the issuance of a regular Permit to Operate.

Memorandum Circular No. 2007-003 (Compliance Testing Requirements) states that: *"A small source is defined as diesel generator rated at 599 KW or less (regardless of its frequency of operation) should be tested by the permittee/facility operator once during the first year of its operation to verify its compliance. Thereafter, it should be tested once every second year".*

Please take note that **"Permit Conditions"** must be strictly observed; otherwise, penalties shall be imposed on violations pursuant to the provisions of Republic Act 8749 otherwise known as The Philippine Clean Air Act of 1999. Be reminded that said permit shall be filed at least thirty (30) days before its expiry date.

You are hereby advised to claim said Permit within sixty (60) days from receipt of the Notice otherwise it will be deemed cancelled. Check payments should be payable to **EMB-1 for the account of BUREAU OF TREASURY.**

Further, you are required to comply with Section 8 (Accreditation of PCOs) of DENR Administrative Order (DAO) 2014 – 02 within **sixty (60) days.** A list of requirements and application form of PCO Accreditation are hereby attached.

For your guidance and strict compliance.

Very truly yours,

ENGR. MARIA DORICA NAZ-HIPE, CESE
Regional Director

ecl/as
fm: R. Nisperos





REPUBLIC OF THE PHILIPPINES
DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
ENVIRONMENTAL MANAGEMENT BUREAU

Regional Office No. 1
DENR Bldg., Government Center, Sevilla, City of San Fernando,
La Union

Permit Number: POA-19K-01PA15-098

Date Issued: 05 DEC 2019

Valid Until: February 28, 2020

TEMPORARY PERMIT TO OPERATE

AIR POLLUTION INSTALLATION

Pursuant to Section I, Rule XIX of Department Administrative Order No. 2000-81, Series of 2000, known as the 'Implementing Rules and Regulations of the Philippine Clean Air Act of 1999 (RA 8749)', and Department Administrative Order Number 2004-26, PERMIT IS HEREBY GRANTED TO:

GOLDEN HARVESTA INC.

Portic, Bugallon
Pangasinan

to operate the following:

One (1) unit 268 Hp CUMMINS GLTAA-GAS Methane Gas Engine as prime mover of a Generator Set; and

One (1) unit 465 Hp CUMMINS NTA855-G1B Diesel Engine as prime mover of a Generator Set. xxx

Approved by:

Recommended by:

ENGR. NICANOR C. ESTEBAN

Chief, Clearance and Permitting Division

ENGR. MARIA DOMINICA NAZ-HIPE, CESE
Regional Director

Permit Conditions

1. The Managing Head or the Pollution Control Officer in-charge of the above facility shall keep record of its operations and shall furnish quarterly Self-Monitoring Report of the same to this Office within the first two weeks after the quarter.
2. This Permit shall be automatically suspended and penalty shall be imposed for non compliance with or violation of any provision of the Act, its Implementing Rules and Regulations, and/or permit conditions; false or inaccurate information in the application for permit that led to the issuance of the permit; false or inaccurate information in the monitoring data or in reports required by the Permit to Operate; refusal to allow lawful inspection conducted by the duly authorized personnel of the Bureau; non-payment of the appropriate fees; or other valid purposes.
3. This Permit must be posted in a conspicuous location near the facility and shall be adequately framed or otherwise protected against damage and submit proof of compliance thirty (30) days from date of issuance.
4. This permit is not transferrable, however, in case of transfer of ownership or control of the establishment and/or facilities, the transferee shall notify the Bureau within fifteen (15) working days of the fact of transfer of ownership or control.
5. Submit to this Office an Emission Test Result of your 465 Hp CUMMINS Diesel Engine-Powered Generator Set once every two years in compliance with EMB MC No. 2007-003.

Tax Identification Number 009-454-690-000

2606872	Permit Fee	1,000.00	
2606872	Filing Fee	600.00	11/11/2019
2606872	PD 1856 Fee	10.00	11/11/2019

2606872	D S T	30.00	11/11/2019
---------	-------	-------	------------

Protect the environment... Protect Life...

Tel. Nos. (072)-607-3057 / 700-2448; Fax No. (072)-700-2449; e-mail: embdenr1@yahoo.com

VALID ONLY IF AFFIXED WITH DRY SEAL

Department of Environment and Natural Resources
ENVIRONMENTAL MANAGEMENT BUREAU R01
Clearance and Permitting Division
PERMIT TO OPERATE AIR-NEW



POA-19K-01PA15-098

12:52:33 PM

Permit Number: POA-19K-01PA15-098

Date Issued: 05 DEC 2019

Valid Until: February 28, 2020

TEMPORARY PERMIT TO OPERATE

AIR POLLUTION INSTALLATION

Pursuant to Section I, Rule XIX of Department Administrative Order No. 2000-81, Series of 2000, known as the 'Implementing Rules and Regulations of the Philippine Clean Air Act of 1999 (RA 8749)', and Department Administrative Order Number 2004-26, PERMIT IS HEREBY GRANTED TO:

GOLDEN HARVESTA INC.

Portic, Bugallon
Pangasinan

to operate the following:

One (1) unit 268 Hp CUMMINS GLTAA-GAS Methane Gas Engine as prime mover of a Generator Set; and

One (1) unit 465 Hp CUMMINS NTA855-G1B Diesel Engine as prime mover of a Generator Set. xxx

Approved by:

ENGR. MARIA BORICA NAZ-HIPE, CESE
Regional Director

Recommended by:

ENGR. NICANOR C. ESTEBAN

Chief, Clearance and Permitting Division

Permit Conditions

1. The Managing Head or the Pollution Control Officer in-charge of the above facility shall keep record of its operations and shall furnish quarterly Self-Monitoring Report of the same to this Office within the first two weeks after the quarter.
2. This Permit shall be automatically suspended and penalty shall be imposed for non compliance with or violation of any provision of the Act, its Implementing Rules and Regulations, and/or permit conditions; false or inaccurate information in the application for permit that led to the issuance of the permit; false or inaccurate information in the monitoring data or in reports required by the Permit to Operate; refusal to allow lawful inspection conducted by the duly authorized personnel of the Bureau; non-payment of the appropriate fees; or other valid purposes.
3. This Permit must be posted in a conspicuous location near the facility and shall be adequately framed or otherwise protected against damage and submit proof of compliance thirty (30) days from date of issuance.
4. This permit is not transferrable, however, in case of transfer of ownership or control of the establishment and/or facilities, the transferee shall notify the Bureau within fifteen (15) working days of the fact of transfer of ownership or control.
5. Submit to this Office an Emission Test Result of your 465 Hp CUMMINS Diesel Engine-Powered Generator Set once every two years in compliance with EMB MC No. 2007-003.

Tax Identification Number 009-454-690-000

2606872	Permit Fee	1,000.00	
2606872	Filing Fee	600.00	11/11/2019
2606872	PD 1856 Fee	10.00	11/11/2019

2606872	D S T	30.00	11/11/2019
---------	-------	-------	------------

VALID ONLY IF AFFIXED WITH DRY SEAL

