

SHOP MATERIALS

NO	NPD	DESCRIPTION	IDENT	QTY
1	10	Pipes, -, Prj Std, FRP, PE, -,-, .701"	C8GYA8YY	52.1 '
2	8	Pipes, -, Prj Std, FRP, PE, -,-, .592"	C8GYAA87	1.1 '
3	10	90° Elb LR, Prj Std, FRP, PE, Prj Std, -, .701"	C8GYASKR	3
4	10	Neck Flg, ASTM D5421, FRP, 150 PSI, FF/PE - Butt & Wrap Type, -, .701"	C8M6VXFE	1

OTHER THAN SHOP MATERIALS

NO	NPD	DESCRIPTION	IDENT	QTY
5	10	NM Flat Gk, EPDM, 150 Lbs, FF as per ASME B16.5, Full Face, Thk=1/8in, -, -	C7V61SDZ	1
6	7/8	SBlt 2 HHx N&2W, A193 Gr.B7/A194 Gr.2H, -, Extra 1 Hex nut & 2 Lock Wsh, -, 9.25 in. Length	C9PNU7FL	12

INSTRUMENTS

7	10	14-FO-68989	14-FO-68989	1

PIPE SUPPORTS

8	10	PS-NM122-10-5-WWXL-FP01	PS-NM122	1
9	10	PS406-2-19.2-20-10	PS406	1
10	10	PS-NM130-10-WWXL-FP01	PS-NM130	1
11	10	PS435-B-46-20.75-20.75-1	PS435	1

PIECE MARKS

6820-R2-61029-01-1 6820-R2-61029-01-2

FRP PIPE

Filler Material Requisition

Date: 4-25-25

Line Class: WWXL-FP01

WPS: N/A

Electrode: N/A

Signature: Glenn Sumrall, Jr.

COORDINATE SYSTEM : PLANTCOORDINATES

Turner Industries Group, LLC
Received
APRIL 24, 2025
DOCUMENT CONTROL

NOTES:

1. FOR LINE PRESSURES, TEMPERATURES, INSULATION TYPE AND THICKNESS, ETC. REFER TO LATEST REVISION OF LDT.
2. FOR STANDARD PIPE SUPPORT DETAILS SEE PROJECT STANDARD.
3. FIELD SHIM TO SUIT UNLESS OTHERWISE NOTED.
4. FOR PWHT REQUIREMENTS REFER TO LINE CLASS SPECIFICATION.
5. ALL THREADED PIPE LINE SYSTEMS, FIELD SHALL VERIFY DIMENSION PRIOR TO ERECTION.
6. FFW DESIGNATION AT WELDS INDICATES FIELD FIT WELD, WHERE PIPE FABRICATOR IS TO ADD 9 INCH OF PIPE TO THE ISOMETRIC DIMENSION TO ENABLE THE FIELD TO CUT TO FIT AT SITE.
7. REFER TO 202998C-000-W1-1300-0001 FOR FRP AND DUAL-LAM FABRICATION.

TECHNIP ENERGIES

Information contained in this document is the work product of one or more legal entities of Technip Energies N.V. and embodies confidential and proprietary information of the applicable entity and/or its client.use of this information is restricted in accordance with conditions specified by the contract.Technip Energies N.V. and its affiliates disclaim any and all liabilities for any changes or modifications to this document which are made by any person other than the entity that issued the document under the applicable client contract.

THIS DOCUMENT IS UNCONTROLLED WHEN REPRODUCED

REV	DATE	BY	DESCRIPTION	CHKD	MTO	STRESS	APRVD
1	2025-04-18	RVA	ISSUED FOR CONSTRUCTION	SAD	KJK	SMR	GR
0	2024-12-06	RVA	ISSUED FOR CONSTRUCTION	SAD	KJK	SMR	GR

SERVICE:	VAPOR/LIQUID:	INSUL TYPE:	INSUL THK:	SHOP:	FIELD:	PAINT CODE:	MODULE:
R2	L	Per LDT	Per LDT	Y	Y	Per LDT	-

OxyChem Redstone Battleground
PROJECT

P&ID: 202998C-001-PID-0021-0305

UNIT#:	EWP AREA:	SPEC:	STRESS CALC #:
6800	6820	WWXL-FP01	CN-0137/CN-0255

LINE No. 10"-R2-61029-WWXL-FP01-N

DRAWING NUMBER **6820-R2-61029-01**

REV. **1**

17 APR 2025 04:46