

Project	Riverside Office Plaza				Project No.	WBR-2024-0071				
Submittal No.		SUB-2024-0041			Date	05/28/2024				
Spec Section		08 51 13 — Aluminum Windows		Sheet Ref.	A1.01, A2.01		Rev.	02	Copies	3
Submitted By		Keystone Construction Group, LLC			Contact	Brian Kettner, PM				
Phone	(217) 555-4400		Date Required	06/07/2024						

SECTION 1 — SUBMITTAL CONTENT

The following product data, shop drawings, and samples are submitted for review in accordance with the Contract Documents. Contractor certifies that all items comply with the Contract requirements.

Item	Spec Sec.	Description	Manufacturer / Model	Qty Submitted	Type
1	08 51 13	Aluminum storefront window — fixed, type W1	Kawneer 1600UT, Bronze Anodized	3 sets	Shop Dwg + Product Data
2	08 51 13	Aluminum window — operable, type W3	Kawneer 1600UT Casement, Bronze	2 sets	Shop Dwg + Product Data
3	08 51 13	Glazing specification — 1" IG, Low-E	Guardian SN68, LoE-366 Coating	2 sets	Product Data + Test Rpt
4	08 51 13	Aluminum finish sample — Color No. 4503	Anodized Bronze #4503 — 3" x 5" chip	3 ea	Sample
5	08 51 13	Sealant compatibility report — ASTM C1087	Tremco Spectrem 2 + Primer 1	1 set	Test Report
6	08 51 13	Thermal performance calc (U=0.25, SHGC=0.23)	Per ASHRAE 90.1 compliance	1 set	Calc. Sheet

SECTION 2 — CONTRACTOR CERTIFICATION

The undersigned contractor certifies that the above-listed submittals have been reviewed and checked, and are in conformance with the Contract Documents, except as noted. Deviations from the Contract Documents are identified and underlined herein. Submission of this transmittal constitutes approval by the Contractor of all stated items.

Contractor Signature:	<i>Brian Kettner</i>	Date:	05 / 28 / 2024	Title:	Project Manager
-----------------------	----------------------	-------	----------------	--------	-----------------

SECTION 3 — ARCHITECT / ENGINEER REVIEW ACTION

☒ APPROVED — Fabricate/Install per Submittal
☐ APPROVED AS NOTED — Fabricate/Install per Submittal with Corrections Noted Below
☐ REVISE AND RESUBMIT — Do Not Fabricate/Install
☐ REJECTED — Does Not Comply with Contract Documents
☐ FOR INFORMATION ONLY — No Action Required

Review Notes	Approved per Contract Documents. Confirm Low-E coating orientation per ASTM E2189. Provide field mock-up at grid line 3/B prior to full installation.
--------------	---

Reviewed By:	<i>K. P. Larsen, AIA</i>	Date:	06 / 04 / 2024	Firm:	Westbridge A+E
--------------	--------------------------	-------	----------------	-------	----------------