	GENERAL INSPECTION REPORT	QCR 004
	PROJECT: Seven Mile Unit: 4	ITP step no.: 1815

EQUIPMENT : **Torquing of outer housing to housing support**

The outer housing has been torqued to the top of the housing support using a torque value of 440 N.m lubricated.

RECEIVED
FEB 25 2003

Measured by.: Jeff Lemon (/ /)

GE Repres.: (Feb 22nd/2003)

Cust. Repres.: (/ /)

GE Canada International Inc.	Reference NC no.: ______ Comments: ______	Rev.: 0 Date: 07/23/01

GENERAL INSPECTION REPORT	QCR 004
PROJECT: Seven Mile Unit: 4	ITP step no.: 1816

EQUIPMENT : **Torquing of housing suppport to brush rigging support**

The housing support has been torqued to the brush rigging support using a torque value of 440 N.m lubricated.

RECEIVED
FEB 25 2003

Measured by.:	P. Lamontagne	(/ /)
GE Repres.:	Philippe Lamontagne	(Feb 22nd 2003)
Cust. Repres.:		(/ /)

GE Canada International Inc.	Reference NC no.: ______ Comments: ______	Rev.: 0 Date: 07/23/01

GENERAL INSPECTION REPORT

QCR 004

PROJECT: Seven Mile | Unit: 4 | ITP step no.: 1818

At re-assembly after bearing problem

Procedure SMI-U04-03090 step 1.19

ITP 2800

EQUIPMENT : **Megger test between housing and housing support.**

A megger test has been performed between the housing and the housing support.

A value greater than 1 MΩ has been measured .

the Reading was 900 MΩ

Measured by.:	François Boulet	(/ /)
GE Repres.:	François Boulet	(/ /)
Cust. Repres.:		(/ /)

GE Canada International Inc.

Reference NC no.:

Comments:

Rev.: 0

Date: 07/23/01

GE	GENERAL INSPECTION REPORT	QCR 004
	PROJECT: Seven Mile Unit: 4	ITP step no.: 1819

EQUIPMENT : **Torquing of lower seal housing**

The lower seal housing has been installed inside the outer housing using a torque value of 130 N.m lubricated.

RECEIVED
FEB 25 2003

Measured by.: P. Lamontagne (/ /)

GE Repres.: Philippe Lamontagne (Feb/22nd/2003)

Cust. Repres.: (/ /)

GE Canada International Inc.	Reference NC no.: ____ Comments: ____	Rev.: 0 Date: 07/23/01

	GENERAL INSPECTION REPORT	QCR 004
	PROJECT: Seven Mile Unit: 4	ITP step no.: 1820

EQUIPMENT : **Torquing of lower seal cover**

The lower seal cover has been installed on the lower seal housing using a torque value of 52 N.m lubricated.

FEB 25 2003

RECEIVED

Measured by.: P. Lamontagne (/ /)

GE Repres.: [illegible] (Feb/22nd/2003)

Cust. Repres.: (/ /)

GE Canada International Inc.	Reference NC no.: ________ Comments: ________	Rev.: 0 Date: 07/23/01

	GENERAL INSPECTION REPORT	QCR 004
	PROJECT: Seven Mile Unit: 4	ITP step no.: 1821

EQUIPMENT : **Torquing of inner housing cover**

The inner housing cover has been bolted to the top of the inner housing using a torque value of 52 N.m lubricated.

Measured by.: P. Lamontagne (/ /)

GE Repres.: Lamontagne (Feb 22nd 2003)

Cust. Repres.: (/ /)

GE Canada International Inc.	Reference NC no.: Comments:	Rev.: 0 Date: 07/23/01

GENERAL INSPECTION REPORT		QCR 004
PROJECT: Seven Mile	Unit: 4	ITP step no.: 1822

EQUIPMENT : **Torquing of outer housing cover**

The studs and nuts holding in place the outer housing cover were torqued at a value of 130 N.m lubricated.

Measured by.:	P. Languitagne	(/ /)
GE Repres.:	[signature]	(Feb 22nd 2003)
Cust. Repres.:		(/ /)

GE Canada International Inc.	Reference NC no.: ______ Comments: ______	Rev.: 0 Date: 07/23/01

GE	GENERAL INSPECTION REPORT	QCR 004
	PROJECT: Seven Mile Unit: 4	ITP step no.: 1823

EQUIPMENT : **Torquing of upper seal housing**

The upper seal housing has been installed on top of the outer housing cover using a torque value of 130 N.m lubricated.

Measured by.:	P. Lamontagne	(/ /)
GE Repres.:	Philippe Lamontagne	(Feb 22nd 2003
Cust. Repres.:		(/ /)

GE Canada International Inc.	Reference NC no.:	Rev.: 0
	Comments:	Date: 07/23/01

	GENERAL INSPECTION REPORT	QCR 004
	PROJECT: Seven Mile Unit: 4	ITP step no.: 1824

EQUIPMENT : **Torquing of lower seal cover**

The uppper seal cover has been installed on the upper seal housing using a torque value of 30 N.m lubricated.

Measured by.: P. Lamontagne (/ /)

GE Repres.: Stéphane Lamontagne (Feb 22nd/2003)

Cust. Repres.: (/ /)

GE Canada International Inc.	Reference NC no.: ____ Comments: ____	Rev.: 0 Date: 07/23/01

GENERAL INSPECTION REPORT		QCR 004
PROJECT: Seven Mile	Unit: 4	ITP step no.: 1825

EQUIPMENT : **Torquing of sealing plate**

The sealing plate on top of the air admission has been torqued at a value of 40 N.m lubricated.

RECEIVED
FEB 25 2003

Measured by.: (/ /)
GE Repres.: Feb, 22nd 2003
Cust. Repres.: (/ /)

GE Canada International Inc.	Reference NC no.: Comments:	Rev.: 0 Date: 07/23/01

	GENERAL INSPECTION REPORT	QCR 004
	PROJECT: Seven Mile Unit: 4	ITP step no.: 1826

EQUIPMENT : **Torquing of inspection covers** (AIR ADMISSION)

The inspection covers of the air admission have been torqued at a value of 15 N.m lubricated.

RECEIVED
FEB 2 [illegible]
CH

Measured by.:	P. Langlois	(/ /)
GE Repres.:	[signature]	(Feb/20th/2003)
Cust. Repres.:		(/ /)

GE Canada International Inc.	Reference NC no.: ______ Comments: ______	Rev.: 0 Date: 07/23/01

GENERAL INSPECTION REPORT

GE	GENERAL INSPECTION REPORT	QCR 004
	PROJECT: Seven Mile — Unit: 4	ITP step no.: 1828

At re-assembly after bearing problem

Procedure SMI-U04-03090 step 1.26

ITP 2800

EQUIPMENT : **Megger test between housing and pipes**

A megger test has been performed between the housing and the pipes of air admission.

With the two 14" pipes, the value is 150 MΩ.

As soon as the carbon is installed, the reading drops to 0. A simple conduity check was done and there is no firm continuity.

The cooling water pipe was checked by itself, the value across the insulated joint is 500 MΩ

It is impossible to check the Drain line.

FROM SSG to Housing : 200 MΩ

RECEIVED 5 Apr 2003 CH

Measured by.:	François Boulet	(03 /30/ 03)
GE Repres.:	Frank Boulet	(03 /30/03)
Cust. Repres.:		(/ /)

GE Canada International Inc.	Reference NC no.: ______ Comments: ______	Rev.: 0 Date: 07/23/01

GE	GENERAL INSPECTION REPORT	QCR 004
	PROJECT: Seven Mile Unit: 4	ITP step no.: 1829

EQUIPMENT : **Torquing of cover plates on the seal base plate under the shaft.**

The cover plates on the seal base plate under the shaft were installed using a torque value of 130 N.m

RECEIVED
FEB 28 2003

Measured by.:	F. Boulet	(Feb/28th/2003)
GE Repres.:	[signature]	(Feb/28th/2003)
Cust. Repres.:		(/ /)

GE Canada International Inc.	Reference NC no.: ______ Comments: ______	Rev.: 0 Date: 07/23/01

	FINAL INSPECTION	QCR 003
	PROJECT: Seven Mile Unit: 4	ITP step no.: 1830

THIS FORM MUST BE COMPLETED BY THE TECHNICAL DIRECTOR, QUALITY ASSURANCE OR HIS REPRESENTATIVE.

THIS FORM MUST BE COMPLETED AT THE END OF WORK FOR EACH SECTION IN THE INSPECTION AND THE TEST PLAN.

ALL NON CONFORMANCES, DISCREPANCIES, ETC. MUST BE CORRECTED BEFORE COMPLETING THIS FORM.

ONLY THE SPECIFIED ITEMS IN CONTRACT ARE SUBMITTED TO THE FINAL INSPECTION.

	YES	NO	N/A
ALL WORK WAS COMPLETED IN CONFORMITY WITH INSTALLATION MANUAL AND DRAWINGS.	✓		
THE FINAL PRODUCT HAVE BEEN INSPECTED AT THE END OF WORK AND IS IN CONFORMITY WITH CONTRACT REQUIREMENTS.	✓		
ALL NON CONFORMANCES HAVE BEEN CORRECTED ACCORDING TO THE DISPOSITION INSTRUCTIONS.	✓		
ALL CORRECTIVE ACTION REQUESTS HAVE BEEN CORRECTED AT THE CUSTOMER SATISFACTION.	✓		
ALL QUALITY ASSURANCE REPORTS HAVE BEEN COMPLETED ACCORDING TO I.T.P.	✓		
ALL FORMS HAVE BEEN REVISED AND APPROVED BY THE QUALITY ASSURANCE REPRESENTATIVE.	✓		
APPROVAL OF ENGINEERING HAVE BEEN OBTAINED WHEN NECESSARY.	✓		
APPROVAL OF CUSTOMER OR HIS REPRESENTATIVE HAVE BEEN OBTAINED WHEN NECESSARY.	✓		

REF. N.C. AND C.A.R. NB.: NC-SM1-U04-033, 34, 35, 38, 39,

COMMENTS :

RECEIVED 24Apr03 CK

Measured by.: [signature] (04/24/03)

GE Repres.: [signature] (04/24/03)

Cust. Repres.: [signature] (/ /)

GE Canada International Inc.	Reference NC no.: Comments:	Rev.: 0 Date: 07/23/01