



Installation INSPECTION AND TEST PLAN

Document #: I-GMS - 6000 Rotor disassembly
Project: GMS poles unit 1-4

Revision : 00

Unit #:

Codes: HC : hold point (customer)
WC : witness point (customer)
HA : hold point (Andritz Technical support)
WA : witness point (Andritz Technical support)

ITP step #	Code	Description	Procedure #	Procedure step #	Comments	Form	Date and initials
Measurements to be provided by customer							
6000 - 1	HA	Runner position, thrust block position and shaft verticality	P-GMS-6301-05	2.1	Four (4) guide shoes locked at 0.002"	Q-0000-001	
Rotor measurements prior to removal							
6000 - 2	HA	Rotor sweep	P-GMS-6301-05	2.2	Four (4) guide shoes locked at 0.002"	Q-1240-032	OK 2011-04-28 SM 2011-04-28
6000 - 3		Elevation difference between stator and rotor	P-GMS-6301-05	2.2		Q-GMS-6301-050	OK 2011-04-28 SM 2011-04-28
6000 - 4		Benchmark elevation	P-GMS-6301-05	2.2		Q-GMS-6301-050	OK 2011-04-28 SM 2011-04-28
6000 - 5		Pole keys grease samples for analysis	P-GMS-6301-05	2.2	For further analysis on lead content in lab.	Q-0000-001	OK 2011-04-28 SM 2011-04-28



Installation INSPECTION AND TEST PLAN

Document #: I-GMS - 6000 Rotor disassembly
Revision : 00
Unit #:
Project: GMS poles unit 1-4

Codes: HC : hold point (customer)
WC : witness point (customer)
HA : hold point (Andritz Technical support)
WA : witness point (Andritz Technical support)

ITP step #	Code	Description	Procedure #	Procedure step #	Comments	Form	Date and initials
6000 - 6		Rotor visual inspection	P-GMS-6301-05	2.2		Q-0000-001	OK 2011-05-01
6000 - 7	HA	Rotor rim speed	P-GMS-6301-05	2.3	WINSON CROMBIE TO SEND REPORT BY EMAIL OK 2011-05-04	Report	OK 2011-05-04
Rotor measurements on the powerhouse floor							
6000 - 8		Re-used parts inspection and identification	P-GMS-6300-00	1.1		Q-0000-001	OK June 17 th 2012 EJ Sept. 27, 12
6000 - 9		Poles visual inspection	P-GMS-6300-00	1.2		Q-0000-001	OK MAY 30 th 2012
6000 - 10		Rotor Megger test - 500VDC	P-GMS-6300-00	1.3		Q-0000-001 Q-0500-004	OK MAY 30 th 2012
6000 - 11		Rotor level on pedestal	P-GMS-6301-05 P-GMS-6300-00	2.4 1.4		Q-6301-041	OK APRIL 9 th 2012

Installation INSPECTION AND TEST PLAN

Document #: I-GMS - 6000 **Rotor disassembly**
Project: GMS poles unit 1-4

Revision : 00
Unit #:

Codes: HC : hold point (customer)
WC : witness point (customer)
HA : hold point (Andritz Technical support)
WA : witness point (Andritz Technical support)

ITP step #	Code	Description	Procedure #	Procedure step #	Comments	Form	Date and initials
6000 - 12	HA	Poles concentricity, circularity and verticality	P-GMS-6300-00	1.5		Q-6301-041	<i>[Signature]</i> 2013-04-20
6000 - 13		Rotor RTD and air-gap sensor identification	P-GMS-6300-00	1.8		Q-0000-001	<i>[Signature]</i> 2013-05-28
6000 - 14		Rotor pole iron elevation	P-GMS-6301-05	2.4		Q-GMS-6301-051	<i>[Signature]</i> 2013-05-28
6000 - 15		Rotor pole height	P-GMS-6301-05	2.4		Q-GMS-6301-051	<i>[Signature]</i> 2013-05-28
6000 - 16		Stator core elevation	P-GMS-6301-05	2.5		Q-GMS-6301-052	<i>[Signature]</i> 2013-08-22
6000 - 17	HA	Stator core height	P-GMS-6301-05	2.5		Q-GMS-6301-052	<i>[Signature]</i> 2013-08-22
6000 - 18		Rotor pole keys height when installed	P-GMS-6300-00	1.10		Q-0000-001	<i>[Signature]</i> 2013-04-20

Installation INSPECTION AND TEST PLAN

Document #: I-GMS - 6000 Rotor disassembly
Project: GMS poles unit 1-4

Codes: HC : hold point (customer)
WC : witness point (customer)
HA : hold point (Andritz Technical support)
WA : witness point (Andritz Technical support)

Revision : 00

Unit #:

ITP step #	Code	Description	Procedure #	Procedure step #	Comments	Form	Date and initials
6000 - 19	HA	- Rotor spider level - Rotor rim diameter, circularity, concentricity and verticality	P-GMS-6300-00	1.13		Q-6301-020C	 2012-06-01
6000 - 20		Rotor pole keys dimensions	P-GMS-6300-00	1.14		Q-0000-001	 2012-06-01
6000 - 21		Final inspection				Q-0000-002	 2012-06-05

Revision summary

Revision_00

Prepared by: François Sergerie

Approved by: François Boulet

Date: 7-Apr-2011