



Installation INSPECTION AND TEST PLAN

Document #: I-GMS - 6010 **Reassembly measurements** **Revision : 01**
Project: GMS Poles Unit 1-4 **Unit #:**

Codes: HC : hold point (customer)
WC : witness point (customer)
HA : hold point (Andritz Technical support)
WA : witness point (Andritz Technical support)

ITP step #	Code	Description	Procedure #	Procedure step #	Comments	Form	Date and initials
Reassembly measurements (Rotor in pit)							
6010 - 1	HC	Rotor sweep	P-GMS-6301-06	2.1		Q-1240-032	
6010 - 2	Step cancelled						
6010 - 3	HC	Rotor and Stator magnetic center elevations	P-GMS-6301-06	2.1	Data of stator received from customer	Q-GMS-6301-050	
6010 - 4	WC	Benchmark elevation	P-GMS-6301-06	2.1		Q-GMS-6301-050	
6010 - 5	HC	Final inspection				Q-0000-002	

Revision summary

Revision 01
Prepared by: François Sergerie
Approved by: François Sergerie

Date: 22-Feb-2012



Installation INSPECTION AND TEST PLAN

Document #: I-GMS - 6010 **Reassembly measurements** **Revision : 01**
Project: GMS Poles Unit 1-4 **Unit #:**

Codes: HC : hold point (customer)
WC : witness point (customer)
HA : hold point (Andritz Technical support)
WA : witness point (Andritz Technical support)

ITP step #	Code	Description	Procedure #	Procedure step #	Comments	Form	Date and initials
------------	------	-------------	-------------	------------------	----------	------	-------------------

- Step 6010-2 cancelled
- Step 6010-3 modified
- Customer's hold and witness points added.

Revision 00

Prepared by: François Sergerie
Approved by: François Boulet

Date: 1-Nov-2010