

11. NEC sections to read

Article / section	Topic	Why it matters here
90.2, 90.4	Scope, enforcement	AHJ, adopted edition, special permission
Art. 100	Definitions	Continuous load, feeder, SDS, tap conductors, busway
110.3(B)	Listing instructions	Starline, PDR, HEMP filter installation instructions become code requirements
110.9, 110.10	Interrupting and SCCR	Breakers, busway, plug-in units vs available fault
110.14(C), (D)	Terminal temperature, torque	75 °C column; calibrated torque
110.16, 110.21(B), 110.22, 110.24	Arc flash, hazard markings, disconnect ID, fault current marking	Labeling after the conversion
110.26	Working space	IFS, PDR, end feeds, remaining panels
200.6, 200.7	Neutral identification	5-wire neutrals
210.3–210.5, 210.19–210.21	Branch circuit ratings, MWBC, identification, conductor and receptacle sizing	Plug-in unit circuits
215.2, 215.3, 215.12	Feeder sizing, OCP, identification	End feed feeders
220.14, 220.44, 220.61, 220.87	Load calculations, neutral, existing load	Demand and transformer margin
225	Outside feeders	Exterior 125 A panel
230 (if IFS is service)	Services	Service disconnect and conductors
240.4, 240.6, 240.21(B)/(C), 240.24, 240.87	OCP, taps, secondary conductors, accessibility, arc energy reduction	Secondary conductor rule; hook-stick operation
242	Overvoltage protection (SPD)	Surge devices
250.4, 250.6, 250.24, 250.28, 250.30	Grounding purpose, objectionable current, bonding, SDS	Transformer and PDR bonding; bypass neutral switching

Article / section	Topic	Why it matters here
250.66, 250.92, 250.96, 250.102, 250.118, 250.119, 250.122, 250.142, 250.146(D)	GEC, bonding, IG, EGC types and sizing, neutral use	5-wire grounding scheme
300.3, 300.4(G), 300.11, 300.20, 300.21	Wiring methods general	Same-raceway rule, bushings, supports, induced current, firestop
310.10(G), 310.15, 310.16	Parallel conductors, ampacity	200% neutral, derating
312.6, 314.28	Bending space, pull boxes	250 kcmil terminations and pulls
344	Rigid metal conduit (RGS)	Supports, bends, fill
348	Flexible metal conduit	Whips from plug-in units
368 Part I-II (368.2, .10, .12, .17, .30, .56, .58, .60, .120)	Busways	Core article: uses, OCP, support, branches, dead ends, grounding, marking
400.10, 400.12, 400.14	Flexible cords	Cord drops
404.8	Switch/breaker mounting height	Hook-stick exception
406	Receptacles	IG receptacles, ratings
408.4, 408.36, 408.40	Panelboards	Remaining panels; IG pass-through
430 Parts II-IV	Motors	Cooling equipment
440	A/C and refrigeration	In-row coolers, CRAC
450.3, 450.9, 450.14	Transformers	Protection, ventilation, disconnect
480, 706	Batteries, ESS	PDR lithium system
645	IT equipment rooms	EPO, if Art. 645 is elected
700, 701, 702, 708	Emergency, legally required standby, optional standby, COPS	Classification of the critical busway
724/725 (2023), 760, 770	Control, fire alarm, optical fiber	External interfaces
Ch. 9 Tables 1, 4, 5, 8, 9	Conduit fill, conductor properties, impedance	Fill, VD, fault calcs

Other standards

Standard	Use
NFPA 70E	Energized work, arc-flash labeling, study review interval
IEEE 1584-2018	Arc-flash calculation
IEEE 551, IEEE 242	Short circuit, protection and coordination
IEEE C57.110, UL 1561	Transformer derating for harmonics, K-factor
IEEE 1100 (Emerald Book)	Powering and grounding electronic equipment, IG practice
ANSI/NETA ATS / MTS	Acceptance and maintenance testing
NEMA MG 1	Voltage unbalance effects on motors
UL 857	Busway listing
UL 9540, NFPA 855	ESS listing and installation
NFPA 72	Fire alarm interface
MIL-STD-188-125-1	HEMP protection; penetrations and shield
UFC 3-520-01	DoD interior electrical systems (if applicable)