

Summary Schedule		
Bar Diameter	Total Bar Length	Weight
8 mm	297225 mm	117.43 kg
10 mm	126150 mm	77.88 kg
16 mm	104625 mm	165.34 kg
20 mm	4725 mm	11.67 kg
25 mm	8750 mm	33.76 kg
	541475 mm	406.08 kg

Rebar schedule for PW-GF-05(A)												
Schedule Mark	Bar Diameter	Shape	A	B	C	D	E	G	Bar Length	Total Bar Length	Quantity	Weight
A	8 mm	M_00	0 mm	595 mm	0 mm	0 mm	0 mm	0 mm	600 mm	3000 mm	5	1.19 kg
A1	8 mm	M_00	0 mm	1095 mm	0 mm	0 mm	0 mm	0 mm	1100 mm	5500 mm	5	2.17 kg
A2	8 mm	M_00	0 mm	1375 mm	0 mm	0 mm	0 mm	0 mm	1375 mm	41250 mm	30	16.30 kg
A3	8 mm	M_00	0 mm	1415 mm	0 mm	0 mm	0 mm	0 mm	1425 mm	42750 mm	30	16.89 kg
B	8 mm	M_17	0 mm	400 mm	90 mm	400 mm	0 mm	0 mm	875 mm	20125 mm	23	7.95 kg
B1	8 mm	M_17	0 mm	400 mm	120 mm	400 mm	0 mm	0 mm	900 mm	10800 mm	12	4.27 kg
C	8 mm	M_17A	0 mm	580 mm	265 mm	0 mm	0 mm	0 mm	850 mm	3400 mm	4	1.34 kg
D	8 mm	M_T1	70 mm	200 mm	330 mm	200 mm	330 mm	70 mm	1175 mm	38775 mm	33	15.32 kg
D1	8 mm	M_T1	70 mm	330 mm	220 mm	330 mm	220 mm	70 mm	1200 mm	45600 mm	38	18.02 kg
D2	8 mm	M_T1	70 mm	330 mm	420 mm	330 mm	420 mm	70 mm	1600 mm	52800 mm	33	20.86 kg
E	8 mm	M_T10	70 mm	220 mm	0 mm	0 mm	0 mm	70 mm	375 mm	14250 mm	38	5.63 kg
E1	8 mm	M_T10	70 mm	420 mm	0 mm	0 mm	0 mm	70 mm	575 mm	18975 mm	33	7.50 kg
F	10 mm	M_00	0 mm	4365 mm	0 mm	0 mm	0 mm	0 mm	4375 mm	43750 mm	10	27.01 kg
F1	10 mm	M_00	0 mm	4995 mm	0 mm	0 mm	0 mm	0 mm	5000 mm	50000 mm	10	30.87 kg
F2	10 mm	M_00	0 mm	5035 mm	0 mm	0 mm	0 mm	0 mm	5050 mm	30300 mm	6	18.70 kg
G	10 mm	M_17A	0 mm	305 mm	745 mm	0 mm	0 mm	0 mm	1050 mm	2100 mm	2	1.30 kg
H	16 mm	M_17	0 mm	800 mm	200 mm	800 mm	0 mm	0 mm	1750 mm	5250 mm	3	8.30 kg
H1	16 mm	M_17	0 mm	800 mm	310 mm	800 mm	0 mm	0 mm	1850 mm	9250 mm	5	14.62 kg
H2	16 mm	M_17	0 mm	800 mm	400 mm	800 mm	0 mm	0 mm	1950 mm	3900 mm	2	6.16 kg
H3	16 mm	M_17	0 mm	800 mm	590 mm	800 mm	0 mm	0 mm	2125 mm	4250 mm	2	6.72 kg
H4	16 mm	M_17	0 mm	800 mm	1385 mm	800 mm	0 mm	0 mm	2925 mm	5850 mm	2	9.25 kg
I	20 mm	M_00	0 mm	2020 mm	0 mm	0 mm	0 mm	0 mm	2025 mm	2025 mm	1	5.00 kg
I1	20 mm	M_00	0 mm	2680 mm	0 mm	0 mm	0 mm	0 mm	2700 mm	2700 mm	1	6.67 kg
J	25 mm	M_00	0 mm	1830 mm	0 mm	0 mm	0 mm	0 mm	1850 mm	5550 mm	3	21.41 kg
J1	25 mm	M_00	0 mm	3180 mm	0 mm	0 mm	0 mm	0 mm	3200 mm	3200 mm	1	12.35 kg
										465350 mm	332	285.77 kg

Rebar schedule for PW-GF-05(B)											
Schedule Mark	Bar Diameter	Shape	A	B	C	D	E	Bar Length	Total Bar Length	Quantity	Weight
K	16 mm	Rebar Shape 30	935 mm	720 mm	2405 mm	255 mm	660 mm	5000 mm	5000 mm	1	7.90 kg
K1	16 mm	Rebar Shape 30	935 mm	720 mm	2445 mm	255 mm	620 mm	5000 mm	5000 mm	1	7.90 kg
K2	16 mm	Rebar Shape 30	935 mm	720 mm	2455 mm	255 mm	610 mm	5000 mm	10000 mm	2	15.80 kg
K3	16 mm	Rebar Shape 30	950 mm	625 mm	2550 mm	195 mm	<varies>	5000 mm	10000 mm	2	15.80 kg
K4	16 mm	Rebar Shape 30	950 mm	625 mm	2585 mm	195 mm	625 mm	5000 mm	20000 mm	4	31.61 kg
									50000 mm	10	79.02 kg

Rebar schedule for PW-GF-05(C)									
Schedule Mark	Bar Diameter	Shape	A	B	C	Bar Length	Total Bar Length	Quantity	Weight
L	16 mm	26	595 mm	745 mm	2925 mm	4275 mm	4275 mm	1	6.76 kg
L1	16 mm	26	905 mm	500 mm	2925 mm	4350 mm	4350 mm	1	6.87 kg
L2	16 mm	26	930 mm	545 mm	2885 mm	4375 mm	4375 mm	1	6.91 kg
L3	16 mm	26	930 mm	535 mm	2895 mm	4375 mm	4375 mm	1	6.91 kg
L4	16 mm	26	930 mm	435 mm	2990 mm	4375 mm	8750 mm	2	13.83 kg
							26125 mm	6	41.29 kg

Rebar Shape	Shape Image
M_00	
M_17	
M_17A	
M_T1	
M_T10	
REBAR SHAPE 30	
26	

PROJECT -:
MF FACTORY

GENERAL NOTES:

GRADE OF CONCRETE - M40

GRADE OF STEEL - Fe500

STRIPPING STRENGTH - M20

COVER

WALL - 30mm

CORBEL - 25mm

ALL DIMENSIONS ARE IN MM

LEGENDS:

ERECTION MARK -

MOULD FACE -

CONTRACTOR -:

VME Precast Products

 Arihant Esta, 2g2, 2nd floor,
No.370, Church Road, Mogappair East,
Chennai-600037.
Tel:+91- 98400 - 41400 / 90802 - 22066

STRUCTURAL CONSULTANT -:

ES STRUCTURAL CONSULTANT

 B167, 12th cross street, Jawahar Nagar,
Palayamkottai, Tirunelveli-627007
Cell No: +91 9865803764

0	23-07-25	FOR APPROVAL	PK	PRC
Rev	Date	Description	Chkd	Appd.

REVISION SCHEDULE

DRAWING TITLE -:

PW-GF-05-BBS

JOB NO. : ESP24075	DRAWN BY:- IH
ELEMENT NO. : PW-GF-05	SHEET SIZE:- A3
DWG. NO. : PW-GF-05(S)	REV.NO:- 0
SCALE :	LEVEL. :