



Office of Executive Engineer, Jal Nigam
(Gramin) Etah U.P.
Analysis Report of Water

17/18/15

To,

Report No. E023

Place/Source of Sampling - Tanishka International Public School

Nagar Name- Barailly Block-

District- Barailly

Name of Sample Collector- Rashmi

Date/Time- 24-04-2024 11:25 am


Date of Analysis- 27-04-2024

Latitude-

Longitude-

S. No.	Parameter (Unit)	BIS Acceptable Limit	Unit Mg/l	BIS Permissible Limit in Absence of alternate source	Result	Remarks
1	Turbidity	1.0	NTU	5	1.36	
2	pH	6.5-8.5	-	No Relaxation	7.04	
3	Chloride	250	Mg/l	1000	48	
4	TDS	500	Mg/l	2000	320	
5	Alkalinity	200	Mg/l	600	38	
6	Fluoride	1	Mg/l	1.5	0.46	
7	Nitrate	45	Mg/l	No Relaxation	0.94	
8	Sulphate	200	Mg/l	400	28	
9	Total Hardness	200	Mg/l	600	106	
10	Iron	1	Mg/l	No Relaxation	0.04	
11	Calcium	75-200	Mg/l		58	
12	Magnesium	30-100	Mg/l		48	
13	Colour	5-15	Hazen Unit		5	
14	Odour	-	-		Agreeable	
15	Taste	-	-		Agreeable	
16	Total Coliform		Shall not be Detectable in any 100 ml Sample		Not Detected	
17	E.coli		Shall not be Detectable in any 100 ml Sample		Not Detected	

Rashmi Arya
प्रबन्धक
तनिष्का इंटरनेशनल पब्लिक स्कूल
संजय नगर, पुलिबा नं० 1
सैनिक कालोनी, बरेली



Rashmi Arya
प्रबन्धक
तनिष्का इंटरनेशनल पब्लिक स्कूल
संजय नगर, पुलिबा नं० 1
सैनिक कालोनी, बरेली