

**Fill the Information Below**

Company: **Rezayat Company Limited**

Date: 12/16/2020

Location: **Auditorium**

Time: 10:30 AM

Project/ Site Name: Site Name: Catering Auditorium & Recreation Facilities : **097-C76R**

Worst Potential Severity: 3  
Actual Severity: 3

**Person(s) Involved:**
**Employee**
**Contractor**
**Others**

1. Abdul Rahman (Badge no-34537)

3.

2.

Other(s).

**Type of Incident:**

Near Miss

**Injury Location by Body Parts (Select one or more if necessary):**

Head	Chest	Hand	Eyes
Face	Leg	Arm	Hip
Neck	Abdomen	Wrist	Ankle/Foot
Back	Stomach	Elbow	Knee
Nose/ Ears	Shoulder	Fingers/ Thumb	Toes

**Type of Injury Sustained (Select one or more if necessary):**

Fracture	Cut/ Laceration	Scalping	Bruising
Loss of Sight	Loss of Consciousness	Heat	Amputation
Dislocation	Crush Injury	Cold	Other(s)
Abrasion	Suffocation	Burn	

**Immediate Cause(s) (Select one or more if necessary):**

Safety Rule Violated	Lack of Resources	Drugs/ Alcohol Related	Inadequate Visibility
Lack of Task Skill	Method Deviation	Poor Housekeeping	Employee Morale
Lack of Supervision	Poor Weather Conditions	Inadequate Lighting	Employee Attitude
Improper Lifting (MH)	Lack of Task Knowledge	Poor Team Work	Behavior Problem
Not Paying Attention	Lack of Communication	No Risk Assessment	Poor Ground Conditions
Human Error	Incorrect Tools/Equip	Defective Equipment	Improper Lifting (crane)
Inadequate PPE	Defective Tools	Unprotected excavation	Unprotected Edge
Animals	Violence	Horseplay	Improper/ Poor Slings
Heat Stress	STF Above Ground	STF on the Same Level	Manual Handling
Misuse of Hand Tools	Grinding/ Welding	Knives/ Sharps	Hit by Vehicle
Hit by Static Machinery	Heavy Equipment	Splashes from C.P.O.L.	Other(s) :
Stress	Fatigue	Vandalism	

**Equipment(s) Involved:**

Light Vehicle:	Heavy Vehicle:	Plant Equipment:	Static Plant Equipment:
Building:	Structure:	Scaffold:	Excavation:
Other(s):			

**Description of the Event:**

Today at 10:30 hours, while the steel fixing team was working on one of the scaffolding platform,

one scaffolding pipe (length 1 meter) fell from the platform (between the DOKA gaps)

Where steel team was working and hit the ground near to the scaffolder who was working downside the scaffolding platform.

**Immediate Action(s) Taken to Prevent Reoccurrence (If Any):**

Work was stopped immediately and Near miss was discussed with the crew.


Always ensure no loose material on platform before putting yellow tag.

Avoid simultaneous operation as far as possible.

Barricade the area and ensure no one stand beneath the working platform.

Supervisor should be present there for close monitoring.

**Person Created the Report:**

Name: Sufyan Javed	Position: Safety Officer	Signature: 	Date: 12/16/2020
--------------------	--------------------------	---	------------------

