

Fill the Information Below

Company: Rezayat Company Limited

Date: 3/17/2021

Location: Yanbu

Time:

Project/ Site Name: Corrosion Repair and protective works

Worst Potential Severity: 1

Actual Severity: 1

Person(s) Involved:

Employee

Contractor

Others

1. Faiz Alam 30039806

3. Narayan Sarker 30040810

2. Zamal Khan 30040807

Other(s).

Type of Incident:

Property Damage

Injury Location by Body Parts (Select one or more if necessary):

Head	Chest	Hand	Eyes
Face	Leg	Arm	Hip
Neck	Abdomen	Wrist	Ankle/Foot
Back	Stomach	Elbow	Knee
Nose/ Ears	Shoulder	Fingers/ Thumb	Toes

Type of Injury Sustained (Select one or more if necessary):

Fracture	Cut/ Laceration	Scalping	Bruising
Loss of Sight	Loss of Consciousness	Heat	Amputation
Dislocation	Crush Injury	Cold	Other(s)
Abrasion	Suffocation	Burn	

Immediate Cause(s) (Select one or more if necessary):

Safety Rule Violated	Lack of Resources	Drugs/ Alcohol Related	Inadequate Visibility
Lack of Task Skill	Method Deviation	Poor Housekeeping	Employee Morale
Lack of Supervision	Poor Weather Conditions	Inadequate Lighting	Employee Attitude
Improper Lifting (MH)	Lack of Task Knowledge	Poor Team Work	Behavior Problem
Not Paying Attention	Lack of Communication	No Risk Assessment	Poor Ground Conditions
Human Error	Incorrect Tools/Equip	Defective Equipment	Improper Lifting (crane)
Inadequate PPE	Defective Tools	Unprotected excavation	Unprotected Edge
Animals	Violence	Horseplay	Improper/ Poor Slings
Heat Stress	STF Above Ground	STF on the Same Level	Manual Handling
Misuse of Hand Tools	Grinding/ Welding	Knives/ Sharps	Hit by Vehicle
Hit by Static Machinery	Heavy Equipment	Splashes from C.P.O.L.	Other(s) :
Stress	Fatigue	Vandalism	

Equipment(s) Involved:

Light Vehicle:	Heavy Vehicle:	Plant Equipment:	Static Plant Equipment:
Building:	Structure:	Scaffold:	Excavation:
Other(s):			

Description of the Event:

During removal of Sweet sand using Back hoe loader equipment from the housing area, the teeth of backhoe loader bucket hit the potable water line valve box which was under sweet sand and damage to the pipe line. This causes the leakage of water in the location.

Immediate Action(s) Taken to Prevent Reoccurrence (If Any):

Shutdown the water supply by closing the pipe.
Reported to concern department MASA for further rectification through Project manager.
Instructed not to store any material near or over the client property.

Person Created the Report:

Name: Ejaz Akthar	Position: Safety Officer	Signature:	Date: 3/17/2021
-------------------	--------------------------	------------	-----------------