

Fill the Information Below

 Company: **Rezayat Company Limited**

Date: 2/15/2021

Location: Auditorium Part 2,

Time: 02:30 PM

 Project/ Site Name: Catering Auditorium & Recreation Facilities : **097-C76R**

Worst Potential Severity: 2

Actual Severity: 3

Person(s) Involved:

Employee

Contractor

Others

1. Surya Bahadur Thapa (30039751)

3.Praveen Kummari (31037192)

2.An Bahadur Magar(30037483)

Other(s).

Type of Incident:

Near Miss

Injury Location by Body Parts (Select one or more if necessary):

Head	Chest	Hand	Eyes
Face	Leg	Arm	Hip
Neck	Abdomen	Wrist	Ankle/Foot
Back	Stomach	Elbow	Knee
Nose/ Ears	Shoulder	Fingers/ Thumb	Toes

Type of Injury Sustained (Select one or more if necessary):

Fracture	Cut/ Laceration	Scalping	Bruising
Loss of Sight	Loss of Consciousness	Heat	Amputation
Dislocation	Crush Injury	Cold	Other
Abrasion	Suffocation	Burn	

Immediate Cause(s) (Select one or more if necessary):

Safety Rule Violated	<input checked="" type="checkbox"/>	Lack of Resources	Drugs/ Alcohol Related	Inadequate Visibility
Lack of Task Skill		Method Deviation	Poor Housekeeping	Employee Morale
Lack of Supervision	<input checked="" type="checkbox"/>	Poor Weather Conditions	Inadequate Lighting	Employee Attitude
Improper Lifting (MH)		Lack of Task Knowledge	Poor Team Work	Behavior Problem
Not Paying Attention		Lack of Communication	No Risk Assessment	Poor Ground Conditions
Human Error		Incorrect Tools/Equip	Defective Equipment	Improper Lifting (crane)
Inadequate PPE		Defective Tools	Unprotected excavation	Unprotected Edge
Animals		Violence	Horseplay	Improper/ Poor Slings
Heat Stress		STF Above Ground	STF on the Same Level	Manual Handling
Misuse of Hand Tools		Grinding/ Welding	Knives/ Sharps	Hit by Vehicle
Hit by Static Machinery		Heavy Equipment	Splashes from C.P.O.L.	Other(s) :
Stress		Fatigue	Vandalism	

Equipment(s) Involved:

Light Vehicle:	Heavy Vehicle:	Plant Equipment:	Static Plant Equipment:
Building:	Structure:	Scaffold:	<input checked="" type="checkbox"/> Excavation:
Other(s):			


Description of the Event:

While performing housekeeping on the scaffolding platform, tie rod plate fell down from platform to bottom. Luckily area was barricaded and no one was there no injury or property damage was reported.

Immediate Action(s) Taken to Prevent Reoccurrence (If Any):

- Gaps on the platforms must be closed
- Take help of team. After finish his work removal loose material.
- Barricade the area from downside.
- Always depute one person downside to monitor pedestrian access.

Person Created the Report:

Name: Mohammed Arif	Position: Safety Officer	Signature: 	Date: 2/15/2021
---------------------	--------------------------	---	-----------------

