





Name of Employee	Mohammad Hasnain	Badge No.	(30040429)	Profession/ Designation	Mason
Safety Awareness Training Date	3,sep,2019	Proof of Training	Induction		
Name of Line Manager	Weesam Ramadan	Badge No.	30040315		
Name of Supervisor	Mehmood	Badge No.	31034797		
Division / Department	CIVIL Department	Project Name	097-C76R	Project Location	JUC
Place of the Incident/Injury	Area 3	Date of Incident	27-06-2021	Time of Incident	07:45 AM
Nature of the Incident/Injury	Occupational Incident/Injury	Yes	<input checked="" type="checkbox"/>	No	
	Road Traffic Incident/ Injury	Yes		No	<input checked="" type="checkbox"/>
				Near Miss	
					Other, Please specify : First Aid Case
Brief Description of the Incident/Injury	IP was unloading CMU blocks from the bucket of telehandler, on the rooftop on central kitchen (inclined roof of sandwich panel). IP was standing on A-type ladder which was supported on the bucket of the telehandler (as shown in the picture). At that time the ladder got slipped and lower portion of the ladder got bended. IP grabbed the bucket and hung onto it and the lower portion of the bucket hit on his stomach. He got abrasion injury as a result. He was taken site's first aid room to get treatment.				
Details of the Injury (Specify affected body parts)	Abrasion Injury on Stomach				
First Aid Given?	Yes	<input checked="" type="checkbox"/>	No		Name of First Aider Baseur Fer saud
Name of Hospital where patient was treated/transferred	N/A		Address/Location of the hospital N/A		
Medical leave given by administering Hospital/Clinic or Doctor	Yes		No	<input checked="" type="checkbox"/>	Number of Days N/A
Property damage	Yes		No	N/A	Estimated percentage of damage N/A
Property Details	Type / Function of the property	N/A		Location of affected property	N/A
	Name of Manufacturer	N/A			
	Model of the Property	N/A		Plate Number	N/A
	Vehicle Registration Number	N/A		Company Fleet Number	N/A

Was Pre- Task / Toolbox meeting conducted	Yes	✓	No		Was the person using required Personal Protective Equipment (PPE)	Yes	✓	No	
Specify the Personal Protective Equipment (PPE)				Safety Gloves, Glasses, Helmet, Shoes					
What was the injured person/employee doing at the time of the incident?					Unloading CMU Blocks from the Bucket of Telehandler.				
What was the machine/equipment doing at the time of the incident?					Telehandler lifted the CMU Blocks from ground to C.K Rooftop (Sandwich panel roofing)				
What was the material/s / substance/s doing at the time of the incident					N/A				
Immediate Cause/s of the Incident/injury: Used Ladder inappropriately and as a result got abrasion injury. Also due to lack of Task skills and competency.									
Root Cause/s of the Incident/injury: People: IP adopted wrong procedure and also there was no supervision from Team leader. Process / Procedure: Ladder must not be used as per Safe work procedure. Equipment: Telehandler was okay for the task. Workplace: Workplace was not suitable for use of Ladder as the floor of the roof was bended.									
Corrective Action to prevent reoccurrence: Elimination: N/A Substitution: N/A Engineering Control: Good condition Ladder should be used for such works. Mobile equipment bucket should be rested properly at a location where worker can easily remove material without using ladder. Administrative Control: Instructions were given on the safe use of ladders and manual handling. Ensure Ladder must not rest on the mobile equipment. Buddy system should be used for Ladder by holding one crew ladder and other crew work on it. Ensure Close supervision all time PPE: PPE's Should be used all time.									
Were there any witnesses?	Yes		None	✓	Type of witness/s	Employee		Public	
Witness Details -					Badge Number		Mobile Number		
Witness Statement:									
Initial Investigation Conducted by: <i>Wagdy Ghalib</i> 					Noted by: Mustafa Ali 		Date	27-06-2021	

Additional Details:



Investigation Report Verified by:

Noted by:

Date

27-06-2021