




Name of Employee	Maqbool Hussain	Badge No.	65186	Profession/ Designation	Scaffolder
Safety Awareness Training Date	09-06-2020	Proof of Training	Induction		
Name of Line Manager	Mustafa Ali	Badge No.	4049		
Name of Supervisor	Ibrahim Sabri	Badge No.	32055		
Division / Department	Civil	Project Name	097-c76R	Project Location	auditorium
Place of the Incident/Injury	Auditorium, part 1	Date of Incident	16-12-2020	Time of Incident	08:45 AM
Nature of the Incident/Injury	Occupational Incident/Injury	Yes	No	✓	Other, Please specify :
	Road Traffic Incident/ Injury	Yes	No	✓	
Brief Description of the Incident/Injury	<p>Today at 10:30 hours, while the steel fixing team was working on one of the scaffolding platform, one scaffolding pipe (length 1 meter) fell from the platform (between the DOKA gaps) where steel team was working and hit the ground near to the scaffolder who was working downside the scaffolding platform.</p> <p>Fortunately no injury or property damage happened.</p>				
Details of the Injury (Specify affected body parts)	N/A				
First Aid Given?	Yes	No	✓	Name of First Aider	
Name of Hospital where patient was treated/transferred				Address/Location of the hospital	
Medical leave given by administering Hospital/Clinic or Doctor	Yes	No	✓	Number of Days	
				Hospitalization	Yes
					No
					✓
Property damage	Yes	No	✓	Estimated percentage of damage	
				Estimated Cost of damaged (SAR)	
Property Details	Type / Function of the property	N/A		Location of affected property	N/A
	Name of Manufacturer	N/A			
	Model of the Property	N/A		Plate Number	N/A
	Vehicle Registration Number	N/A		Company Fleet Number	N/A

Was Pre- Task / Toolbox meeting conducted	Yes	✓	No	Was the person using required Personal Protective Equipment (PPE)	Yes	✓	No
Specify the Personal Protective Equipment (PPE)	Helmet, shoes, vest, glasses, gloves and harness						
What was the injured person/employee doing at the time of the incident?	N/A						
What was the machine/equipment doing at the time of the incident?	N/A						
What was the material/s / substance/s doing at the time of the incident	Scaffolding tubes laying on the scaffolding platform						
Immediate Cause/s of the Incident/injury: Loose material kept on scaffolding platform Root Cause/s of the Incident/injury: loose material kept on platform People: Scaffolder did not removed the materials after erecting the scaffolding Process / Procedure: Housekeeping not done before start of work on the platform Equipment: N/A Workplace: Poor housekeeping, loose materials on the platform							
Corrective Action to prevent reoccurrence: Elimination: N/A Substitution: N/A Engineering Control: All gaps on the platform must be closed. Administrative Control: Loose scaffolding materials must be removed from the scaffolding platform after finishing the work. PPE: All workers must wear necessary PPEs at site.							
Were there any witnesses?	Yes	✓	None	Type of witness/s	Employee	✓	Public
Witness Details Mehar Zaman(scaffolder)				Badge Number 40754	Mobile Number		
Witness Statement: As per him there was loose tubes on platform left by erection team which fell down due to the gaps between doka I beams.							
Initial Investigation Conducted by: Krishna Pillai 				Noted by: Mustafa Ali 		Date 10-1-2021	

Additional Details:



Investigation Report Verified by:	Noted by:	Date	
-----------------------------------	-----------	------	--

