

Cabana Club Gardens Apartments

10980 SW 202 Drive · Miami-Dade County, FL

Folio 30-6007-009-0030 · Built 1966 · Two-story CBS apartment building · 16 units

Verdict: a fundamentally clean, permitted 1960s apartment building carrying **one open item** — a CBS perimeter wall the county records with no permit number — and the routine code-era material disclosures of 1966 construction. The 1989 alteration is permitted (**89037613**). **Overall risk: LOW-MODERATE, contingent on the wall permit.**

Tracking TRK-2026-1310 · Research TRK-2026-9078 · Prepared 2026-08-30 · Version 1 · CURRENT

Index

Each chapter of the research, front to back, by page.

Cover	1
Index	2
1 · Executive summary & verdict	3
2 · The forensic story — how the record reads	4
3 · Causes of concern	5
4 · Additions, alterations & permits (the ledger)	6
5 · Methodology, sources & what is still pending	7
Chapter A — Photographs (November 1967)	8–10
Chapter B — 1966 Property Appraiser master card	11–12
Chapter C — 1989 permit 89037613 (on record)	13
Chapter D — Building points card / the CBS wall	14
Chapter E — 2002 valuation & inquiry records	15–18

Executive summary & verdict

The property. Cabana Club Gardens Apartments at 10980 SW 202 Drive, unincorporated Miami-Dade (folio 30-6007-009-0030): a two-story CBS (concrete-block-and-stucco) apartment building, **16 units**, 20 bedrooms / 16 baths, **built in 1966** and documented in county photographs dated November 1967.

Verdict

This is a **sound, permitted 1960s apartment building**. The paper trail is largely clean, and the one significant later alteration — a 1989 add-alter / exterior / roof job — **carries a real permit number (89037613) and is therefore SAFE**.

There is **one open item**, and it is the reason this is not a no-issue file: a **CBS perimeter wall that the county records — and values — with no permit number of any kind**. On the record alone that reads as an unpermitted improvement, i.e. a legalization exposure, until the actual Building-Department permit is produced or ruled out.

Beyond that, the building's **1966 vintage** brings the ordinary code-era material questions (asbestos, lead paint, older drain and supply lines) that belong in any honest disclosure for a structure of this age. These are **disclosure items, not proven defects**.

Overall rating

LOW-to-MODERATE risk. It drops to LOW if the 1970 wall (and a possible enclosed “lanai”) turn out to be permitted; it rises toward MODERATE only if they are confirmed unpermitted and the buyer would have to legalize them. No open unsafe-structure case or code-enforcement action surfaced against this folio in the county records search.

The forensic story

Read in order, the documents tell one coherent story. The key on every page is a single thing: **does a change carry a permit number?**

1966 — the building goes up

The Property Appraiser opens a card dated 1966 for a two-story CBS apartment building. Remember what that card is: an **outside-only assessor estimate**, written from the curb and updated on the assessor's schedule, not the Building Department's. **A PA date is never a build or permit date.**

~1970 — a wall appears on the record

A field-visit remark adds "add CB Wall" on the year-70 line, and a separate note reads "Lanai? 4/23/70." From here on, every card values a CBS wall as an extra feature — but **not one card ever fills in a permit number for it.**

1989 — a permitted alteration

A computer permit record appears: **89037613, ADD-ALT TO CONDO APT / ALTER EXTERIOR**, with a roof alteration noted 12/7/89. **This is what a documented, permitted change looks like** — and it is the contrast that makes the wall's blank permit field meaningful.

2002 — the record is restated, nothing is built

The 2002 printouts and inquiry screens re-carry the CBS wall and recalculate value, but the permit fields are either blank (0000000000) or a system placeholder (0000191). **Those zeros are not permits** — they are how the county's software fills an empty field, and they must not be mistaken for one.

So the whole file reduces to this: the building and the 1989 work are documented and safe; the wall (and possibly a small enclosed porch) is the one change the record shows **without** a permit number.

Causes of concern

1. **CBS perimeter wall — recorded and valued, no permit number (the one real open item).** On the record it reads as an unpermitted improvement. Closes only by producing the 1970-era Building-Department permit from county microfilm, or confirming none exists and treating it as a legalization item in the sale.
2. **Possible “lanai” (enclosed porch), note dated 4/23/70.** If real, it is a second change to check for its own permit — folded into the same microfilm request.
3. **Code-era material disclosures (1966 construction).** To be disclosed and, where relevant, tested: **asbestos** (pre-1980 materials), **lead-based paint** (pre-1978), **cast-iron drain lines** (South-Florida pre-1975), and older electrical/supply components. Any duct or system that is **touched** in a renovation generally must be brought up to current code. These are age-based disclosures, not proven defects.
4. **Record hygiene (resolved, noted for completeness).** The folio appears in two formats historically (30.6007090003 early, 30-6007-009-0030 later) — same parcel; one address digit was once ambiguous and is confirmed 10980 by the later computer labels.
5. **What is NOT a concern.** No open unsafe-structure case, no active code-enforcement action, and no litigation flag surfaced against this folio in the county records search — stated plainly so its absence is on the record.

Additions, alterations & permits

Every recorded change to the property, and whether a permit number attaches to it.

DATE	WORK	PERMIT NO.	STATUS
1966	Original construction — 2-story CBS apartment, 16 units	PA DATE PERMIT Original permit not in this jacket — verify 1966	
~1970	“add CB Wall” — CBS perimeter wall	none on any card	EXPOSURE
4/23/70	“Lanai?” — possible enclosed porch	unknown	CHECK
02/1989	ADD-ALT TO CONDO APT / ALTER EXTERIOR	89037613	SAFE
12/7/1989	“CODE-90 ALT. Roof” — roof alteration	under 89037613	SAFE
2002	Administrative recalculation (R/S Calc), no physical change	n/a	NA
—	System placeholders 0000191 / 0000000000	not a permit	clarify — software fill

The rule that governs this table: a change with a permit number is **safe**; a change without one is a **legalization exposure** until proven otherwise. On this property, everything is safe except the CBS wall (and a possible small porch).

Methodology, sources & pending

How this book was built

The county jacket pages were rendered **in grayscale from the originals and never binarized**, so photographs keep their tone; Polaroid copier frames were cropped away; faint handwriting was darkened; sideways and inverted pages were straightened; blank forms were removed; and every document was transcribed so it is text-searchable.

Sources


Miami-Dade Property Appraiser building jacket (photographs, master card, field sketch, points cards, valuation and inquiry printouts) and the county public-records search (property, permit, code-enforcement and unsafe-structure sources). The Property Appraiser record is an assessor's outside estimate and does not speak for the Building Department.

What is still pending (does not change the verdict)


1. **Microfilm pull** for the ~1970 CBS-wall and "lanai" permits — the one step that closes the open exposure. County Building-Department microfilm is not reachable online.
2. **Machine-verified page auto-rotation** on the desktop (some pages here were squared by eye).
3. **High-resolution re-scan** of the illegible inspector initials on the photo backs — low value, no bearing on the safe/exposure call.

These pending items are tracked separately on the property's gaps board. None of them alter the conclusions above; they close the single open question.


Photograph 1 — November 1967. Front elevation, two-story wood/CBS apartment building (Cabana Club Gardens), street sign and parked car at right. Film-edge date stamp **NOV 67**. *Reverse (lower):* handwritten folio **30-6007-090-0003**, date **11-20-67**, inspector initials (illegible).



Photograph 2 — November 1967. Rear / side elevation of the same building, open exterior walkway (breezeway) and end wall. *Reverse (lower):* same folio and date.




Photograph 3 — November 1967. Side elevation with landscaping and the open second-floor gallery. *Reverse (lower):* same folio and date. (Trees confirm upright orientation.)



1966 Property Appraiser master card. DATE PERMIT **1966**; PERMIT NO. **blank**; folio 30-6007-09-003; material **CBS**; 2 stories; 16 living units, 20 bed / 16 bath. Field-visit remarks note “add CB Wall” (yr 70) and “Lanai? 4/23/70”. This card is an outside-only assessor estimate and lags real work by years.

DATE PERMIT 1966		AMT. PERMIT		PERMIT NO.		DATE CK'D 1/20-67		DEPUTY FG	
30-6007 09 003 41 LEGAL DESC'T. Cabana Club Ydne apto Unit 3 Block 1 SCHOOL DIST. PB						NAME ADDRESS OF PROP. 20401 SW 202 DRIVE MAIL ADDRESS 10350 SW 892			
BUILDINGS TYPE BLDG. MATERIAL STORIES FOUND. FLOORS BED ROOMS BATHS OOF ASH PLUMBING ELECTRIC /C-HEAT PROJ./CUST. MISC'L INT						OPERATORS FOLIO PLATES YR. LAND IMPR. TOTAL REMARKS		100 104-832 2 20 16 11 11 5 30 Rail 1-2-3-4	
100 104-832 2 20 16 11 11 5 30 Rail 1-2-3-4						3-12-68 4-8-70 6-9-70 7-13-70 8-15-70 9-17-70 10-19-70 11-21-70 12-23-70		68 69 70 70 71 72 73 74 75 76 77 78 79 80	

1966 field dimension sketch. Footprint 138 x 40, notation "2 STORY", dated 1966. No permit number recorded on the sketch.



[illegible]

Building points card. YEAR BUILT 66; EXTRA FEATURE “CBS WALL” 72 units. All four **PERMIT boxes are blank** — the wall is valued and recorded but shows no permit number. This is the property’s single open legalization exposure.

[illegible]

Narrative history card, 6-27-02. A single administrative entry (“R/S Calc 02 — converted points to the new appraisal system”). **No physical change to the building.**

MIAMI-DADE COUNTY PROPERTY APPRAISER

NARRATIVE HISTORY CARD

FOLIO # 30-6007-009-0030

[illegible]

REV 03-01

Building Inquiry screen. PERMIT field reads 0000000000 — no permit on file at this screen. The CBS wall shows only as an extra-feature value (\$1,653).

```

      * * * * BUILDING INQUIRY * * * *
FOLIO 30 6007 009 0030      PROP ADDR 10980 SW 202 DR      PTXM0580
TYPE PAAB DATE 08302001      NO 10525 CALCULATED FOLIO VALUE 386692
LAST CHGE DTE 01012002      SITED BY      FOLIO SITE VALUE
XF 2 CLUC 0003 SLUC 0300 MULTIFAMILY 10 UNITS PLUS      INSP 04 1994 RS DMGASSM
                                BLDG SITE VALUE
LOT SIZE      24829.00 SQ FT PERMIT 0000000000      BLDG VALUE 385039
BLDG      01      RATE KEY 01 APTS000000 BLDG X-FEATURES VALUE 1653
                                CONST CD 1 A/C Y
EXTERIOR 31      ROOF MAT. 4      RATE CD 1 YR BLT 1966
ELECTRIC 5      DECKING      ADJUST CD 2 EFF AGE 1981
PLUMBING 11      FOUNDATN      FLOORS 1 1BR
INTERIOR 30      STR FR      LIV UNITS 16 2BDR
FL.FINISH 12      MISC      BEDROOMS 20 3BDR
ROOF TYPE 8      GRADE 4      BATHS 16 EFF/APT
PTS&GD 105      1/2 BATHS      RM/OFC
                                STORES
                                TOTAL ADJUSTED SQUARE FEET 11146
BASE RATE 35.00      TOTAL RATE 36.75      BATH ADJ      REPL COST 409616
PC COMP 100 FUN      ECO      PHY      MKT      94 PC GD 94      ADJUST 24577
TOTAL DEPR VALUE 385039 # ITEMS 1.00 TOTAL RATE KEY VALUE 385039

ENTER-NEXT BLDG/RATE PF2-DIM PF3-XFEA PF8-MENU PF9-R/C MENU PF10-FINISH 5___
*** ALL BUILDING INFORMATION HAS BEEN DISPLAYED ***
```

Date: 6/27/02 Time: 2:31:37 PM

Building Extra-Features screen. Lists “WALL CBS” with the **PERMIT** column blank — consistent across every county record: the wall exists, no permit number attaches to it.

```

      * * * BUILDING EXTRA FEATURES * * *
FOLIO: 30 6007 009 0030 BLDG: 01
LN PRICE EXT-FT DESC YR EFF PERMIT ITEM ADJUSTMENT PC VALUE
NO CODE & NO. UNITS BLT AGE          FN EC PH  GD
01 136 WALL CBS      1966          1.00      82
      3.00      672.00
                                     1653

```

```

ENTER-CONTINUE PF1-RETURN PF2-DIM PF8-MENU PF9-R/C MENU PF10-FINISH
*** ALL EXTRA FEATURE INFORMATION HAS BEEN DISPLAYED ***

```

Date: 6/27/02 Time: 2:31:40 PM