

Modbus TCP Server Device Parameters**Parameters:**

Name:	Type:	Value:	Default Value:	Unit:	Description:
Timeout	DINT(500..200000)	0	0		Configuration of the TimeOut
InputAssemblySize	UINT(2..4096)	10	10		Configure the size of the loscanner register
OutputAssemblySize	UINT(2..4096)	10	10		Configure the size of the loscanner register
Port	UINT	502	502		Port where the Server is listening for requests
BindPort	BOOL	FALSE	FALSE		Bind Mdobus port to IP address of specified ethernet adaper
OptimizationOn	BOOL	TRUE	TRUE		the driver optimizes the io update
UpdateableHolding	BOOL	FALSE	FALSE		Holding Registers as %Q-data for local update by application
DistinctBitAreas	BOOL	TRUE	FALSE		Coils and Discrete Inputs data blocks get their own IO-Mapping
Coils Size	UINT	16	0		Number of Coils
Discrete Inputs Size	UINT	16	0		Number of Discrete Inputs
StartAddresses					Start Addresses of Modbus Data Areas
Coils	UINT	0	0		
DiscreteInputs	UINT	0	0		
HoldingRegister	UINT	0	0		
InputRegister	UINT	0	0		
Data Model Options	UDINT	0	0		0 = default, 1 = Holding- and Input-Register Data Areas overlay
CloseTCPsocketAtTimeout	BOOL	TRUE	TRUE		Close TCP-socket at timeout
SerialGatewayEnabled	BOOL	FALSE	FALSE		
ComPort	USINT	1	1		COM port number to use for the serial communication
Baudrate	Enumeration of UDINT	9600	9600		Baudrate of the serial port.
Status					Device's status information
Version	UDINT	1	1		
Connections	UDINT				Number of active TCP-Client Connections
TCP-Port Status	Enumeration of UDINT				Current State of TCP Port
Request Counter	UDINT				Total number of incomming client requests
Modbus Exception Counter	UDINT				Number of Request that have been rejected with Exception Code
Serial Gateway					
Active	BOOL				TCP/Serial gateway function is enabled
align	BYTE				
align	BYTE				
align	BYTE				
COM-Port Status	Enumeration of UDINT				Current State of COM-Port
Request Counter	UDINT				Number of forwarded requests

Device: ModbusTCP_Server_Device

Error Counter	UDINT			Number of failed forwarded requests
Timeout	DINT(500..200000)	2000	2000	Actual value of the TimeOut configured
InputAssemblySize	UINT(2..4096)	10	10	Actual value of the size of the assembly
OutputAssemblySize	UINT(2..4096)	10	10	Actual value of the size of the assembly
Port	UINT	502	502	Current Port where the Server is listening for requests
Unit-ID	BYTE	0	0	Current Unit-ID of the Server (optional)
ConfigVersion	UDINT	16#03051000	16#03051000	

Modbus TCP Server Device I/O Mapping

Input Parameters:

Mapping:	Channel:	Address:	Type:	Unit:	Description:
Application.PLC_PRG.Start_Button	Bit0		BOOL		
Application.PLC_PRG.E_Stop_Button	Bit1		BOOL		
Application.PLC_PRG.Reset_Button	Bit2		BOOL		

Output Parameters:

Mapping:	Channel:	Address:	Type:	Unit:	Description:
Application.PLC_PRG.Tank_Level	Input Registers[0]		WORD		
Application.PLC_PRG.Flow_Rate	Input Registers[1]		WORD		
Application.PLC_PRG.Intake_Runtime_Sec	Input Registers[2]		WORD		
Application.PLC_PRG.Discharge_Runtime_Sec	Input Registers[3]		WORD		
Application.PLC_PRG.Intake_Pump	Bit0		BOOL		
Application.PLC_PRG.Chlorine_Valve	Bit1		BOOL		
Application.PLC_PRG.Mixer_Motor	Bit2		BOOL		
Application.PLC_PRG.Discharge_Pump	Bit3		BOOL		

IEC objects:

Variable:	Type:
ModbusTCP_Server_Device	IoDrvModbusTCPSlave

Information

Name: ModbusTCP Server Device
Vendor: CODESYS
Categories: ModbusTCP Server Device
Type: 115
ID: 0000 0002
Version: 4.6.0.0
Order number: -
Description: A device that works as a Modbus TCP Server.
Configuration version: 3.5.16.0