Examination 2: Convection

Heat Transfer Ch En 3453

Rules:

- Open book and notes
- Calculators and use of software (like Excel) allowed
- Anyone caught communicating with others during the exam (via email, text, chat, in person, etc.) will receive a score of zero on the exam and will be disciplined according to university policies.
- Attempt to answer as much of each problem as possible. Partial credit may be awarded based on completing parts of the problem correctly or demonstrating the correct thought process.

Report answers to at least 3 significant figures.

Name	Sost whitehead	
UNID	U106934 3	

Problem 1 (25 pts)

Air at 20 °C flows parallel to a flat plate at 12 m/s. The heated plate is kept at a constant temperature (T_s) of 145 °C. If the plate is 1 m wide and 10 m long, what is the total amount of heat (in W) that is transferred from the plate to the air?

Use the following thermal properties for air:

ρ	1.16 kg/m ³
μ	1.846x10 ⁻⁵ (N*s/m ²)
k	2.63x10 ⁻² (W/m*K)
Pr	.707

20 12 "sec]= 14/5

Re = PLV : 7540628 JJ 5 XIOS : Turbulent

Nu = 6.0296Re 468 P113 = awasto = 8375.76

h= Nuk = 8375.2.63 x102 = 22.03 === K


9- LA (T5-T00) = 22.03.10.1 (145-20) - 27535 = 2.75×104 W

Problem 2 (25 pts)

Water at 30 °C enters a pipe with an inner diameter of 6 cm. The pipe's inner wall is held constant at a temperature of 110 °C. If the water's velocity is 2.3 cm/s, what is the mean temperature of the water at x = 14 m from the pipe entrance?

Use the following thermal properties for water:


ρ	998 kg/m ³		
μ	0.000890 (N*s/m²)		
k	0.598 (W/m*K)		
Pr	6.99		
Cp	4180 (J/kg*K)		




Problem 3 (25 pts)

A hot, 3 m tall wall with a constant surface temperature of 330 K causes natural convection to happen in a room. There is also forced convection due to a downward draft of cooler air at 280 K. Given the Nusselt numbers for forced and natural convection below, what is the average rate of heat flux from the wall to the room air?

$\overline{Nu_F}$	650	
$\overline{Nu_N}$	450	
Kair	.0262	W/m*K
Kwall	20.3	W/m*K





Problem 4 (25 pts)

Page 8 of 9

A counterflow heat exchanger (double-pipe configuration) is used to recover heat from a hot fluid in order to heat up a cold fluid.

Assuming that the exchanger is at steady state, what is the value of the product U*A (in W/K)?

T _{c,i} (cold fluid inlet temperature) = 170 K	T _{h,i} (hot fluid inlet temperature) = 418 K	
	T _{h,o} (hot fluid outlet temperature) = 290 K	
\dot{m}_c (cold fluid mass flow rate) = 5 kg/s	\dot{m}_h (hot fluid mass flow rate) = 3 kg/s	
C _{p,c} (cold fluid heat capacity) = 1,570 J/kg*K	C _{p,h} (hot fluid heat capacity) = 2,320 J/kg*K	

$T_{c,o}$			Cold fluid	T _{c,i}
$T_{h,i}$	→ He	ot fluid		T _{h,o}
9: ~	C (To-T;)	LETA AN IP	MA = 9	- ~ ((To-T;)
0H=	3.2320(290-	418 - (290-170) -	- (30) - X	9: 800680 W
		- H(H(TOH-T; H)		
٦	10,0 = m + CH	DT.4 + Tic - 3	BN 583 K	
T A N	g q.	120-134 - 890	880 0157	- 1724 1135118001
				13 K/48 2000