

720862	I-95 over SR 109 (University Blvd)	Slightly Aggressive	Moderately Aggressive (Resistivity = 2,979 ohm-cm	Moderately Aggressive (Resistivity = 2,979 ohm-cm
720863	I-95 over Spring Glen Road	Slightly Aggressive	Moderately Aggressive (Resistivity = 1,453 ohm-cm	Moderately Aggressive (Resistivity = 1,453 ohm-cm
729022	Pedestrian Bridge over I-95	Slightly Aggressive	Moderately Aggressive (Resistivity = 2,979 ohm-cm	Moderately Aggressive (Resistivity = 2,979 ohm-cm

5. When additional bridge conduits are required beyond those already provided in the bridge traffic railings, for utility or aesthetic lighting purposes, conduits shall be located directly under the bridge deck, and in an interior beam bay.
6. Visibility of all bridge drainage conveyance systems shall be minimized as much as possible. The conveyance systems (piping) shall not be embedded within the piers or run within box structures but attached to the exterior and aesthetically integrated with the pier. The conveyance systems must be painted in accordance with the Department's Structures Detailing Manual (SDM) Section 22.3.1.E. Avoid, when possible, placing drainage pipes inside of box superstructures by providing inlets near piers.
7. The Design-Build Firm shall be responsible for providing new bridge deck drainage systems in locations necessary to accommodate spread criteria or where stipulated by the regulatory agencies. Bridge drainage system material requirements shall comply with Chapter 22 of the Structure Detailing Manual supplemented as follows:
 1. Socket fittings shall be used and shall conform to ASTM D2467, and threaded fittings shall conform to ASTM D2464.
 2. When possible, to account for bridge expansion, separate the downspout from the collector pipe and insert a minimum of 3 inches.
 3. Pipes shall be hung beneath the deck utilizing two linked eye rods.
8. The LRFD Operational Importance Factor shall be 1.0 for all bridges.
9. A permanent steel shell for forming and casting is not allowed for concrete pier caps.
10. Integral abutments shall not be permitted.

Materials

11. A Class 5 Applied Finish Coating shall be provided as shown in Project Aesthetic Requirements.
12. Lightweight concrete shall not be permitted for any structural applications.
13. Reinforcing steels other than allowed by SDG 1.4.1.B are not permitted, except in drilled shafts and auger-cast piles. This restriction does not apply to non-corrosive materials that are allowed for by the RFQ.
14. Use of uncoated weathering steel is not permitted.
15. All proposed structural steel shall be painted with a High Performance Coating System in accordance with Sections 560 and 975 of the Specifications. The High Performance Coating System shall consist of an inorganic zinc rich primer, epoxy intermediate coat, polyurethane finish