

- 6. Full enclosure cladding / railing combination
- D. Utilize FDOT standard fence designs or connection details from *Standard Plans* Index 550-010, 550-011, 550-012 and 550-013 where applicable.

10.10 ENCLOSURES, DECORATIVE FEATURES, AND ATTACHMENTS

- A. A decorative feature (architectural cladding, etc.) attached to a pedestrian bridge is a Community Aesthetic Feature that must be approved by the Department. See *FDM* 127.
- B. For pedestrian bridges other than prefabricated steel trusses, connections for enclosures, decorative features, lighting, signs, traffic signals, and other attachments (architectural cladding, etc.) must be designed by the Project Engineer of Record (EOR) with the details included in the Plans. Do not defer to the shop drawings for the design and detailing of these connections. For prefabricated steel truss pedestrian bridges designed by the Contractor's EOR, the Project EOR must review the connection details through the shop drawing process in accordance with Section 5 of the *Specifications*.
- C. Provide access for inspection and maintenance of the connections for enclosures, decorative features, and other attachments. The tapping of holes into structural steel tubular members is not allowed.
- D. For an enclosed pedestrian bridge with or without climate control, establish the environmental classification based on the assumption that the enclosure is not present. The Department does not consider the presence of an enclosure or climate control to provide protection from the surrounding environmental conditions, as those items could be removed in the future.
- E. Design and detail enclosures, decorative features, and other attachments to provide complete inspection access to all superstructure components, connections, and bearing areas. See *SDG* 10.15 for more information on inspection and maintenance.
- F. For wind loads, design attachments for enclosures, decorative features, lighting, signs, and traffic signals as per the *AASHTO LRFD Bridge Design Specifications* and the *LRFD Specifications for Structural Supports for Highway Signs, Luminaires, and Traffic Signals*. See *SDG* 10.3 for special wind analysis considerations.
- G. Design and detail drainage from enclosures, decorative features, and other attachments as required by *SDM* Chapter 22.

10.11 DRAINAGE

- A. Design and detail drainage systems as required. See *SDM* Chapter 22.
- B. Provide curbs, drains, pipes, or other means to drain the superstructure pedestrian deck. Drainage of the superstructure onto the roadway underneath is not allowed.
- C. Conform to ADA requirements for drainage components.