

3. The deck design thickness is defined as the top of the SIP metal forms to the finished deck surface.
4. Use design methodology per **LRFD** 4.6.2.1 using the strip method.
5. The minimum reinforcing steel is No. 4 bars at 12-inch spacing in each direction.
6. If the deck is continuous over supports, refer to **SDG** 4.2.6, 4.2.7, or 4.2.8 for applicable criteria.
7. For drip grooves, refer to **SDG** 4.2.12.
8. For concrete deck finish see **Specifications** Section 400-15.2.5.2.

10.3 LOADING

This section supplements the **LRFD Guide Specifications for the Design of Pedestrian Bridges**.

- A. Design all pedestrian bridges for wind speeds specified in **SDG** Table 2.4.1-1.
- B. Calculate design wind loads on truss type pedestrian bridges according to the **LRFD Specifications for Structural Supports for Highway Signs, Luminaires, and Traffic Signals**. For all other types of pedestrian bridges calculate design wind loads according to **SDG** 2.4.1 and the **LRFD Bridge Design Specifications**.
- C. For pedestrian bridges over 75-feet high or with unusual structural features, submit wind load calculations to the SSDE for approval.
- D. A special wind analysis may be required for pedestrian bridges with enclosures, decorative features, architectural cladding, etc. For the purposes of considering the need for a special wind analysis, the bridge fencing per **Standard Plans** Index 550-012 is not considered an enclosure. Consult the SDO early in the planning process to determine the need for a special wind analysis, as this could have a significant impact on the project design budget and schedule.

10.4 MATERIALS

- A. Require that all materials be in compliance with the applicable **Specifications**.
- B. Careful attention shall be given in selecting combinations of metal components that do not promote dissimilar metals corrosion.
- C. Specify ASTM A500 Grade B or C for structural tubing. The minimum thickness for structural tubing is 1/4-inch for top and bottom chords and 3/16-inch for verticals and diagonals.
- D. For steel I-girder superstructures, see **SDG** 5.3.1 for the structural steel material requirements.