



FLORIDA DEPARTMENT OF Environmental Protection

Northwest District
160 W. Government Street, Suite 308
Pensacola, FL 32502

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Shawn Hamilton
Secretary

March 3, 2022

Mr. David Sloan, Plant Manager
Dolomite Inc, Marianna
1321 Highway 71
Marianna, Florida 32447
Sloand54@hotmail.com

Re: Dolomite, Inc
FL0101192
Jackson County

Dear Mr. Sloan:

A compliance sampling inspection was conducted at Dolomite on December 21, 2021. During this inspection, potential non-compliance was noted. The purpose of this letter is to offer compliance assistance as a means of resolving this matter.

Specifically, potential non-compliance with the requirements of chapter 403, Florida Statutes, Chapter 62-160, Florida Administrative Code, were observed. Please see the attached inspection report for a full account of Department observations and recommendations.

We request you review the items of concern noted and respond in writing within **15 days** of receipt of this Compliance Assistance Offer. Your written response should include one of the following:

1. Describe what has been done to resolve the non-compliance issue or provide a schedule describing how/when the issue will be addressed.
2. Provide the requested information, or information that mitigates the concerns or demonstrates them to be invalid.

It is the Department's desire that you are able to adequately address the aforementioned issue so that this matter can be closed. Your failure to respond promptly may result in the initiation of formal enforcement proceedings.

Please address your response and any questions to Larry Couch of the Northwest District Office at (850) 767-0047 or via email at Larry.Couch@floridadep.gov. We look forward to your cooperation with this matter.

Dolomite, Inc.
FL0101192
Compliance Assistance Offer
Page 2 of 2

Sincerely,



Erin Rasnake
Assistant Director
Compliance Assurance Program

KFM/lc

Enclosures: Inspection Report Form
 Inspection Report Summary
 Sampling Inspection Report

cc: David Thompson, Dolomite Inc, (dolomite.inc@gmail.com)
Michael Fuller, DEP Pensacola Office (Michael.Fuller@floridadep.gov)



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

SAND MINE COMPLIANCE INSPECTION REPORT



Facility Details

Facility Name	Dolomite, Inc			WAFR ID	FL0101192		
Physical Address	1321 Highway 71			City, State, Zip	Marianna, FL 32448		
County	Jackson			Facility Phone #	850-482-5570		
Permit Issued:	11/17/2018			Permit Expiration:	11/26/2023		
Facility Type	Sand Mine			Is the Facility NPDES (Y/N)	Yes		
Latitude	Degrees °	30	Minutes ‘	39	Seconds “	29.64	
Longitude	Degrees °	85	Minutes ‘	9	Seconds “	59.77	

Inspection Details

Inspection Type		Entry Date		Exit Date		
CSI		12/21/2021		12/21/2021		
		Entry Time (HH:MM AM/PM)		Exit Time (HH:MM AM/PM)		
		1:00 PM		2:30 PM		
Sampling Taken (Y/N)	Yes	RQ#	RQ-2021-11-15-15		QA Conducted (Y/N)	Yes
Name(s) and Title of Field Representatives(s)		Operator Certification		Email		Phone Number
David Thompson, Superintendent		NA		dolomite.inc@gmail.com		(850) 209-3903
Name(s) and address of Permittee / Designated Rep.		Title		Email		Phone Number
David S. Sloan PO Box 1568 Marianna, FL 32447		President		sloan54@hotmail.com		(850) 482-5570

Inspector Information

Name(s) and Signature(s) of Inspectors(s)	District Office/Phone Number	Date
Larry Couch 	NWD/850-767-0047	1/19/2022
Name and Signature of Reviewer	District Office/Phone Number	Date
Krista F. McGraw 	NWD/850-595-0612	1/20/2022

Facility Compliance Eval Areas

<i>IC = In Compliance; MC = Minor Out of Compliance; NC = Out of Compliance; SC = Significant Out of Compliance; NA = Not Applicable; NE = Not Evaluated Significant Non-Compliance Criteria Should be Reviewed when Out of Compliance Ratings Are Given in Areas Marked by a “*”</i>							
Overall Compliance Determination							
IC	*Permit	NA	Laboratory	IC	Facility Site Review	IC	*Effluent Quality
NA	*Compliance Schedules	NA	Sampling	NA	Flow Measurement	IC	*Effluent Disposal
MC	*Records & Reports	NA	Biosolids	IC	*Operation & Maintenance	NA	*Groundwater
NA	SSO Survey	NA	Other	NA	Nutrient Management Plan	NA	Access Control
NA	Site Restrictions & Setbacks	NA	Odor/Nuisance	NA	Site Monitoring	NA	MLPW Disposal
NA	Manure Solids						

Clear Report	Hide/Unhide Placeholders	Generate Blank Rows (for field paper setup)	Generate Deficiency & Observation Rows	Finish Inspection Report Form
---------------------	---------------------------------	--	---	--------------------------------------

Single Event Violations (“*” SNC SEVs)

Check for Yes	Evaluation Area	Description	Finding Description	Finding ID
---------------	-----------------	-------------	---------------------	------------

☐	Permit	Effluent Violations - Unapproved Bypass	Wastewater was diverted from a portion of the treatment process without department approval.	UNBY
☐	*Permit	Permit Violations - Discharge Without a Valid Permit	The facility was operating without a permit or with an expired permit.	UPHI
☐	Permit	Permit Violations - Failure to Submit Timely Permit Renewal Application	The permittee failed to submit an application to renew the existing permit at least 180 days prior to expiration.	PFSA
☐	Laboratory	Management Practice Violations - Laboratory Not Certified	The laboratory was not certified by the National Environmental Laboratory Accreditation Conference (NELAC).	LNCE
☐	Sampling	Monitoring Violations - Analysis not Conducted	The facility failed to collect and/or analyze samples as required by permit or enforcement action.	ANCV
☐	Sampling	Monitoring Violations - Failure to Monitor for Toxicity Requirements	The facility failed to collect and/or analyze routine or follow-up toxicity samples.	FTOX
☐	Records and Reports	Management Practice Violations - Failure to Develop Adequate SPCC Plan	The facility failed to develop or maintain their Spill Prevention Control and Countermeasures (SPCC) plan.	FSPC
☐	Records and Reports	Management Practice Violations - Failure to Maintain Records	The facility failed to maintain records for the required retention period.	FMRR
☐	Records and Reports	Reporting Violations - Failure to Notify	The permittee failed to notify the department of any event or activity that requires notification as required by permit or rule.	RSWP
☐	Records and Reports	Reporting Violations - Failure to Submit DMRs	The permittee failed to submit any DMR required by rule, permit, or enforcement action in a timely manner.	FDMR
☐	Records and Reports	Reporting Violations - Failure to submit required report (non-DMR, non-pretreatment)	The facility failed to submit any report required by rule, permit, enforcement action or inspection activity except for DMRs.	FRPT
☐	Facility Site Review	Management Practice Violations - Improper Land Application (non-503, non-CAFO)	The land application system was not being maintained.	LASN
☐	Flow Measurement	Monitoring Violations - No Flow Measurement Device	The facility failed to install a flow measurement device, an approved flow measurement device, or a working flow measurement device.	NOFL
☐	Operation and Maintenance	Management Practice Violations - Improper Operation and Maintenance	The facility failed to follow their operation and maintenance plan/manual.	IONM
☐	Operation and Maintenance	Management Practice Violations - Inflow/Infiltration (I/I)	The facility had an inflow and infiltration problem causing collection system issues and/or operational issues.	ININ
☐	Operation and Maintenance	Management Practice Violations - No Licensed/Certified Operator	The facility was being operated without a certified operator or by an operator that is not licensed for the size of plant.	ONCO
☐	*Effluent Quality	Effluent Violations - Failed Toxicity Test	Persistent acute toxicity has been documented through follow-up tests.	EATX
☐	*Effluent Quality	Effluent Violations - Failed Toxicity Test	Persistent chronic toxicity has been documented through follow-up tests.	ECTX
☐	*Effluent Quality	Effluent Violations - Failed Toxicity Test	Persistent acute or chronic toxicity has been documented in the effluent through the use of routine and follow-up tests.	ETOX
☐	Effluent Quality	Effluent Violations - Narrative Effluent Violation	The facility violated a permit or enforcement narrative effluent limit.	XNEV
☐	Effluent Quality	Effluent Violations - Reported Fish Kill	The facility had a discharge of wastewater that resulted in a fish kill.	XFSH
☐	Sanitary Sewer Overflow Survey	WW SSO - Discharge to Waters	A sewage spill from any components of a collection/transmission system or from a treatment plant reached surface waters including stormwater conveyance system or drainage ditch.	SSO1
☐	Sanitary Sewer Overflow Survey	WW SSO - Failure to Maintain Records or Meet Record Keeping Requirements	The facility failed to keep routine documentation and reporting records of spills, and/or operation and maintenance activities on the collection/transmission system.	SSO2
☐	Sanitary Sewer Overflow Survey	WW SSO - Failure to monitor	The facility failed to collect and/or analyze bacteriological samples for sewage spills that reached surface waters.	SSO3
☐	Sanitary Sewer Overflow Survey	WW SSO - Failure to report violation that may endanger public health 122.41(I)(7)	The facility failed to report a sewage spill within 24 hours of discovery.	SSO4
☐	Sanitary Sewer Overflow Survey	WW SSO - Improper Operation and Maintenance	The facility failed to perform routine preventative maintenance to keep the collection/transmission system in good working order.	SSO5
☐	Sanitary Sewer Overflow Survey	WW SSO - Overflow to Dry Land	A sewage spill from any part of a collection/transmission system or treatment plant that did not make it to surface waters, i.e., stormwater collection system, drainage ditch, stream, pond, or lake.	SSO6

Permit

Compliance Rating	In Compliance
Does this section apply to the facility?	☒ Yes ☐ No
Questions	
*Is the permit current?	Yes
Is a copy of the permit available onsite?	Yes
Is the facility operated in accordance with the permit?	Yes
*Was the facility constructed or modified with an appropriate or valid permit issued by the Department?	Yes
Has the facility submitted the permit renewal application within the required timeframe prior to the expiration date?	N/A
If the permittee for the facility has changed did the department receive notification of this change?	N/A
If the permit is accompanied by a Consent Order or Administrative Order are, they abiding by the conditions of the order?	N/A
Is wastewater diverted from a portion of the treatment process with Department approval?	N/A
*Is the facility discharging to waters of the state with an appropriate FDEP permit?	Yes
*Was the facility free from unpermitted discharge, bypass, collection system, or residuals with a high potential for water quality or health impacts?	Yes
Is the facility free from any Permit violation not listed above that needs to be addressed?	Yes
- Significant Non-Compliance Criteria per Program Guidance Memo OWM-00-01 Should be Reviewed when Checklist Items Deficiencies are Noted and Marked by a "*" - Questions with "No" responses indicate deficiencies - Questions with "N/A" responses do not apply to the facility	
Observations:	
No issues were observed in this section.	

Compliance Schedule

Compliance Rating	Not Applicable
Does this section apply to the facility?	☐ Yes ☒ No
Questions	
If the facility has a compliance schedule in a permit, Administrative Order or Enforcement Action are they in compliance with the schedule?	N/A
*Are the Compliance Date(s), Construction Milestone(s), Enforcement Order Schedule(s) or Final Compliance Date started/completed within 90 days of the due date?	N/A
Has the facility completed construction and submitted a Notification of Completion of Construction for Wastewater Facilities or Activities (Form 62-620.910(12)), if required?	N/A
Has the Notification of Availability of Record Drawings and Final Operation and Maintenance Manuals (Form 62-620.910(13)) been submitted as required?	N/A
If the facility is under a Toxicity Corrective Action Plan, are they in compliance with the plan?	N/A
Is the facility free from any Compliance Schedule violation not listed above that needs to be addressed?	N/A
- Significant Non-Compliance Criteria per Program Guidance Memo OWM-00-01 Should be Reviewed when Checklist Items Deficiencies are Noted and Marked by a "*" - Questions with "No" responses indicate deficiencies - Questions with "N/A" responses do not apply to the facility	
Observations:	

There is no compliance schedule for this facility.

Records and Reports

Compliance Rating	Minor Out of Compliance			
Does this section apply to the facility?	☒	Yes	☐	No
Questions				
Is the Best Management Practices (BMP) Plan onsite and available for review by staff?	Yes			
Was the BMP Plan prepared by certified Engineer?	Yes			
Does the BMP Plan include plots, plans, drawings or maps?	Yes			
Does the BMP Plan identify areas, systems, and components with the potential to release pollutants to surface waters?	Yes			
Does the BMP Plan predict direction, flowrate, and total quantity of pollutants which could be discharged from the facility?	Yes			
Does the BMP Plan have specific preventative and remedial procedures to prevent pollutants from reaching state waters?	Yes			
Is the BMP Plan modified when there are change(s) at the facility?	N/A			
Does the facility maintain the records onsite for the required retention period?	Yes			
Has the permittee notified the Department of any event or activity that requires notification as required by permit or rule?	N/A			
*Has the facility submitted all report(s) required by rule, permit, enforcement action or inspection activity, other than DMRs? (If any reports are >30 days late meets SNC criteria)	N/A			
*Are records or reports free from falsified data?	Yes			
Is the facility free from any Records and Reports violation not listed above that needs to be addressed?	No			
- Significant Non-Compliance Criteria per Program Guidance Memo OWM-00-01 Should be Reviewed when Checklist Items Deficiencies are Noted and Marked by a "*" - Questions with "No" responses indicate deficiencies - Questions with "N/A" responses do not apply to the facility				
Deficiencies & Corrective Actions:				
Is the facility free from any Records and Reports violation not listed above that needs to be addressed? [See Deficiency Narrative for Specific Rule Violated]	Deficiency: (Narrative) A records review of the August and May 2021 field audit and chain of custody sheets indicated that the facility failed to include the facility permit number and plant staffing on DMR Part B. Sample preservation type, sample receipt temperature and the person's facility affiliation who relinquished the samples were not included on the August 16, 2021 laboratory chain of custody. QA Rule 62-160			
	Corrective Action(s): (Narrative) Update the lab chain of custody and DMR standard operating procedure to include the facility permit number, plant staffing, preservation type, sample receipt temperature and person's facility affiliation as noted in the deficiency above.			
Quality Assurance Evaluation: DMR Part A, DMR Part B and Groundwater DMR QA Audit Checklists				
Please see deficiency and corrective action stated above. Ackuritlabs, Inc. (NELAC#: E81350) is the contract laboratory for turbidity and TSS. pH is collected by Homer Sims.				
Observations:				

Per permit condition I.A.1. the facility is required to perform grab samples monthly for flow, turbidity, TSS and pH.

Facility Site Review

Compliance Rating	In Compliance			
Does this section apply to the facility?	☒	Yes	☐	No
Questions				
Measures are in place at mine to prevent unauthorized entry around the entire perimeter of the site?	Yes			
The mine is designed and constructed per permit application / BMP?	Yes			
Are all sites operating in accordance with the BMP Plan?	Yes			
Site grading directs all wastewater and stormwater to swales and settling ponds?	Yes			
All above grade earthen dams that store process water and runoff are properly constructed and maintained?	Yes			
The mine is free from signs of overflow or evidence of a discharge around the perimeter of the site?	Yes			
No unauthorized discharge to waters of the state was observed during the inspection?	Yes			
Number of ponds onsite?	3 Yes			
Ponds are free from sediment/excessive solids/vegetation/shreen?	Yes			
All earthen pits and associated berms are inspected and documented for freeboard and berm integrity?	Yes			
Is the facility free from any Facility Site Review violation not listed above that needs to be addressed?	Yes			
- Significant Non-Compliance Criteria per Program Guidance Memo OWM-00-01 Should be Reviewed when Checklist Items Deficiencies are Noted and Marked by a “*” - Questions with “No” responses indicate deficiencies - Questions with “N/A” responses do not apply to the facility				
Observations:				
No issues were observed during the facility inspection.				

Operations and Maintenance

Compliance Rating	In Compliance			
Does this section apply to the facility?	☒	Yes	☐	No
Questions				
The facility is operated under the supervision of a person who is qualified by formal training and/or practical experience?	Yes			
The facility was maintaining site inspection frequency and logs?	Yes			
There is no evidence that the mine has expanded its operations?	Yes			
If operations have been expanded, has a new ERP permit been applied for?	N/A			
Are approved chemicals added to process water? (If yes, identify type in observations)	N/A			
The facility was free from any evidence of unauthorized offsite discharges to ground or surface waters?	Yes			

*The facility was operated and maintained in accordance with the description of the permit which did not result in a high potential for water quality impacts?	Yes
*All equipment onsite is maintained and is generally in good condition not resulting in a high potential for water quality or health impacts?	Yes
Is the facility free from any Operation and Maintenance violation not listed above that needs to be addressed?	Yes
- Significant Non-Compliance Criteria per Program Guidance Memo OWM-00-01 Should be Reviewed when Checklist Items Deficiencies are Noted and Marked by a “*” - Questions with “No” responses indicate deficiencies - Questions with “N/A” responses do not apply to the facility	
Observations:	
No issues were observed with this section.	

Effluent Quality

Compliance Rating	In Compliance			
Does this section apply to the facility?	☒	Yes	☐	No
Questions				
DMR review period:	3/1/2017-11/30/2021 Yes			
A review of the Discharge Monitoring Reports revealed the following effluent exceedance(s).	No exceedances within review period N/A			
*Are the effluent limits without exceedances four out of six months (chronic criteria)?	Yes			
*Did the effluent limits exceed the Technical Review Criteria less than two times in a six month period?	Yes			
Was the facility free of a discharge of wastewater that resulted in a fish kill?	Yes			
Does the facility meet the permit or enforcement narrative effluent limitation(s)? (Non-DMR visible sheen defined as iridescence present so as to cause taste or odor, or otherwise interfere with the beneficial use of the receiving water)	Yes			
Is the effluent free from excessive (suspended solids, foam, grease, scum) in the discharge stream?	Yes			
*Was the facility free from any other violation with a high potential for water quality or health impacts?	Yes			
Is the facility free from any Effluent Quality violation not listed above that needs to be addressed?	Yes			
- Significant Non-Compliance Criteria per Program Guidance Memo OWM-00-01 Should be Reviewed when Checklist Items Deficiencies are Noted and Marked by a “*” - Questions with “No” responses indicate deficiencies - Questions with “N/A” responses do not apply to the facility				
Observations:				
No exceedances were noted for the review period. DMRs are being submitted timely by the facility.				

Effluent Disposal

Compliance Rating	In Compliance
Does this section apply to the facility?	☒ Yes ☐ No
Questions	
The discharge location(s) are as per the permit?	Yes
*At the time of inspection was the mine observed to be free from evidence of a bypass or failure from the storage ponds?	Yes
The disposal pond berms were free from excessive growth or vegetation?	Yes
*Was the disposal system being operated as designed with a low potential for water quality or health impacts?	Yes
*There was no unauthorized operation or modification of the effluent disposal system.	Yes
Is the facility free from any Effluent Disposal violation not listed above that needs to be addressed?	Yes
- Significant Non-Compliance Criteria per Program Guidance Memo OWM-00-01 Should be Reviewed when Checklist Items Deficiencies are Noted and Marked by a “*” - Questions with “No” responses indicate deficiencies - Questions with “N/A” responses do not apply to the facility	
Observations:	
Facility's discharge location D-001 was observed and in good condition. Flow from Chipola River was flowing into the device at the time of the inspection (negative flow).	

Groundwater

Compliance Rating	Not Applicable
Does this section apply to the facility?	☐ Yes ☒ No
Questions	
DMRs review period	N/A
Are the groundwater monitoring results sent to the Department on Discharge Monitoring Report, Form 62-620.910(10), F.A.C. or entered into EzDMR and submitted by the DMR due date?	N/A
After a review of the Discharge Monitoring Reports, are the compliance well parameters meeting the groundwater standards in the time period reviewed (12 months or greater)?	N/A
A review of the Discharge Monitoring Reports revealed the following effluent exceedance(s).	N/A
Does the facility's purging logs on DEP Form FD 9000-24 indicate that purging was done properly; including sufficient volume, purge rate, depth to water, and stability criteria (pH, Temperature, Conductivity, Dissolved Oxygen, Turbidity).	N/A
Is the groundwater monitoring report complete and accurate, including analysis method, laboratory method detection limits, static water level, purging logs, sample collection procedures and treatment?	N/A
Do the groundwater monitoring wells meet DEP requirements including; tamper-proof locks, unique well label(s), concrete well pad with protective bumpers not containing numerous cracks, and is free of clutter for sampling purposes.	N/A
If or when new well construction was completed did the facility plug and properly abandoned the existing well and submit Monitoring Well Completion Report, Form 62-520.900(3) to DEP within 60 days?	N/A
If a monitoring well became damaged or inoperable was maintenance conducted and notification sent to DEP within 2 days of discovery?	N/A

Is the well(s) that the facility is sampling at, part of the approved groundwater monitoring plan?	N/A
Are the monitoring wells operable to the extent that sampling is possible?	N/A
Are groundwater samples being collected and analyzed as required by the permit or enforcement action; including location, well type, sample type (grab/composite), time, and frequency?	N/A
If sampling was observed were the sample collection activities being performed in accordance with DEP SOP FS 2200?	N/A
If sampling was observed was equipment in satisfactory condition?	N/A
If sampling was not observed is the description of sample collection activities being performed in accordance with DEP SOP FS 2200?	N/A
Is the facility free from any Groundwater violation not listed above that needs to be addressed?	N/A
- Significant Non-Compliance Criteria per Program Guidance Memo OWM-00-01 Should be Reviewed when Checklist Items Deficiencies are Noted and Marked by a “*” - Questions with “No” responses indicate deficiencies - Questions with “N/A” responses do not apply to the facility	
Observations:	
There is no groundwater monitoring for this facility.	

Other

Compliance Rating	Not Applicable			
Does this section apply to the facility?	☐	Yes	☒	No
Questions				
*Is the facility free from any violation not listed above, or pattern of noncompliance, resulting in a high potential for water quality or health impacts (Any violations considered significant by the Secretary, Deputy Secretary, Director of District Management, or the Division Director meet SNC criteria)	N/A			
Please describe any potential Non-wastewater violations (i.e. hazardous waste, stormwater, SLERP, Air and Storage Tanks) that were referred.	N/A			
- Significant Non-Compliance Criteria per Program Guidance Memo OWM-00-01 Should be Reviewed when Checklist Items Deficiencies are Noted and Marked by a “*” - Questions with “No” responses indicate deficiencies - Questions with “N/A” responses do not apply to the facility				
Observations:				
No non-wastewater observations were made.				

Deficiencies Summary

Evaluation Area: Records and Reports	
Is the facility free from any Records and Reports violation not listed above that	Deficiency: (Narrative) A records review of the August and May 2021 field audit and chain of custody sheets indicated that the facility failed to include the facility permit number and plant staffing on DMR Part B. Sample preservation type, sample receipt temperature and the person's facility

needs to be addressed? [See Defficiency Narritive for Specific Rule Violated]	affiliation who relinquished the samples were not included on the August 16, 2021 laboratory chain of custody. QA Rule 62-160
	Corrective Action(s): (Narrative) Update the lab chain of custody and DMR standard operating procedure to include the facility permit number, plant staffing, preservation type, sample receipt temperature and person's facility affiliation as noted in the deficiency above.

Photo Log

Date: 12/21/2021

Facility Name: Dolomite, Inc

Facility Location: 1321 Highway 71, Marianna FL 32448

Facility ID: FL0101192


Camera Used: Fuji Film XP, Serial Number: 7TC10689

Photographer: Larry Couch, Nina Zimmermann

Department Representatives Present: Larry Couch, Nina Zimmermann

Facility Representatives Present: David Thompson

Photo #1:



Description Photo #1:

Flow rate chart

Photo #2:



Description Photo #2: Main pond with dredger

Photo #3:



Description Photo #3: Outfall and signage

Photo #4:



Description Photo #4: Outfall and Chipola River
Photo #5:



Description Photo #5: Pond upstream from outfall with curtain

Biological Analysis Report

NW-DIST-2022-01-24-01

Florida Department of Environmental Protection
Central Laboratory
2600 Blair Stone Road
Tallahassee, FL 32399-2400
DOH Accreditation E31780

Overflow Analyses Performed By:
Eurofins TestAmerica Tampa
6712 Benjamin Road, Suite 100
Tampa, FL 33634

DOH Accreditation E84282

Event Description: **Northwest District: CSIs for FL0101192 Dolomite, Inc**
Request ID: **RQ-2021-11-15-15**
Customer: **NW-DIST**
Project ID: **CSI**

Send Reports to:
FL Dept. of Environmental Protection
160 Government Center
Suite 308
Pensacola, FL 32502-5794
Attn: Krista McGraw

For additional information please contact
Cheryl Swanson - Administrator
Sarah Menz, Ph.D. - Bench Biology & Aquatic
Toxicity
Puja Jasrotia, Ph.D. - Molecular Biology & Taxonomy
Thekkekalathil Chandrasekhar, Ph.D, QA Officer
Phone (850) 245-8177

Certified by: Sarah Menz, Environmental Administrator

Date Certified: 15-FEB-2022 09:59

A handwritten signature in black ink, appearing to be 'Sarah Menz', written in a cursive style.

Case Narrative

Unless otherwise noted, all samples included in this report were received in accordance with protocols referenced in Chapter 62-160, Florida Administrative Code (F.A.C.). Results published in this report pertain only to the samples as submitted to, and received by the laboratory. All times in this report are adjusted to the applicable Eastern Time Zone (EST or EDT).

Results for the following analytical groups are included in this report: Microbiology and Overflow.

Scientific notation may be used in reporting very large or small values. Values reported using scientific notation will take the form of the following example: 1.3E+03, which is equivalent to 1.3×10^3 or 1300.

Unless otherwise noted, analytical values for soil and sediment samples are reported on a dry weight basis, and analytical values for waste and tissue samples are reported on a wet weight basis.

Results for TNI accredited tests met requirements established by The NELAC Institute. A double asterisk (**) is used to indicate an analyte/matrix/method for which the laboratory is not TNI accredited by the Florida Department of Health Environmental Laboratory Certification Program or where accreditation for that field of testing is not applicable.

Any significant anomalies or deviations from established protocols are documented in Non-Conformance Reports, which, where appropriate, are included within this analytical report. Additional comments related to specific analytical tests may be included as remarks following the analytical results for each sample. Such comments and remarks are for informational purposes only and are not intended to convey judgement about the usability of the reported data.

A quality control report on the performance of the test method for the submitted samples is included. Uncertainty associated with the analytical results contained in this report can be estimated from the reported quality assurance results and from published quality control acceptance limits for each analytical test. Matrix quality control results (matrix spike recoveries and matrix sample precision) pertain only to the matrix sample tested and do not necessarily reflect test method performance for other samples.

Typical matrix quality control (QC) measurements may include matrix spike recovery, matrix spike duplicate recovery, matrix spike precision and matrix sample precision. Not all matrix QC results may be available or reportable; where they are not an explanation is provided. Typical reasons for unavailable QC results include, but are not limited to, a) insufficient matrix sample to perform some or all QC measurements; b) analyte concentration in the sample replicated was too low for a meaningful measurement of precision and c) analyte concentration in the matrix sample spiked was too high (relative to the amount of analyte spiked) for a meaningful measurement of recovery. Where matrix QC results are unavailable, other method performance metrics (e.g., LCS recovery, LCS precision, surrogate recovery) may be used to assess performance of the method. Comments explaining any missing QC measurements are not intended to convey any adverse conclusions about the quality of the reported data.

Precision is reported as relative percent difference unless otherwise noted.

Quality Control codes as defined below may be used in this report to indicate results that are associated with one or more quality control elements which did not fall within established test method criteria. Such results may be qualified as estimates using a J qualifier as required by 62-160 F.A.C. Explanations are included in the report for any results that were reported as estimates for other reasons.

QC Codes used in this report may include:

- LCS – Recovery for the batch Laboratory Control Sample (LCS) was outside existing control limits;
- MS – Recovery for the batch matrix spike (MS) was outside existing control limits;
- CCV – Recovery for a continuing calibration verification (CCV) standard was outside existing control limits;
- SUR – Recovery of a surrogate (SUR) for associated analytes was outside existing control limits;
- RPD – The precision, measured as relative percent difference (RPD), of batch replicate measurements was outside existing control limits;
- RSD – The precision, measured as relative standard deviation (RSD), of batch replicate measurements was outside existing control limits;
- SMP – Sample - used precision derived from replicate analyses of a sample;

The following data qualifiers are used, where applicable, in this report as specified in 62-160 F.A.C.

- A - Value reported is the mean of two or more determinations.
- B - Results based on colony counts outside the acceptable range.
- I - The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
- J - Estimated value and/or the analysis did not meet established quality control criteria.
- K - Actual value is known to be less than value given.
- L - Actual value is known to be greater than value given.
- N - Presumptive evidence of presence of material.
- O - Sampled, but analysis lost or not performed.
- Q - Sample held beyond normal holding time.
- T - Value reported is less than the criterion of detection.
- U - Material was analyzed for but not detected. The reported value is the method detection limit for the sample analyzed.
- V - Analyte was detected in both sample and method blank.
- X - Too few individuals to calculate SCI value.
- Y - The laboratory analysis was from an unpreserved or improperly preserved sample. The data may not be accurate.
- Z - Colonies were too numerous to count (TNTC).

Quality control information from overflow laboratories may not be included in this report. Please refer to the associated report from the overflow laboratory for additional information.

Sample Location: Dolomite Inc. (Sand Mine)

Collection Date/Time: 01/24/2022 09:45

Field ID: Discharge Point D-001 Grab

Matrix: W-SURF-FRH

Sample ID	Ref. Method	Component	Result	Code	Units	Batch ID	QC Codes
2301237	SM 9223 B Quanti-Tray	Escherichia Coli-Quanti-Tray	42.0		MPN/100 mL	P409025	
2301238	SM 9222 D	Fecal Coliforms-Membrane Filter	50		cfu/100 mL	P408972	
2301239	SM 5210 B	Carbonaceous Biochemical Oxygen Demand	2.0	U	mg/L		

Ref. Method and Comment:

SM 9222 D: Laboratory duplicate result is 30 B. Precision data for this duplicate is unavailable due to the colony count falling outside of method acceptable range.

SM 5210 B: Sample received at Eurofins TestAmerica on 01/25/22 at 09:10.

Quality Assurance Report Method Blank Results

Reference Method: SM 9222 D

Batch ID: P408972

Component	Result	Code	Units
Fecal Coliforms-Membrane Filter	2	U	cfu/100 mL

Reference Method: SM 9223 B Quanti-Tray

Batch ID: P409025

Component	Result	Code	Units
Escherichia Coli-Quanti-Tray	1.0	U	MPN/100 mL

Quality Assurance Report Precision

Reference Method: SM 9223 B Quanti-Tray

Batch ID: P409025

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2301312	Escherichia Coli-Quanti-Tray	11.4	Sample	P	0 - 80

* Sample, spike and/or laboratory control sample precision (LCS) is reported.

Quality Assurance Report Summary

Ref. Method	Analyte	LCS % Recovery	MS % Recovery	LCS	Precision SMP	MS
SM 9223 B Quanti-Tray	Escherichia Coli-Quanti-Tray				11.4	

Reference Method Descriptions

Method	Description	Associated Samples
SM 5210 B	BOD, nitrogen-inhibited (CBOD) at Eurofins Testamerica-Tampa	2301239
SM 9222 D	Fecal coliforms by membrane filter method - non-chlorinated water systems	2301238
SM 9223 B Quanti-Tray	Escherichia coli by Colilert 18 Quanti-Tray method - non-chlorinated water systems	2301237

Preparation and Analysis Log

Ref. Method	Received Date	Prep Date/Time	Prepared By	Analysis Date/Time	Analyzed By	Associated Samples
SM 5210 B	01/24/2022			01/26/2022 06:47	TestAmerica-Tampa	2301239
SM 9222 D	01/24/2022	01/24/2022 16:11	Jillian G Hanley	01/25/2022 15:00	Jillian G Hanley	2301238
SM 9223 B Quanti-Tray	01/24/2022	01/24/2022 17:14	Caitlyn Owens	01/25/2022 12:57	Tynan A Branch	2301237

Chemical Analysis Report

NW-DIST-2022-01-24-01

Florida Department of Environmental Protection
Central Laboratory
2600 Blair Stone Road
Tallahassee, FL 32399-2400
DOH Accreditation E31780


Event Description: **Northwest District: CSIs for FL0101192 Dolomite, Inc**
Request ID: **RQ-2021-11-15-15**
Customer: **NW-DIST**
Project ID: **CSI**

Send Reports to:
FL Dept. of Environmental Protection
160 Government Center
Suite 308
Pensacola, FL 32502-5794
Attn: Krista McGraw

For additional information please contact
Colin Wright, Ph.D.
Liang-Tsair Lin, Ph.D.
Kerry Tate, Ph.D.
Dr. rer. nat. Bettina Steinbock
Thekkekalathil Chandrasekhar, Ph.D, QA Officer
Phone (850) 245-8085

Certified by: Kerry Tate, Ph.D., Environmental Administrator

Date Certified: 11-FEB-2022 11:33

A handwritten signature in black ink that reads "Kerry Tate". The signature is written in a cursive, flowing style with a horizontal line above the first name.

Case Narrative

Unless otherwise noted, all samples included in this report were received in accordance with protocols referenced in Chapter 62-160, Florida Administrative Code (F.A.C.). Results published in this report pertain only to the samples as submitted to, and received by the laboratory. All times in this report are adjusted to the applicable Eastern Time Zone (EST or EDT).

Results for the following analytical groups are included in this report: Metals and Nutrients.

Scientific notation may be used in reporting very large or small values. Values reported using scientific notation will take the form of the following example: 1.3E+03, which is equivalent to 1.3×10^3 or 1300.

Unless otherwise noted, analytical values for soil and sediment samples are reported on a dry weight basis, and analytical values for waste and tissue samples are reported on a wet weight basis.

Results for TNI accredited tests met requirements established by The NELAC Institute. A double asterisk (**) is used to indicate an analyte/matrix/method for which the laboratory is not TNI accredited by the Florida Department of Health Environmental Laboratory Certification Program or where accreditation for that field of testing is not applicable.

Any significant anomalies or deviations from established protocols are documented in Non-Conformance Reports, which, where appropriate, are included within this analytical report. Additional comments related to specific analytical tests may be included as remarks following the analytical results for each sample. Such comments and remarks are for informational purposes only and are not intended to convey judgement about the usability of the reported data.

A quality control report on the performance of the test method for the submitted samples is included. Uncertainty associated with the analytical results contained in this report can be estimated from the reported quality assurance results and from published quality control acceptance limits for each analytical test. Matrix quality control results (matrix spike recoveries and matrix sample precision) pertain only to the matrix sample tested and do not necessarily reflect test method performance for other samples.

Typical matrix quality control (QC) measurements may include matrix spike recovery, matrix spike duplicate recovery, matrix spike precision and matrix sample precision. Not all matrix QC results may be available or reportable; where they are not an explanation is provided. Typical reasons for unavailable QC results include, but are not limited to, a) insufficient matrix sample to perform some or all QC measurements; b) analyte concentration in the sample replicated was too low for a meaningful measurement of precision and c) analyte concentration in the matrix sample spiked was too high (relative to the amount of analyte spiked) for a meaningful measurement of recovery. Where matrix QC results are unavailable, other method performance metrics (e.g., LCS recovery, LCS precision, surrogate recovery) may be used to assess performance of the method. Comments explaining any missing QC measurements are not intended to convey any adverse conclusions about the quality of the reported data.

Precision is reported as relative percent difference unless otherwise noted.

Quality Control codes as defined below may be used in this report to indicate results that are associated with one or more quality control elements which did not fall within established test method criteria. Such results may be qualified as estimates using a J qualifier as required by 62-160 F.A.C. Explanations are included in the report for any results that were reported as estimates for other reasons.

QC Codes used in this report may include:

- LCS – Recovery for the batch Laboratory Control Sample (LCS) was outside existing control limits;
- MS – Recovery for the batch matrix spike (MS) was outside existing control limits;
- CCV – Recovery for a continuing calibration verification (CCV) standard was outside existing control limits;
- SUR – Recovery of a surrogate (SUR) for associated analytes was outside existing control limits;
- RPD – The precision, measured as relative percent difference (RPD), of batch replicate measurements was outside existing control limits;
- RSD – The precision, measured as relative standard deviation (RSD), of batch replicate measurements was outside existing control limits;
- SMP – Sample - used precision derived from replicate analyses of a sample;

The following data qualifiers are used, where applicable, in this report as specified in 62-160 F.A.C.

- A - Value reported is the mean of two or more determinations.
- B - Results based on colony counts outside the acceptable range.
- I - The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
- J - Estimated value and/or the analysis did not meet established quality control criteria.
- K - Actual value is known to be less than value given.
- L - Actual value is known to be greater than value given.
- N - Presumptive evidence of presence of material.
- O - Sampled, but analysis lost or not performed.
- Q - Sample held beyond normal holding time.
- T - Value reported is less than the criterion of detection.
- U - Material was analyzed for but not detected. The reported value is the method detection limit for the sample analyzed.
- V - Analyte was detected in both sample and method blank.
- X - Too few individuals to calculate SCI value.
- Y - The laboratory analysis was from an unpreserved or improperly preserved sample. The data may not be accurate.
- Z - Colonies were too numerous to count (TNTC).

Quality control information from overflow laboratories may not be included in this report. Please refer to the associated report from the overflow laboratory for additional information.

Sample Location: Dolomite Inc. (Sand Mine)

Collection Date/Time: 01/24/2022 09:45

Field ID: Discharge Point D-001 Grab

Matrix: W-SURF-FRH

Sample ID	Ref. Method	Component	Result	Code	Units	Batch ID	QC Codes
2301240	EPA 180.1 Rev. 2.0	Turbidity	11		NTU	P408925	
	SM 2540 D-2011	TSS	8	I	mg/L	P409495	
2301241	EPA 350.1 Rev. 2.0	Ammonia-N	0.13		mg N/L	P409348	
	EPA 351.2 Rev. 2.0	Kjeldahl Nitrogen	0.38		mg N/L	P409134	
	EPA 353.2 Rev. 2.0	NO2NO3-N	0.52		mg N/L	P408988	
	EPA 365.1 Rev. 2.0	Total-P	0.025		mg P/L	P408931	
	SM 5310 B-2011	Organic Carbon	3.3		mg C/L	P409214	
	EPA 200.7 Rev. 4.4	Calcium	37.2		mg/L	P408891	
2301244	EPA 200.8 Rev. 5.4	Iron	210		ug/L	P408891	
		Magnesium	7.22		mg/L	P408891	
		Potassium	1.1	I	mg/L	P408891	
		Sodium	8.8		mg/L	P408891	
		Zinc	5.0	U	ug/L	P408891	
		Aluminum	189		ug/L	P408891	
		Arsenic	1.21		ug/L	P408891	
		Cadmium	0.029	I	ug/L	P408891	
		Chromium	0.59	I	ug/L	P408891	
		Copper	0.40	U	ug/L	P408891	
		Lead	0.20	U	ug/L	P408891	
		Nickel	1.9	I	ug/L	P408891	
		Selenium	0.37	I	ug/L	P408891	
		Silver	0.010	U	ug/L	P408891	

Ref. Method and Comment:

SM 2540 D-2011: Batch relative percent difference is unavailable because of low analyte concentration in the QC sample.

Sample Location: Dolomite Inc.

Collection Date/Time: 01/24/2022 10:00

Field ID: Field Blank

Matrix: W-FIELD-BK

Sample ID	Ref. Method	Component	Result	Code	Units	Batch ID	QC Codes
2301242	EPA 180.1 Rev. 2.0	Turbidity	0.10	U	NTU	P408925	
2301243	EPA 350.1 Rev. 2.0	Ammonia-N	0.002	U	mg N/L	P409348	
	EPA 351.2 Rev. 2.0	Kjeldahl Nitrogen	0.080	U	mg N/L	P409135	
	EPA 353.2 Rev. 2.0	NO2NO3-N	0.004	U	mg N/L	P408988	
	EPA 365.1 Rev. 2.0	Total-P	0.002	U	mg P/L	P408931	
	SM 5310 B-2011	Organic Carbon	1.2		mg C/L	P409214	
2301245	EPA 200.7 Rev. 4.4	Calcium	0.075	U	mg/L	P408891	
		Iron	30	U	ug/L	P408891	
		Magnesium	0.040	U	mg/L	P408891	
		Potassium	0.30	U	mg/L	P408891	
		Sodium	0.50	U	mg/L	P408891	
		Zinc	5.0	U	ug/L	P408891	
	EPA 200.8 Rev. 5.4	Aluminum	5.0	U	ug/L	P408891	
		Arsenic	0.050	U	ug/L	P408891	
		Cadmium	0.020	U	ug/L	P408891	
		Chromium	0.40	U	ug/L	P408891	
		Copper	0.40	U	ug/L	P408891	
		Lead	0.20	U	ug/L	P408891	
		Nickel	0.50	U	ug/L	P408891	
		Selenium	0.20	U	ug/L	P408891	
		Silver	0.010	U	ug/L	P408891	

Ref. Method and Comment:
SM 5310 B-2011: The result was confirmed on 02/04/2022.

Quality Assurance Report

Method Blank Results

Reference Method: EPA 180.1 Rev. 2.0
Batch ID: P408925

Component	Result	Code	Units
Turbidity	0.10	U	NTU

Reference Method: EPA 200.7 Rev. 4.4
Batch ID: P408891

Component	Result	Code	Units
Calcium	0.075	U	mg/L
Iron	30	U	ug/L
Magnesium	0.040	U	mg/L
Potassium	0.30	U	mg/L
Sodium	0.50	U	mg/L
Zinc	5.0	U	ug/L

Reference Method: EPA 200.8 Rev. 5.4
Batch ID: P408891

Component	Result	Code	Units
Aluminum	5.0	U	ug/L
Arsenic	0.050	U	ug/L
Cadmium	0.020	U	ug/L
Chromium	0.40	U	ug/L
Copper	0.40	U	ug/L
Lead	0.20	U	ug/L
Nickel	0.50	U	ug/L
Selenium	0.20	U	ug/L
Silver	0.010	U	ug/L

Reference Method: EPA 350.1 Rev. 2.0
Batch ID: P409348

Component	Result	Code	Units
Ammonia-N	0.002	U	mg N/L

Reference Method: EPA 351.2 Rev. 2.0
Batch ID: P409134

Component	Result	Code	Units
Kjeldahl Nitrogen	0.080	U	mg N/L

Reference Method: EPA 351.2 Rev. 2.0
Batch ID: P409135

Component	Result	Code	Units
Kjeldahl Nitrogen	0.080	U	mg N/L

Reference Method: EPA 353.2 Rev. 2.0
Batch ID: P408988

Component	Result	Code	Units
NO2NO3-N	0.004	U	mg N/L

Quality Assurance Report

Method Blank Results

Reference Method: EPA 365.1 Rev. 2.0
Batch ID: P408931

Component	Result	Code	Units
Total-P	0.002	U	mg P/L

Reference Method: SM 2540 D-2011
Batch ID: P409495

Component	Result	Code	Units
TSS	2	U	mg/L

Reference Method: SM 5310 B-2011
Batch ID: P409214

Component	Result	Code	Units
Organic Carbon	0.50	U	mg C/L

Quality Assurance Report Laboratory Control Sample Accuracy

Reference Method: EPA 200.7 Rev. 4.4
Batch ID: P408891

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Calcium	102		P	85 - 115
Iron	111		P	85 - 115
Magnesium	103		P	85 - 115
Potassium	105		P	85 - 115
Sodium	101		P	85 - 115
Zinc	98.2		P	85 - 115

Reference Method: EPA 200.8 Rev. 5.4
Batch ID: P408891

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Aluminum	101		P	85 - 115
Arsenic	101		P	85 - 115
Cadmium	100		P	85 - 115
Chromium	99.2		P	85 - 115
Copper	99.0		P	85 - 115
Lead	98.3		P	85 - 115
Nickel	100		P	85 - 115
Selenium	99.9		P	85 - 115
Silver	101		P	85 - 115

Reference Method: EPA 350.1 Rev. 2.0
Batch ID: P409348

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Ammonia-N	98.6		P	90 - 110

Reference Method: EPA 351.2 Rev. 2.0
Batch ID: P409134

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Kjeldahl Nitrogen	102		P	90 - 110

Reference Method: EPA 351.2 Rev. 2.0
Batch ID: P409135

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Kjeldahl Nitrogen	94.2		P	90 - 110

Reference Method: EPA 353.2 Rev. 2.0
Batch ID: P408988

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
NO2NO3-N	104		P	90 - 110

Reference Method: EPA 365.1 Rev. 2.0
Batch ID: P408931

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Total-P	102		P	90 - 110

Quality Assurance Report

Laboratory Control Sample Accuracy

Reference Method: SM 5310 B-2011
Batch ID: P409214

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Organic Carbon	94.6		P	85 - 115

Quality Assurance Report Matrix Spike Accuracy

Reference Method: EPA 200.7 Rev. 4.4

Batch ID: P408891

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2301004	Calcium	98.6		P	80 - 120
2301004	Iron	108	109	P/P	80 - 120
2301004	Magnesium	101		P	80 - 120
2301004	Potassium	100	101	P/P	80 - 120
2301004	Sodium	99.7		P	80 - 120
2301004	Zinc	96.7	98.5	P/P	80 - 120
2301328	Calcium	107		P	80 - 120
2301328	Iron	112		P	80 - 120
2301328	Magnesium	111		P	80 - 120
2301328	Potassium	103		P	80 - 120
2301328	Sodium	106		P	80 - 120
2301328	Zinc	105		P	80 - 120

Reference Method: EPA 200.8 Rev. 5.4

Batch ID: P408891

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2301004	Aluminum	98.2	97.5	P/P	80 - 120
2301004	Arsenic	101	99.8	P/P	80 - 120
2301004	Cadmium	103	103	P/P	80 - 120
2301004	Chromium	102	102	P/P	80 - 120
2301004	Copper	96.4	95.8	P/P	80 - 120
2301004	Lead	98.9	99.0	P/P	80 - 120
2301004	Nickel	96.5	95.9	P/P	80 - 120
2301004	Selenium	98.1	98.6	P/P	80 - 120
2301004	Silver	99.1	98.8	P/P	80 - 120
2301328	Aluminum	91.6		P	80 - 120
2301328	Arsenic	96.4		P	80 - 120
2301328	Cadmium	94.6		P	80 - 120
2301328	Chromium	98.1		P	80 - 120
2301328	Copper	98.3		P	80 - 120
2301328	Lead	94.7		P	80 - 120
2301328	Nickel	98.4		P	80 - 120
2301328	Selenium	95.1		P	80 - 120
2301328	Silver	97.4		P	80 - 120

Reference Method: EPA 350.1 Rev. 2.0

Batch ID: P409348

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2301249	Ammonia-N	98.0	99.6	P/P	90 - 110

Reference Method: EPA 351.2 Rev. 2.0

Batch ID: P409134

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2301108	Kjeldahl Nitrogen	103	108	P/P	90 - 110

Reference Method: EPA 351.2 Rev. 2.0

Batch ID: P409135

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
---------------	-----------	---------	---------	-----------	----------------

Quality Assurance Report Matrix Spike Accuracy

Reference Method: EPA 351.2 Rev. 2.0
Batch ID: P409135

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2301347	Kjeldahl Nitrogen	104	108	P/P	90 - 110

Reference Method: EPA 353.2 Rev. 2.0
Batch ID: P408988

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2301209	NO2NO3-N	102	103	P/P	90 - 110

Reference Method: EPA 365.1 Rev. 2.0
Batch ID: P408931

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2301290	Total-P	105	103	P/P	90 - 110

Reference Method: SM 5310 B-2011
Batch ID: P409214

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2301038	Organic Carbon	94.6	94.8	P/P	85 - 115

Quality Assurance Report Precision

Reference Method: EPA 180.1 Rev. 2.0
Batch ID: P408925

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2301248	Turbidity	1.65	Sample	P	0 - 20

Reference Method: EPA 200.7 Rev. 4.4
Batch ID: P408891

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2301004	Calcium	0.824	Spike	P	0 - 20
2301004	Iron	0.613	Spike	P	0 - 20
2301004	Magnesium	0.190	Spike	P	0 - 20
2301004	Potassium	0.320	Spike	P	0 - 20
2301004	Sodium	0.774	Spike	P	0 - 20
2301004	Zinc	1.90	Spike	P	0 - 20

Reference Method: EPA 200.8 Rev. 5.4
Batch ID: P408891

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2301004	Aluminum	0.703	Spike	P	0 - 20
2301004	Arsenic	1.01	Spike	P	0 - 20
2301004	Cadmium	0.210	Spike	P	0 - 20
2301004	Chromium	0.288	Spike	P	0 - 20
2301004	Copper	0.664	Spike	P	0 - 20
2301004	Lead	0.0709	Spike	P	0 - 20
2301004	Nickel	0.590	Spike	P	0 - 20
2301004	Selenium	0.427	Spike	P	0 - 20
2301004	Silver	0.233	Spike	P	0 - 20

Reference Method: EPA 350.1 Rev. 2.0
Batch ID: P409348

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2301249	Ammonia-N	1.37	Spike	P	0 - 20

Reference Method: EPA 351.2 Rev. 2.0
Batch ID: P409134

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2301108	Kjeldahl Nitrogen	3.90	Spike	P	0 - 20

Reference Method: EPA 351.2 Rev. 2.0
Batch ID: P409135

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2301347	Kjeldahl Nitrogen	3.08	Spike	P	0 - 20

Quality Assurance Report Precision

Reference Method: EPA 353.2 Rev. 2.0
Batch ID: P408988

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2301209	NO2NO3-N	0.434	Spike	P	0 - 20

Reference Method: EPA 365.1 Rev. 2.0
Batch ID: P408931

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2301290	Total-P	2.01	Spike	P	0 - 20

Reference Method: SM 5310 B-2011
Batch ID: P409214

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2301038	Organic Carbon	0.203	Spike	P	0 - 20

* Sample, spike and/or laboratory control sample precision (LCS) is reported.

Quality Assurance Report Calibration Verification

Reference Method: EPA 180.1 Rev. 2.0

Run ID: A110034

Included Lab Sample IDs: 2301240, 2301242

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Turbidity	99.5	98.5	P/P	95 - 105

Reference Method: EPA 353.2 Rev. 2.0

Run ID: A110050

Included Lab Sample IDs: 2301241, 2301243

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
NO2NO3-N	104	104	P/P	90 - 110

Reference Method: EPA 200.8 Rev. 5.4

Run ID: A110059

Included Lab Sample IDs: 2301244, 2301245

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Aluminum	98.0	98.3	P/P	90 - 110
Aluminum	98.3	97.9	P/P	90 - 110
Arsenic	99.0	96.4	P/P	90 - 110
Arsenic	99.5	99.0	P/P	90 - 110
Cadmium	98.3	98.9	P/P	90 - 110
Cadmium	98.9	99.8	P/P	90 - 110
Chromium	95.8	97.0	P/P	90 - 110
Chromium	97.0	96.7	P/P	90 - 110
Copper	96.6	96.7	P/P	90 - 110
Copper	96.7	92.1	P/P	90 - 110
Lead	93.6	93.4	P/P	90 - 110
Lead	94.0	93.6	P/P	90 - 110
Nickel	96.8	97.7	P/P	90 - 110
Nickel	97.7	92.4	P/P	90 - 110
Selenium	98.0	98.0	P/P	90 - 110
Selenium	98.5	98.0	P/P	90 - 110
Silver	99.4	99.5	P/P	90 - 110
Silver	99.9	99.4	P/P	90 - 110

Reference Method: EPA 200.7 Rev. 4.4

Run ID: A110065

Included Lab Sample IDs: 2301244, 2301245

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Calcium	102	99.1	P/P	90 - 110
Calcium	103	99.5	P/P	90 - 110
Iron	105	102	P/P	90 - 110
Iron	106	102	P/P	90 - 110
Magnesium	103	100	P/P	90 - 110
Magnesium	104	101	P/P	90 - 110
Potassium	98.7	97.3	P/P	90 - 110
Potassium	99.9	95.6	P/P	90 - 110
Sodium	100	99.3	P/P	90 - 110
Sodium	102	97.1	P/P	90 - 110
Zinc	96.9	94.8	P/P	90 - 110
Zinc	97.3	95.3	P/P	90 - 110

Quality Assurance Report Calibration Verification

Reference Method: EPA 365.1 Rev. 2.0

Run ID: A110109

Included Lab Sample IDs: 2301241, 2301243

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Total-P	101	104	P/P	90 - 110
Total-P	104	99.5	P/P	90 - 110

Reference Method: SM 5310 B-2011

Run ID: A110130

Included Lab Sample IDs: 2301241, 2301243

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Organic Carbon	97.7	97.5	P/P	90 - 110

Reference Method: EPA 351.2 Rev. 2.0

Run ID: A110164

Included Lab Sample IDs: 2301241

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Kjeldahl Nitrogen	95.7	94.3	P/P	90 - 110

Reference Method: EPA 350.1 Rev. 2.0

Run ID: A110182

Included Lab Sample IDs: 2301241, 2301243

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Ammonia-N	99.4	99.7	P/P	90 - 110

Reference Method: EPA 351.2 Rev. 2.0

Run ID: A110188

Included Lab Sample IDs: 2301243

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Kjeldahl Nitrogen	93.7	94.9	P/P	90 - 110

* Pass/Fail determinations are made for each bracketing calibration verification check.

Control limits for initial calibration checks may be different from those for continuing checks, depending on method requirements.

Where they are different, both control limits are provided.

Quality Assurance Report Summary

Ref. Method	Analyte	LCS % Recovery	MS % Recovery			LCS	Precision SMP	MS
EPA 180.1 Rev. 2.0	Turbidity						1.65	
EPA 200.7 Rev. 4.4	Calcium	102	98.6	107				0.824
	Iron	111	108	109	112			0.613
	Magnesium	103	101	111				0.190
	Potassium	105	100	101	103			0.320
	Sodium	101	99.7	106				0.774
	Zinc	98.2	96.7	98.5	105			1.90
EPA 200.8 Rev. 5.4	Aluminum	101	91.6	98.2	97.5			0.703
	Arsenic	101	96.4	101	99.8			1.01
	Cadmium	100	94.6	103	103			0.210
	Chromium	99.2	98.1	102	102			0.288
	Copper	99.0	98.3	96.4	95.8			0.664
	Lead	98.3	94.7	98.9	99.0			0.0709
	Nickel	100	98.4	96.5	95.9			0.590
	Selenium	99.9	95.1	98.1	98.6			0.427
	Silver	101	97.4	99.1	98.8			0.233
EPA 350.1 Rev. 2.0	Ammonia-N	98.6	98.0	99.6				1.37
EPA 351.2 Rev. 2.0	Kjeldahl Nitrogen	102	103	108				3.90
	Kjeldahl Nitrogen	94.2	104	108				3.08
EPA 353.2 Rev. 2.0	NO ₂ NO ₃ -N	104	102	103				0.434
EPA 365.1 Rev. 2.0	Total-P	102	105	103				2.01
SM 5310 B-2011	Organic Carbon	94.6	94.6	94.8				0.203

Reference Method Descriptions

Method	Description	Associated Samples
EPA 180.1 Rev. 2.0	Turbidity in aqueous matrices	2301240, 2301242
EPA 200.7 Rev. 4.4	Total Recoverable Metals analysis using ICP emission spectroscopy for aqueous samples supporting Clean Water Act Projects	2301244, 2301245
EPA 200.8 Rev. 5.4	Total Recoverable Metals analysis using ICP-MS for aqueous samples supporting Clean Water Act Projects	2301244, 2301245
EPA 350.1 Rev. 2.0	Ammonia in aqueous matrices as mg N/L	2301241, 2301243
EPA 351.2 Rev. 2.0	Total Kjeldahl Nitrogen in aqueous matrices	2301241, 2301243
EPA 353.2 Rev. 2.0	Nitrite/Nitrate in aqueous matrices as mg N/L	2301241, 2301243
EPA 365.1 Rev. 2.0	Total Phosphorus in aqueous matrices as mg P/L	2301241, 2301243
SM 2540 D-2011	Total Suspended Solids in aqueous matrices using a maximum of 250 mL of sample	2301240
SM 5310 B-2011	Nonpurgeable Organic Carbon in aqueous matrices	2301241, 2301243

Preparation and Analysis Log

Ref. Method	Received Date	Prep Date/Time	Prepared By	Analysis Date/Time	Analyzed By	Associated Samples
EPA 180.1 Rev. 2.0	01/24/2022			01/25/2022 15:03	Khloe J Berg	2301240, 2301242
EPA 200.7 Rev. 4.4	01/24/2022	01/25/2022 11:15	Emily M Philpot	01/26/2022 19:54	Josef B Mick	2301245
	01/24/2022	01/25/2022 11:15	Emily M Philpot	01/26/2022 22:49	Josef B Mick	2301244
EPA 200.8 Rev. 5.4	01/24/2022	01/25/2022 11:15	Emily M Philpot	01/26/2022 12:32	Alexander Thompson	2301245
	01/24/2022	01/25/2022 11:15	Emily M Philpot	01/26/2022 14:55	Alexander Thompson	2301244
EPA 350.1 Rev. 2.0	01/24/2022			02/02/2022 13:24	Ping Hua	2301241
	01/24/2022			02/02/2022 13:30	Ping Hua	2301243
EPA 351.2 Rev. 2.0	01/24/2022	01/31/2022 10:51	Samantha L Bates	02/01/2022 17:12	Virginia P. Brown	2301241
	01/24/2022	01/31/2022 10:51	Samantha L Bates	02/02/2022 12:16	Alexandra J Mattheus	2301243
EPA 353.2 Rev. 2.0	01/24/2022			01/26/2022 10:19	Beverly Y. Sanders	2301241
	01/24/2022			01/26/2022 10:33	Beverly Y. Sanders	2301243
EPA 365.1 Rev. 2.0	01/24/2022	01/26/2022 17:15	Simonne.V. Calhoun	01/28/2022 15:12	Shengyu Ding	2301243
	01/24/2022	01/26/2022 17:15	Simonne.V. Calhoun	01/28/2022 15:22	Shengyu Ding	2301241
SM 2540 D-2011	01/24/2022			01/28/2022 14:02	Yijie Li	2301240
SM 5310 B-2011	01/24/2022			01/29/2022 00:28	Nathaniel J Jones	2301241
	01/24/2022			01/29/2022 00:37	Nathaniel J Jones	2301243

ANALYTICAL REPORT

Eurofins Tampa
6712 Benjamin Road
Suite 100
Tampa, FL 33634
Tel: (813)885-7427

Laboratory Job ID: 660-117096-1
Client Project/Site: OV303

For:
DEP-Chemistry Section
2600 Blirstone Road
Tallahassee, Florida 32399-2400

Attn: Ms. Kathleen Lurding



Authorized for release by:
1/31/2022 3:21:38 PM

Noel Savoie, Project Manager I
(850)254-0107
Noel.Savoie@Eurofinset.com

LINKS

Review your project
results through
TotalAccess

Have a Question?



Visit us at:

www.eurofinsus.com/Env

The test results in this report meet all 2003 NELAC, 2009 TNI, and 2016 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

Table of Contents

Cover Page	1
Table of Contents	2
Sample Summary	3
Case Narrative	4
Definitions/Glossary	5
Detection Summary	6
Client Sample Results	7
QC Sample Results	8
QC Association Summary	9
Lab Chronicle	10
Method Summary	11
Certification Summary	12
Chain of Custody	13
Receipt Checklists	17



Sample Summary

Client: DEP-Chemistry Section
Project/Site: OV303

Job ID: 660-117096-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
660-117096-1	2301239	Water	01/24/22 08:45	01/25/22 09:10

1

2

3

4

5

6

7

8

9

10

11

12

13

14

Case Narrative

Client: DEP-Chemistry Section
Project/Site: OV303

Job ID: 660-117096-1

Job ID: 660-117096-1

Laboratory: Eurofins Tampa

Narrative

Job Narrative
660-117096-1

Comments

No additional comments.

Receipt

The sample was received on 1/25/2022 9:10 AM. Unless otherwise noted below, the sample arrived in good condition, and where required, properly preserved and on ice. The temperature of the cooler at receipt was 2.0° C.

General Chemistry

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

Definitions/Glossary

Client: DEP-Chemistry Section
Project/Site: OV303

Job ID: 660-117096-1

Qualifiers

General Chemistry

Qualifier	Qualifier Description
U	Indicates that the compound was analyzed for but not detected.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Detection Summary

Client: DEP-Chemistry Section
Project/Site: OV303

Job ID: 660-117096-1

Client Sample ID: 2301239

Lab Sample ID: 660-117096-1

No Detections.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

This Detection Summary does not include radiochemical test results.

Eurofins Tampa

Client Sample Results

Client: DEP-Chemistry Section
Project/Site: OV303

Job ID: 660-117096-1

Client Sample ID: 2301239

Lab Sample ID: 660-117096-1

Date Collected: 01/24/22 08:45

Matrix: Water

Date Received: 01/25/22 09:10

General Chemistry

Analyte	Result	Qualifier	PQL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Carbonaceous Biochemical Oxygen Demand	2.0	U	2.0	2.0	mg/L			01/26/22 06:47	1

QC Sample Results

Client: DEP-Chemistry Section
Project/Site: OV303

Job ID: 660-117096-1

Method: SM 5210B - CBOD

Lab Sample ID: SCB 660-248559/2

Matrix: Water

Analysis Batch: 248559

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	SCB Result	SCB Qualifier	PQL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Carbonaceous Biochemical Oxygen Demand	2.0	U	2.0	2.0	mg/L			01/26/22 06:47	1

Lab Sample ID: USB 660-248559/1

Matrix: Water

Analysis Batch: 248559

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	USB Result	USB Qualifier	PQL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Carbonaceous Biochemical Oxygen Demand	2.0	U	2.0	2.0	mg/L			01/26/22 06:47	1

Lab Sample ID: LCS 660-248559/3

Matrix: Water

Analysis Batch: 248559

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Carbonaceous Biochemical Oxygen Demand	198	199		mg/L		101	85 - 115

Lab Sample ID: 660-117096-1 DU

Matrix: Water

Analysis Batch: 248559

Client Sample ID: 2301239

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	RPD Limit
Carbonaceous Biochemical Oxygen Demand	2.0	U	2.0	U	mg/L		NC	20

QC Association Summary

Client: DEP-Chemistry Section
Project/Site: OV303

Job ID: 660-117096-1

General Chemistry

Analysis Batch: 248559

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
660-117096-1	2301239	Total/NA	Water	SM 5210B	
SCB 660-248559/2	Method Blank	Total/NA	Water	SM 5210B	
USB 660-248559/1	Method Blank	Total/NA	Water	SM 5210B	
LCS 660-248559/3	Lab Control Sample	Total/NA	Water	SM 5210B	
660-117096-1 DU	2301239	Total/NA	Water	SM 5210B	

Lab Chronicle

Client: DEP-Chemistry Section
Project/Site: OV303

Job ID: 660-117096-1

Client Sample ID: 2301239
Date Collected: 01/24/22 08:45
Date Received: 01/25/22 09:10

Lab Sample ID: 660-117096-1
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	SM 5210B		1	248559	01/26/22 06:47	AJG	TAL TAM

Laboratory References:
TAL TAM = Eurofins Tampa, 6712 Benjamin Road, Suite 100, Tampa, FL 33634, TEL (813)885-7427

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

Method Summary

Client: DEP-Chemistry Section
Project/Site: OV303

Job ID: 660-117096-1

Method	Method Description	Protocol	Laboratory
SM 5210B	CBOD	SM	TAL TAM

Protocol References:

SM = "Standard Methods For The Examination Of Water And Wastewater"

Laboratory References:

TAL TAM = Eurofins Tampa, 6712 Benjamin Road, Suite 100, Tampa, FL 33634, TEL (813)885-7427

Accreditation/Certification Summary

Client: DEP-Chemistry Section
Project/Site: OV303

Job ID: 660-117096-1

Laboratory: Eurofins Tampa

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Florida	NELAP	E84282	06-30-22
Georgia	State	E84282	06-30-22
USDA	US Federal Programs	P330-21-00025	10-18-24

**STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION
TASK ASSIGNMENT/NOTIFICATION FORM: LAB145**

Contract Manager: Linda Allen/Magan Bowden
2600 Blair Stone Rd., MS 6512
Tallahassee, FL 32399-2400

(850)-245-8084 / (850) 245-8095

Contractor: Eurofins/TestAmerica Laboratories, Inc
5102 LaRoche Ave
Savannah, GA 31404
ATTN: Noel Savoie

DEP Approval By: Linda S. Allen Contractor Approval By: Noel Savoie
Project Manager

Contractor Representatives Contacted: Noel Savoie

Date: 10/19/2021
Means of Contact: Email

Task Assignment Number: OV303 Maximum Cost: \$36.25 Turnaround Time: 5 BD

Sample Delivery Date: 11/30/2021

Project Name/Description:
RQ-2021-11-15-15;FL0101192 Dolomite

Deliverable Number/ Parameter Group/	Sample Matrix	# of Samples	# of Containers	DEP ID #	Unit Cost	% Mark- up (if any)	Cost
Method							
Quote/OV-CBOD-IN	W	1	1 bottle		\$33.75		\$33.75
CBOD, nitrogen-inhibited 5210B-2011							
217/Sample Disposal Fee:	1				\$2.50		\$2.50
Total Number of Containers Shipped:	1					Total:	\$36.25



660-117096 Chain of Custody

Loc: 660
117096

QC Instructions:

Comments: Quote #66015426 - 0

Samples released to Contract Lab by: Larry Couch Date/Time: 1/24/2022

Delivery Method: Shipping FEDEX

Samples Accepted by: [Signature] Date/Time 1/25/22 9:10

* Please sign and return by email to Linda.S.Allen@FloridaDEP.gov and Magan.Bowden@dep.state.fl.us

1.4/2.0 CU-09

Due to some unforeseen complications with performing in-house BODs, the BOD for this RQ has been changed to overflow analysis and will need to be shipped directly from the field to the TestAmerica – Tampa Office/laboratory.

We have prepared a small cooler for you to ship to TestAmerica.

Inside there will be:

- Pre-labeled overflow sampling container
- Extra Field sheets (please fill them out for TestAmerica)
- Shipping label (to TestAmerica)
- Task Assignment form (to be used by TestAmerica | Please Sign the highlighted portion)

QC Instructions:	
Comments: Quote #66015426 - 0	
Samples released to Contract Lab by: _____	Date/Time: _____
Delivery Method: _____	Shipping _____
Samples Accepted by: _____	Date/Time _____
• Please sign and return by email to Trenetta.L.Wilson@floridadep.gov and Mayan.Bowden@dep.state.fl.us	

- Return shipping labels (to be used by TestAmerica)

If you have any questions please give us a call at 850-245-8206.

Central Laboratory Submittal Form

Customer: NW-DIST

Requester: Elaine Ignacio

Field Report Prepared By:

Larry Couch

Project ID: CSI

Collected By:

Larry Couch

Sampling Agency:

FDEP

Location		Dolomite, Inc. (sand mine)		Comp		Collection (comp begin or grab)		Eastern		Composite end		Bottle Group(s)	
Field ID		Discharge Point D-001 Grab		Matrix (type, e.g., Salt, Fresh, etc)		Date 1/24/2022 Time 0845		Central		Date		Time	
WIN/STORET #				Temp (C)		pH		Diss. Oxygen		mg/L		Total Res. Chlorine (mg/L)	
Latitude		30° 38' 50.24" N		Longitude		85° 10' 35.32" W		Salinity (ppt)		ft		Sp. Conductance (umho/cm)	
Location				Comp		Collection (comp begin or grab)		Eastern		Composite end		Bottle Group(s)	
Field ID				Matrix (type, e.g., Salt, Fresh, etc)		Date		Central		Date		Time	
WIN/STORET #				Temp (C)		pH		Diss. Oxygen		mg/L		Total Res. Chlorine (mg/L)	
Latitude		dd dms		Longitude		dd dms		Salinity (ppt)		ft		Sp. Conductance (umho/cm)	
Location				Comp		Collection (comp begin or grab)		Eastern		Composite end		Bottle Group(s)	
Field ID				Matrix (type, e.g., Salt, Fresh, etc)		Date		Central		Date		Time	
WIN/STORET #				Temp (C)		pH		Diss. Oxygen		mg/L		Total Res. Chlorine (mg/L)	
Latitude		dd dms		Longitude		dd dms		Salinity (ppt)		ft		Sp. Conductance (umho/cm)	
Location				Comp		Collection (comp begin or grab)		Eastern		Composite end		Bottle Group(s)	
Field ID				Matrix (type, e.g., Salt, Fresh, etc)		Date		Central		Date		Time	
WIN/STORET #				Temp (C)		pH		Diss. Oxygen		mg/L		Total Res. Chlorine (mg/L)	
Latitude		dd dms		Longitude		dd dms		Salinity (ppt)		ft		Sp. Conductance (umho/cm)	
Location				Comp		Collection (comp begin or grab)		Eastern		Composite end		Bottle Group(s)	
Field ID				Matrix (type, e.g., Salt, Fresh, etc)		Date		Central		Date		Time	
WIN/STORET #				Temp (C)		pH		Diss. Oxygen		mg/L		Total Res. Chlorine (mg/L)	
Latitude		dd dms		Longitude		dd dms		Salinity (ppt)		ft		Sp. Conductance (umho/cm)	

Relinquished By:	Date/Time	Shipping Method	Number of Coolers Shipped:	Received By:	Date/Time
L. Couch	1/24/22	FedEx	1	HL	1.24.22 / 1235

REQUEST ID	EVENT ID	SAMPLE ID	FIELD ID	DATE SAMPLED	REFERENCE METHOD	COMPONENT	MATRIX	ANALYSIS
RQ-2021-11-15-15	NW-DIST-2022-01-24-01	2301239	Discharge Point D-001 Grab	1/24/2022 9:45 SM	5210 B	Carbonaceous Biochemical Oxygen Demand	W-SURF-FRH	OV-CBOD-IN

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

Login Sample Receipt Checklist

Client: DEP-Chemistry Section

Job Number: 660-117096-1

Login Number: 117096

List Number: 1

Creator: Arevalo, Maria L

List Source: Eurofins Tampa

Question	Answer	Comment
Radioactivity wasn't checked or is $\leq$ background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is $<6\text{mm}$ (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

Login Checklist

RQ- 2021-11-15-15

Login Station ID: #5

Shipping Method: FedEx | UPS | HD | Greyhound

Date/Time of Receipt: 1/ 24 /22 @ 12:35

*Cooler Temperature	Samples Frozen?	* All Samples in Cooler Preserved with		Number of Sample Containers in Cooler	Evidence Tape				Waybill Tracking #
					Present?		*Intact?		
	YES	HNO ₃	Formalin		Yes	No	Yes	No	
0.5				1		✓			
-0.3				8		✓			

COOLER CHECK

*All samples received on ice unless otherwise noted. HNO3 and Formalin preserved samples do NOT have a temperature requirement.

- If the temperature of a cooler exceeds 6.0 oC (above 10.0 oC for W-1-4-DIOX and microbiology) or received without ice, identify affected samples in an NCR. NCR# _____
- DOH coolers can exceed 2.0 °C above the standard temperature (6.0 or 10.0 °C for W-1-4-DIOX) without login confirmation from customer for samples requiring ice preservation; identify affected samples in an NCR. NCR# _____
- If cooler or samples are received with a damaged Evidence Seal; identify the affected samples in an NCR. NCR# _____
- If coolers or samples are received late; identify the affected samples in an NCR. NCR# _____

Chain of Custody/ Field Sheet(s) Included?

Yes ☒ No _____

Micro-Biology Overflow Chain of Custody/ Field Sheet(s) Included?

Yes _____ No ☒

CONTAINER CHECK

Evidence Tape on Bottles?

Yes _____ No _____ NA ☒

Evidence Tape intact? Yes _____ No _____

If Criminal, photographs taken?

Yes _____ No _____

Containers intact? Yes ☒ No _____

Caps on tight?

Yes ☒ No _____

Sufficient Sample Volume:

Yes ☒ No _____

If NO is checked above, generate an NCR listing affected sample IDs in its appropriate category. NCR# _____

CHLORINE CHECK REQUIRED? (Blue dot on container)

Yes _____ No ☒ Init: 16K

Chlorine detected? (One container checked per Field ID)

Yes _____ No _____ Init: _____

If chlorine is detected, generate an NCR listing affected sample IDs . NCR# _____

PRESERVATION CHECK (EXCLUDING SAMPLES SENT TO OVERFLOW LABS, "OV-")

**Acid Preserved Samples: pH< 2.0?

Yes ☒ No _____ NA _____ Init: IM

**W-1-4-DIOX (Green dot on container) preserved to pH<4.0?

Yes _____ No _____ NA ☒ Init: 16K

If samples were not preserved correctly, generate an NCR listing affected sample IDs . NCR# _____

Coolers Unpacked/Checked by: 16K/IM

Date: 1/ 24 /22

Event contains NCRs (Y/N)? N

Event ID Northwest District: CSIs for FL010119
NW-DIST-2022-01-24-01 (CSI)

Date Received: 24-JAN-2022 12:35

Login Checklist

Login Preservation Equipment

Lot # & Exp: Date

Additional Comments:

Infrared Thermometer ID:	IR TEMP GUN #5 EXP:10-19-22
pH Test Strips 0 – 6	Lot#210620 EXP:4-15-23
pH Paper 0 – 3	
pH Paper 0 – 13	Lot#210620 EXP:4-15-23
Chlorine Test Strips	Lot#0070 EXP:2-23

ENCORE SAMPLES

S-VOC-MS samples in Encores must be frozen within 48 hours of collection.

Were Encore samples received? Yes _____ Init: _____

Date and time placed in freezer _____

Were all samples placed in freezer within 48 hours of collection? Yes _____ No _____

If no, were samples shipped on dry ice? Yes _____ No _____

If S-VOC-MS samples were not preserved correctly, generate an NCR listing affected sample IDs . NCR# _____

FOR CLEAN LAB USE ONLY – Total Mercury Preservation Check(W-HG-AF;W-HG-AF-F):

Samples preserved within 48 hours? Yes _____ No _____

Date and time samples preserved: _____

Northwest District: CSIs for FL0101192 Dolomite, Inc

Central Laboratory Submittal Form

last revised Jan 25, 2018

Customer: NW-DIST

Requester: Elaine Ignacio

Field Report Prepared By:

Project ID: CSI

Collected By:

Sampling Agency:

Location Dolomite, Inc. (sand mine)		☐ Comp ☒ Grab	Collection (comp begin or grab) Date 1/24/2022 Time 0845		Eastern Central	Composite end Date Time		Bottle Group(s) (See pg 2) A
Field ID Discharge Point D-001 Grab		Matrix (type, e.g., Salt, Fresh, etc) Fresh		Diss. Oxygen ☐ mg/L ☐ % sat		Total Res. Chlorine (mg/L)		
WIN/STORET #		Temp (C)	pH	Sample Depth	☐ ft ☐ m	Sp. Conductance (umho/cm)		
Latitude 30°38'50.24" ☐ dd ☒ dms		Longitude 85°10'35.32" ☐ dd ☒ dms		Salinity (ppt)		Comments NPDES ID # FL0101192		
Location Dolomite, Inc.		☐ Comp ☒ Grab	Collection (comp begin or grab) Date 1/24/2022 Time 0900		Eastern Central	Composite end Date Time		Bottle Group(s) B
Field ID Field Blank		Matrix (type, e.g., Salt, Fresh, etc) Analyte Free H ₂ O		Diss. Oxygen ☐ mg/L ☐ % sat		Total Res. Chlorine (mg/L)		
WIN/STORET #		Temp (C)	pH	Sample Depth	☐ ft ☐ m	Sp. Conductance (umho/cm)		
Latitude ☐ dd ☐ dms		Longitude ☐ dd ☐ dms		Salinity (ppt)		Comments		
Location		☐ Comp ☐ Grab	Collection (comp begin or grab) Date Time		Eastern Central	Composite end Date Time		Bottle Group(s)
Field ID		Matrix (type, e.g., Salt, Fresh, etc)		Diss. Oxygen ☐ mg/L ☐ % sat		Total Res. Chlorine (mg/L)		
WIN/STORET #		Temp (C)	pH	Sample Depth	☐ ft ☐ m	Sp. Conductance (umho/cm)		
Latitude ☐ dd ☐ dms		Longitude ☐ dd ☐ dms		Salinity (ppt)		Comments		
Location		☐ Comp ☐ Grab	Collection (comp begin or grab) Date Time		Eastern Central	Composite end Date Time		Bottle Group(s)
Field ID		Matrix (type, e.g., Salt, Fresh, etc)		Diss. Oxygen ☐ mg/L ☐ % sat		Total Res. Chlorine (mg/L)		
WIN/STORET #		Temp (C)	pH	Sample Depth	☐ ft ☐ m	Sp. Conductance (umho/cm)		
Latitude ☐ dd ☐ dms		Longitude ☐ dd ☐ dms		Salinity (ppt)		Comments		

Relinquished By: L. Couch	Date/Time 1/24/2022	Shipping Method	Number of Coolers Shipped: 1	Received By: JHK	Date/Time 1.29.22/1235
------------------------------	------------------------	-----------------	---------------------------------	---------------------	---------------------------

Group: A	Bottle Type: P-250ML-WO-THI ECOLI-18QT	# of Bottles: 1	Preservative: ICE	Enter Number of Bottles Sent to Lab	1
Group: A	Bottle Type: P-250ML-WO-THI FCOLI-MF	# of Bottles: 1	Preservative: ICE	Enter Number of Bottles Sent to Lab	1
Group: A	Bottle Type: P-1L OV-CBOD-IN	# of Bottles: 1	Preservative: ICE	Enter Number of Bottles Sent to Lab	0 sent to Eurofins Contract lab
Group: A	Bottle Type: P-1L TURBIDITY W-TSS	# of Bottles: 1	Preservative: ICE	Enter Number of Bottles Sent to Lab	1
Group: A	Bottle Type: P-500ML W-ICP W-ICPMS	# of Bottles: 1	Preservative: HNO3	Enter Number of Bottles Sent to Lab	1
Group: A	Bottle Type: P-500ML W-NH3 W-NO2NO3 W-S-A-TP W-TKN W-TOC	# of Bottles: 1	Preservative: ICE And H2SO4	Enter Number of Bottles Sent to Lab	1
Group: B	Bottle Type: P-250ML TURBIDITY	# of Bottles: 1	Preservative: ICE	Enter Number of Bottles Sent to Lab	1
Group: B	Bottle Type: P-500ML W-ICP W-ICPMS	# of Bottles: 1	Preservative: HNO3	Enter Number of Bottles Sent to Lab	1
Group: B	Bottle Type: P-500ML W-NH3 W-NO2NO3 W-S-A-TP W-TKN W-TOC	# of Bottles: 1	Preservative: ICE And H2SO4	Enter Number of Bottles Sent to Lab	1

Northwest District: CSIs for FL0101192 Dolomite, Inc

Central Laboratory Submittal Form

last revised Jan 25, 2018

Customer: NW-DIST

Requester: Elaine Ignacio

Field Report Prepared By: Larry Couch

Project ID: CSI

Collected By: Larry Couch

Sampling Agency: FDEP

Location Dolomite, Inc. (sand mine)		☐ Comp ☒ Grab		Collection (comp begin or grab) Date 1/24/2022 Time 0845		Eastern Central ☒		Composite end Date _____ Time _____		Bottle Group(s) (See pg 2)	
Field ID Discharge Point D-001 Grab		Matrix (type, e.g., Salt, Fresh, etc) Fresh		Diss. Oxygen		☐ mg/L ☐ % sat		Total Res. Chlorine (mg/L)		A	
WIN/STORET #		Temp (C)		pH		Sample Depth		☐ ft ☐ m			
Latitude 30° 38' 50.24"		☒ dd ☒ dms		Longitude 85° 10' 35.32"		☒ dd ☒ dms		Salinity (ppt)		Comments NPDES ID# FL0101192	
Location		☐ Comp ☐ Grab		Collection (comp begin or grab) Date _____ Time _____		Eastern Central ☐		Composite end Date _____ Time _____		Bottle Group(s)	
Field ID		Matrix (type, e.g., Salt, Fresh, etc)		Diss. Oxygen		☐ mg/L ☐ % sat		Total Res. Chlorine (mg/L)			
WIN/STORET #		Temp (C)		pH		Sample Depth		☐ ft ☐ m			
Latitude		☐ dd ☐ dms		Longitude		☐ dd ☐ dms		Salinity (ppt)		Comments	
Location		☐ Comp ☐ Grab		Collection (comp begin or grab) Date _____ Time _____		Eastern Central ☐		Composite end Date _____ Time _____		Bottle Group(s)	
Field ID		Matrix (type, e.g., Salt, Fresh, etc)		Diss. Oxygen		☐ mg/L ☐ % sat		Total Res. Chlorine (mg/L)			
WIN/STORET #		Temp (C)		pH		Sample Depth		☐ ft ☐ m			
Latitude		☐ dd ☐ dms		Longitude		☐ dd ☐ dms		Salinity (ppt)		Comments	
Location		☐ Comp ☐ Grab		Collection (comp begin or grab) Date _____ Time _____		Eastern Central ☐		Composite end Date _____ Time _____		Bottle Group(s)	
Field ID		Matrix (type, e.g., Salt, Fresh, etc)		Diss. Oxygen		☐ mg/L ☐ % sat		Total Res. Chlorine (mg/L)			
WIN/STORET #		Temp (C)		pH		Sample Depth		☐ ft ☐ m			
Latitude		☐ dd ☐ dms		Longitude		☐ dd ☐ dms		Salinity (ppt)		Comments	
Location		☐ Comp ☐ Grab		Collection (comp begin or grab) Date _____ Time _____		Eastern Central ☐		Composite end Date _____ Time _____		Bottle Group(s)	
Field ID		Matrix (type, e.g., Salt, Fresh, etc)		Diss. Oxygen		☐ mg/L ☐ % sat		Total Res. Chlorine (mg/L)			
WIN/STORET #		Temp (C)		pH		Sample Depth		☐ ft ☐ m			
Latitude		☐ dd ☐ dms		Longitude		☐ dd ☐ dms		Salinity (ppt)		Comments	

Relinquished By: L. Couch	Date/Time 1/24/22	Shipping Method FEDEX	Number of Coolers Shipped: 1	Received By: HK	Date/Time 1.24.22 / 1235
-------------------------------------	-----------------------------	---------------------------------	--	---------------------------	------------------------------------

Group: A	Bottle Type: P-250ML-WO-THI ECOLI-18QT	# of Bottles: 1	Preservative: ICE	Enter Number of Bottles Sent to Lab	<u>0</u>
Group: A	Bottle Type: P-250ML-WO-THI FCOLI-MF	# of Bottles: 1	Preservative: ICE	Enter Number of Bottles Sent to Lab	<u>0</u>
Group: A	Bottle Type: P-1L OV-CBOD-IN	# of Bottles: 1	Preservative: ICE	Enter Number of Bottles Sent to Lab	<u>1</u>
Group: A	Bottle Type: P-1L TURBIDITY W-TSS	# of Bottles: 1	Preservative: ICE	Enter Number of Bottles Sent to Lab	<u>0</u>
Group: A	Bottle Type: P-500ML W-ICP W-ICPMS	# of Bottles: 1	Preservative: HNO3	Enter Number of Bottles Sent to Lab	<u>0</u>
Group: A	Bottle Type: P-500ML W-NH3 W-NO2NO3 W-S-A-TP W-TKN W-TOC	# of Bottles: 1	Preservative: ICE And H2SO4	Enter Number of Bottles Sent to Lab	<u>0</u>
Group: B	Bottle Type: P-250ML TURBIDITY	# of Bottles: 1	Preservative: ICE	Enter Number of Bottles Sent to Lab	<u>0</u>
Group: B	Bottle Type: P-500ML W-ICP W-ICPMS	# of Bottles: 1	Preservative: HNO3	Enter Number of Bottles Sent to Lab	<u>0</u>
Group: B	Bottle Type: P-500ML W-NH3 W-NO2NO3 W-S-A-TP W-TKN W-TOC	# of Bottles: 1	Preservative: ICE And H2SO4	Enter Number of Bottles Sent to Lab	<u>0</u>

Date of Request: 07-OCT-2021
 Created By: IGNACIO_E On: 07-OCT-2021
 Modified By: JASROTIA_P On: 01-NOV-2021
 Customer: NW-DIST
 Project: CSI
 Division:
 District: Northwest District
 Event Description: Northwest District: CSIs for FL0101192 Dolomite, Inc

Send Coolers To:

Phone: 850-767-0047
 Panama City Branch Office
 470 Harrison Ave
 Panama City, FL 32401-2732
 Attn: Larry Couch
 Cooler Ship EMail: Larry.Couch@FloridaDEP.gov

Priority: 3
 Event Status: S
 Criminal Investigation: NO
 Chemistry Request Reviewed By: WATTS_J On: 01-NOV-2021
 Biology Request Reviewed By: JASROTIA_P On: 01-NOV-2021
 Sampling Kit Required: YES Ship on: 05-NOV-2021
 Sampling Kit Shipped: YES On: 05-NOV-2021
 Sampling Kit Packed By: KLUG_K
 Preservatives Needed: YES
 Date to Receive Samples: 30-NOV-2021
 Logged In By:

Send Final Report To:

160 Government Center
 Suite 308
 Pensacola, FL 32502-5794
 Attn: Krista McGraw
 Report Notification EMail: Krista.McGraw@floridaDEP.gov

Comments: 2- vials sulfuric acid
 2- vials nitric acid

CSI inspections for FL0101192 Dolomite, Inc.

Bottle Group A -Effluent (grab)
 Bottle Group B -Field Blank

****OVERFLOW BOD to TestAmerica-Tampa****

Send additional:

- Overflow BOD Cover Letter
- Overflow BOD Task Assignment
- Extra RQ field sheets
- small cooler/liner/zip tie
- temp bottle
- Task Assignment needs to be complete before samples arrive at Tampa Lab

Eurofins/Testamerica
 Attn: Sample Receiving
 6712 Benjamin Rd., Suite 100
 Tampa, FL 33634
 813-885-7427

Bottle Group A (Water) With 1 Samples:

Bottle Type: P-250ML-WO-THI	Number of Bottles: 1	Preserved With: ICE
ECOLI-18QT	Template: DEFAULT	(SM 9223 B Quanti-Tray) Escherichia coli by Colilert 18 Quanti-Tray method - non-chlorinated water systems
Bottle Type: P-250ML-WO-THI	Number of Bottles: 1	Preserved With: ICE
FCOLI-MF	Template: DEFAULT	(SM 9222 D) Fecal coliforms by membrane filter method - non-chlorinated water systems
Bottle Type: P-1L	Number of Bottles: 1	Preserved With: ICE
OV-CBOD-IN	Template: DEFAULT	(SM 5210 B) BOD, nitrogen-inhibited (CBOD) at Eurofins Testamerica-Tampa
Bottle Type: P-1L	Number of Bottles: 1	Preserved With: ICE
TURBIDITY	Template: DEFAULT	(EPA 180.1 Rev. 2.0) Turbidity in aqueous matrices
W-TSS	Template: DEFAULT	(SM 2540 D-2011) Total Suspended Solids in aqueous matrices using a maximum of 250 mL of sample

Bottle Group A (Water) With 1 Samples:

Bottle Type: P-500ML	Number of Bottles: 1	Preserved With: HNO3
W-ICP	Template:	(EPA 200.7 Rev. 4.4) Total Recoverable Metals analysis using ICP emission spectroscopy for aqueous samples supporting Clean Water Act Projects
Calcium		
Iron		
Magnesium		
Potassium		
Sodium		
Zinc		
W-ICPMS	Template:	(EPA 200.8 Rev. 5.4) Total Recoverable Metals analysis using ICP-MS for aqueous samples supporting Clean Water Act Projects
Aluminum		
Arsenic		
Cadmium		
Chromium		
Copper		
Lead		
Nickel		
Selenium		
Silver		

Bottle Type: P-500ML	Number of Bottles: 1	Preserved With: ICE And H2SO4
W-NH3	Template: DEFAULT	(EPA 350.1 Rev. 2.0) Ammonia in aqueous matrices as mg N/L
W-NO2NO3	Template: DEFAULT	(EPA 353.2 Rev. 2.0) Nitrite/Nitrate in aqueous matrices as mg N/L
W-S-A-TP	Template: DEFAULT	(EPA 365.1 Rev. 2.0) Total Phosphorus in aqueous matrices as mg P/L
W-TKN	Template: DEFAULT	(EPA 351.2 Rev. 2.0) Total Kjeldahl Nitrogen in aqueous matrices
W-TOC	Template: DEFAULT	(SM 5310 B-2011) Nonpurgeable Organic Carbon in aqueous matrices

Bottle Group B (Water) With 1 Samples:

Bottle Type: P-250ML	Number of Bottles: 1	Preserved With: ICE
TURBIDITY	Template: DEFAULT	(EPA 180.1 Rev. 2.0) Turbidity in aqueous matrices
Bottle Type: P-500ML	Number of Bottles: 1	Preserved With: HNO3
W-ICP	Template:	(EPA 200.7 Rev. 4.4) Total Recoverable Metals analysis using ICP emission spectroscopy for aqueous samples supporting Clean Water Act Projects
Calcium		
Iron		
Magnesium		
Potassium		
Sodium		
Zinc		
W-ICPMS	Template:	(EPA 200.8 Rev. 5.4) Total Recoverable Metals analysis using ICP-MS for aqueous samples supporting Clean Water Act Projects
Aluminum		
Arsenic		
Cadmium		
Chromium		
Copper		
Lead		
Nickel		
Selenium		
Silver		
Bottle Type: P-500ML	Number of Bottles: 1	Preserved With: ICE And H2SO4
W-NH3	Template: DEFAULT	(EPA 350.1 Rev. 2.0) Ammonia in aqueous matrices as mg N/L
W-NO2NO3	Template: DEFAULT	(EPA 353.2 Rev. 2.0) Nitrite/Nitrate in aqueous matrices as mg N/L
W-S-A-TP	Template: DEFAULT	(EPA 365.1 Rev. 2.0) Total Phosphorus in aqueous matrices as mg P/L
W-TKN	Template: DEFAULT	(EPA 351.2 Rev. 2.0) Total Kjeldahl Nitrogen in aqueous matrices
W-TOC	Template: DEFAULT	(SM 5310 B-2011) Nonpurgeable Organic Carbon in aqueous matrices