



FLORIDA DEPARTMENT OF
ENVIRONMENTAL PROTECTION

NORTHWEST DISTRICT OFFICE
2353 JENKS AVENUE
PANAMA CITY, FLORIDA 32405-4389

RICK SCOTT
GOVERNOR

JENNIFER CARROLL
LT. GOVERNOR

HERSCHEL T. VINYARD JR.
SECRETARY

October 22, 2012

BY ELECTRONIC MAIL

sloand54@hotmail.com

Ms. Kathy Sloan, Vice President
Dolomite, Incorporated
Post Office Box 1568
Marianna, Florida 32447

Dear Ms. Sloan:

On October 15, 2012, Department representatives conducted a Fifth Year Inspection (FYI5) of the Dolomite Incorporated limestone mining facility in Jacksons County (Permit # FL0101192). An FYI5 is a suite of different evaluations that are conducted during the fifth year of a permit cycle to provide information and data the Department uses to assess potential impacts of wastewater discharges to surface waters and to formulate specific permit conditions for the next permit cycle. The Department would like to thank your representatives for their assistance during the inspection. An inspection report is attached for your review. Please note any bolded items which may indicate compliance issues requiring your immediate attention. A final report will be sent to you in the future updated with any new information obtained through analysis of the Department's samples.

At the time of the inspection, the facility was found to be operating **in compliance** with wastewater permit limits and/or state regulations.

Should you have any questions about the inspection or report, please contact Dan Crean at (850) 767-0054 or Daniel.J.Crean@dep.state.fl.us.

Sincerely,

Josie Penton
Environmental Manager

JP/dc

Enclosure (1)

c: Ed Smith, FDEP Tallahassee Office (Edward.C.Smith@dep.state.fl.us)
Kim Allen, FDEP Pensacola Office (Kim.Allen@dep.state.fl.us)
Michelle Fish, FDEP Tallahassee Office (Michelle.Fish@dep.state.fl.us)


Ms. Kathy Sloan
Page 2 of 6
October 22, 2012

Toni Edwards, FDEP Pensacola Office (Toni.Edwards@dep.state.fl.us)

FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

WASTEWATER COMPLIANCE INSPECTION REPORT

FACILITY AND INSPECTION INFORMATION

Name and Physical Location of Facility: Dolomite Incorporated 1321 Hwy 71 Marianna, FL 32448		WAFR ID: FL0101192		County: Jackson		Entry Date/Time: 10/15/12 9:11 AM	
				Phone: (850) 482-5570		Exit Date/Time: 10/15/12 10:04 AM	
Name(s) of Field Representative(s): Mr. David Thompson		Title: Manager		Operator Certification #: N/A		Phone: (850) 482-5570	
Name and Address of Permittee or Designated Representative: Ms. Kathy Sloan Dolomite Incorporated Pos Office Box Marianna, Florida 32448				Title: Vice President		Phone: (850) 482-5570	
Inspection Type:		F	Y	I5	Samples Taken? (Y/N): Y	Sample ID: RQ-2012-10-15-41	Samples Split? (Y/N): N/A
	Domestic	X	Industrial		Photos Taken? (Y/N): N	Logbook Volume: 1	Page: 123
Advance Notification Required (Security)					X	Facility Notified in Advance of Inspection	
FACILITY COMPLIANCE AREAS EVALUATED IC: In Compliance M: Minor NC: Out of Compliance SC: Significantly Out of Compliance NA: Not Applicable NE or Blank: Not Evaluated Significant Non-Compliance Criteria Should be Reviewed when Out of Compliance Ratings Are Given in Areas Marked by a "♦"							
PERMITS/ORDERS		SELF MONITORING PROGRAM		FACILITY OPERATIONS		EFFLUENT/DISPOSAL	
IC	1. ♦ Permit	IC	3. Laboratory	IC	6. Facility Site Review	IC	10. ♦ Effluent Quality
NA	2. ♦ Compliance Schedules	IC	4. Sampling	IC	7. Flow Measurement	IC	11. ♦ Effluent Disposal
		IC	5. ♦ Records & Reports	IC	8. ♦ Operation & Maintenance	N/A	12. Residuals/Sludge
	14. Other			N/A	9. Sanitary Sewer Overflow	N/A	13. ♦ Groundwater
Facility and/or Order Compliance Status:			X	In Compliance		Out of Compliance	Significantly Out of Compliance
Recommended Actions: See "Inspection Comments"							
Name and Signature of Inspector: Daniel J. Crean Jr. 				District Office/Phone Number: NWD/(850) 767-0054		Date: 10/15/12	
Name and Signature of Inspector:				District Office/Phone Number:		Date:	
Signature of Reviewer: Josie Penton 				District Office/Phone Number: NWD/(850) 767-0045		Date: 10/22/12	
Single Event Violation Code(s): , , , ,							

INSPECTION COMMENTS

PERMITS/ORDERS

1. PERMIT: In Compliance

FDEP Permit # FL0101192 was issued on July 18, 2008, for the operation of this facility and it expires on July 17, 2013. At the time of this inspection, the facility was in operation and a copy of the permit was onsite and available for review

Note: In accordance with Rule 62-660.804, Florida Administrative Code (FAC), to continue coverage under this permit beyond the expiration date for coverage, the permittee must complete and submit to the Department, at least 30 days prior to expiration of coverage, a Sand and Limestone Mine General Permit Notification Form, DEP Form 62-660.900(6), FAC.

2. COMPLIANCE SCHEDULES: Not Applicable

SELF MONITORING PROGRAM

3. LABORATORY: In Compliance

The facility's contract laboratory, Water Spigot, performs effluent analyses for total suspended solids (TSS), and turbidity. Mr. Homer Sims, a certified water plant operator for the City of Marianna performs the pH calibration and analysis for the facility.

pH Meters:

The calibration records were reviewed along with a daily verification of the meter with #7 and #10 buffers.

The pH 7 buffer expires November 2013 and the pH 10 buffer expires April 2014.

Note: During calibration verification of meters, if the values observed for chlorine, pH, turbidity, dissolved oxygen (DO) and specific conductance vary $\pm$ **NPDES** 10% for chlorine (or 20% if verifying an inline meter against a calibrated hand-held meter), 0.1 standard units for pH, 10% for turbidity (or 20% if verifying an inline meter against a calibrated hand-held meter), 0.3 mg/L for DO or 5% for specific conductance, **Non-NPDES** 10% for chlorine (or 20% if verifying an inline meter against a calibrated hand-held meter), 0.2 standard units for pH, 10% for turbidity (or 20% if verifying an inline meter against a calibrated hand-held meter), 0.3 mg/L for DO or 5% for specific conductance, it shall be assumed that the calibration of the meters is unstable. The cause of the instability must be determined and corrective actions must be taken to bring the meters into stable calibration, such as maintenance, repair or replacement.

4. SAMPLING: In Compliance

Effluent grab samples are being taken at the facility, in accordance with the facility permit.

5. RECORDS AND REPORTS: In Compliance

Records Review

A records review for the October 2012 effluent monitoring event indicated that information and data on chain of custody sheets, laboratory reports and Discharge Monitoring Reports (DMR) were consistent.

Required Submittals

DMRs are being submitted to the Department in a timely manner.

Note: A more efficient and paperless alternative to reporting discharge and groundwater monitoring data is available at <http://www.edmr.dep.state.fl.us>.

Plans, Manuals, Protocols, and Logs

The facility's Best Management Practice (BMP) Plan was onsite and available for review. It was written and designed by a certified engineer (David Melvin, Inc. consulting engineers August 2007), and it adequately identifies, contains and addresses the following:

Record drawing was onsite and it contained legible grading and elevation information on it.

Current staffing, sites and operations; narrative description of the facility; plots, plans, drawing and/or maps; area, systems or components with the potential to release pollutants to surface waters (due to equipment failure, improper operation, or natural phenomena); prediction of the direction, flow rate and total quantity of pollutants which could be discharged from the facility; and specific procedures to prevent pollutants from reaching State waters.

FACILITY OPERATIONS

6. FACILITY SITE REVIEW: In Compliance

Structures were in place to prevent entry of unauthorized individuals; site grading directs all wastewater and stormwater to swales/settling ponds; and settling pond discharge points function properly.

7. FLOW MEASUREMENT: In Compliance

Flows are estimated at the discharge culvert by timing the water velocity at the culvert and comparing the level/velocity to the chart developed by David Melvin Engineering.

8. OPERATION AND MAINTENANCE: In Compliance

The frequency of preventive maintenance inspections for this facility is daily when the facility is operating. Preventive maintenance inspections are frequent enough for proper operation. When

preventive maintenance issues arise, they are addressed immediately upon discovery if possible. Preventive maintenance records are being kept onsite.

9. SANITARY SEWER OVERFLOW: *Not Evaluated*

Note: Sanitary sewer overflow regulations only apply to domestic wastewater facilities. All industrial or domestic facilities however must report any unauthorized releases of wastewater (spills) to the Department. This requirement is applicable to all facilities with a discharge. If a spill is less than 1,000 gallons, and is not expected to reach surface waters, the report may be made to the District Office at (850) 595-0659 or (850) 595-0673, or to the State Watch Office (SWO) at (800) 320-0519. If the spill is 1,000 gallons or more, and/or if the spill (of any size) reaches surface waters, the report must be made to the SWO. If there is a question whether or not a spill has reached (or will reach) surface waters, the facility should err on the side of safety and report the spill to the SWO.

EFFLUENT/DISPOSAL

10. EFFLUENT QUALITY: *In Compliance*

Facility Self Monitoring Data

A review of the DMRs for the period from April 2012 to August 2012 indicated no violations of effluent quality requirements or permit limits.

Department Monitoring Data

Effluent samples were taken by the Department as part of this inspection and analyzed by the Department's Laboratories (NELAP #E31780). The lab results along with the Effluent Quality Assessment will be attached to the final report when completed.

11. EFFLUENT DISPOSAL: *In Compliance*

The mining operation produces a discharge of wastewater as a result of the flow from natural springs located within the mining area; there may also be a discharge of stormwater runoff in the event that rainfall exceeds a 25-year/24-hour storm. Final disposal is to surface waters of the state, Chipola River (Class III freshwater), a special Outstanding Florida Water (OFW).

12. RESIDUALS/SLUDGE: *Not Applicable*

This section does not apply to this facility.

13. GROUNDWATER: *In Compliance*

This section does not apply to this facility.

14. OTHER: *Not Applicable*