

## UC/Synergetic Design

P.O. Box #550  
Cottage Grove, MN 55016  
(612)-991-7267

**Evaluation Only. Created with Aspose.Words. Copyright 2003-2019 Aspose Pty Ltd.**

February 14, 2019

Notify #766723

RE: MCImetro Access Transmission Services Corp., Facility Attachment Asset Permit Application APA8429, in St. Paul, MN.

Xcel Energy Facility Attachments  
825 Rice St.  
St. Paul, MN 55117

I have completed the site inspection and technical review of MCImetro Access Transmission Services Corp. application, permit number APA8429. I have determined that all poles as indicated on the sketch can be attached to without any rearrangements or pole change-outs with the exception of the poles listed below. This determination was made by referencing the requirements for communications attachments found in the "Xcel Energy Electric Distribution Design and Construction Standards" manual.

It is the attaching utilities responsibility to make sure that all NESC and local ordinances for vertical clearance above surfaces (roads, alleys, fields, buildings etc.) are met.

### **Note!**

Total count of poles checked = 63. 30 – New Attachments

30 poles are owned by Xcel Energy. 33 poles are foreign owned. Total of 30 Xcel Energy poles can be attached to on this request.

Measurements were taken on February 2 with an ambient temperature of +14° F.

Poles of concern needing some sort of modification to meet clearance requirements are as follows:

**See notes in Xcel Energy Use Only columns of the Attachment Information sheet.**

**Please note:** Attachments must be tagged for communication ownership on every pole. Upon completion of project, Xcel Energy must be notified to complete a post inspection.

**Estimated costs for any required "make-ready" work will be provided by Xcel Energy Design Staff upon request. Attachments cannot be made until the cost estimate is approved, payment is made, and the requesting party is notified by Xcel Energy that the "make-ready" work has been completed in the field.**

**Any communication attachments that do not currently meet minimum required NESC clearances from electrical conductors must only be maintained by electrically qualified workers. Please contact Xcel Energy for assistance with correcting any such existing clearance violations or to create a work environment that is safe for any employees and contractors of the Lessee's to perform such work.**

Sincerely,



Jeff Renwick

● Page 2  
Joint Use Technician  
UC/Synergetic Design Inc.

February 13, 2019

